The HASHEMITE KINGDOM OF JORDAN

Ministry of Water and Irrigation Water Authority of Jordan





Feasibility Study, Environmental and Social Impact Assessment and Detailed Designs and Bidding Documents for Zarqa Governorate Wastewater System Reinforcement and Expansion Project

> PREPARATORY WORKS TECHNICAL REPORT



May 2010

BUILDING A BETTER WORLD

Client: WAJ

Project: Zarqa Governorate Wastewater Reinforcement and Expansion

Document Title: Preparatory Works Technical Report

| Main Contributors | Aspect/Section | Notes |
|-------------------|-----------------|-------|
| Ali Mas'ad | All | |
| Osama Zeyadeh | All | |
| Farah Ghniem | All | |
| Maher Abu Ali | Design criteria | |
| Ahlam Shelbayeh | Design criteria | |
| Murat Sarioglu | Design criteria | |

| Pro | Project Code:Document No:Controlled CopyD 1449447(in COLOUR - not black) | | No: 01 | | | | |
|----------------|--|-------|--------------------|----|-------|----------|-------------------------|
| Revision No | Date | Dese | cription/Amendment | Ch | ecked | Reviewed | Authorised for Issue |
| 00 | 4/2/2010 | Draft | | | SL | MJH | IH |
| 01 | 31/5/2010 | Final | | | SL | MJH | JAJ |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

ONLY CONTROLLED COPY HOLDERS WILL BE ISSUED WITH AMENDMENTS TO THIS DOCUMENT.

PLEASE DESTROY ALL SUPERSEDED COPIES OR

CLEARLY MARK THEM AS "SUPERSEDED".

Distribution Record

| DISTRIBUTION | | | | | |
|----------------|-------|--------------|--------------|--|--|
| Name | WAJ | MWH Dubai | MWH Amman | | |
| Revision 00 | 01-07 | 08 | 09 | | |

CONTENTS

| 1. | INTRODUCTION | 1-1 |
|---------------------------------|---|--|
| 1.1 1.2 1.3 1.4 1.5 | General Background Objective Project Location Preparatory Works Technical Report | 1-1 1-1 1-2 1-3 1-4 |
| 2. | EXISTING SITUATION | 2-1 |
| 2.1 2.2 2.3 2.4 | Introduction Existing Service Area Physical Characteristics 2.3.1 Topography 2.3.2 Climate 2.3.3 Geology and Geotechnical Study Wastewater System 2.4.1 Wastewater Collection System 2.4.2 Wastewater Pumping Stations and Pumping Mains | 2-1 2-1 2-1 2-2 2-2 2-4 2-21 2-21 2-23 |
| 3. | REVIEW AND COMMENTS ON PREVIOUS STUDIES | 3-1 |
| 3.1 3.2 3.3 | Introduction Summary of Previous Studies Comments on Previous Studies | 3-1 3-1 3-4 |
| 4. | PLANNING CONSIDERATIONS AND PROJECTIONS | 4-1 |
| 4.1 4.2 4.3 4.4 | Introduction Planning Criteria 4.2.1 General Criteria 4.2.2 Planning Period 4.2.3 Service Area 4.2.4 Level of Service – Sewer Coverage Population 4.3.1 Projections 4.3.2 Spatial Distribution 4.3.3 Population Projections of Tributaries from Amman Areas Wastewater Flow 4.4.1 Water Consumption 4.4.2 Wastewater Generation Factors | 4-1 4-1 4-1 4-2 4-3 4-3 4-3 4-3 4-4 4-7 4-7 4-7 |
| _ | 4.4.3 Wastewater Projection 4.4.4 Wastewater Flow Projections from Amman Tributaries | 4-8 4-8 |
| 5. | DESIGN CRITERIA | 5-1 |
| 5.1 5.2 | Introduction General Criteria 5.2.1 Design Horizon 5.2.2 Design Life | 5-1 5-1 5-1 5-1 |
| 5.3 | Collection Network Design Criteria 5.3.1 Hydraulic Design of Gravity Sewers 5.3.2 Sewer Design and Installation Considerations | 5-2 5-2 5-6 |

| 5.4 | 5.3. 5.3. 5.3. Pumping S 5.4. 5.4. 5.4. 5.4. 5.4. 5.4. 5.4. 5.4 | House Connections Manholes Pipe Material for Gravity Sewers tation Design Criteria General Pumping Station Pump Station Components Pre-treatment Facilities Odour Control Works Design Criteria Pumping Mains Water Hammer Electrical Design Criteria | 5-7 5-8 5-11 5-11 5-12 5-13 5-14 5-17 5-21 5-23 5-24 |
|--------------------------|---|--|--|
| 6. | TOPOGRA | PHICAL SURVEY OF MAIN SEWER SYSTEM | 6-1 |
| 6.1 6.2 6.3 6.4 | Introduction Benchmark Surveying I Surveying I | n is and Triangle Points Works Data | 6-1 6-1 6-2 6-3 |
| 7. | FLOW MO | NITORING | 7-1 |
| 7.1 7.2 7.3 7.4 | Introduction Flow Monitoring Location Selection and Preparation Flow Monitoring Flow Monitoring Data | | 7-1 7-1 7-2 7-2 |
| 8. | WASTEWA | ATER MANAGEMENT STRATEGY | 8-1 |
| 8.1 8.2 8.3 | Introduction Main Wastewater Collection Zones Extension Areas 8.3.1 Extension Areas that Drain into Existing System 8.3.2 Extension Areas that Drain into New Pumping Stations / WwTP | | 8-1 8-1 8-1 8-2 8-2 |
| 8.4 | Main Waste | ewater Options | 8-3 |
| APPEN | NDICES | | |
| APPEN | NDIX 1 | LIST OF COLLECTED DATA | 1 |
| APPEN | NDIX 2 | WZPS YEAR 2009 OPERATIONAL DATA | 1 |
| APPEN | NDIX 3 | EZPS YEAR 2009 OPERATIONAL DATA | 1 |
| APPEN | NDIX 4 | POPULATION PROJECTIONS | 1 |
| APPEN | NDIX 5 | WASTEWATER FLOW DISTRIBUTION PROJECTIONS | 1 |
| APPENDIX 6 TOPOGRAPHICAL | | TOPOGRAPHICAL SURVEY OF MAIN SEWER SYSTEM | 1 |
| APPEN | NDIX 7 | FLOW MONITORING DATA | 1 |

LIST OF TABLES

| Table 2.1 | Description of Soil Units of the Geotechnical Study Area (Ministry of Agriculture (MOA), 1994) | 2-6 |
|------------|---|------|
| Table 2.2 | Geological and Hydrogeological Classification of the Rock Unit in Amman-Zarqa Area (Rimawi, 1985) | 2-11 |
| Table 2.3 | Summary of Slopes of Cuts in Soil and Rock Strata | 2-18 |
| Table 2.4 | Allowable Bearing Capacity for Soil and Rock Material | 2-20 |
| Table 2.5 | Length of Sewers Cleaned During 2008-2009 (m) | 2-22 |
| Table 2.6 | Summary of Lengths of Existing Gravity Sewers * | 2-22 |
| Table 4.1 | Department of Statistics Zarqa Governorate Projected Population | 4-3 |
| Table 4.2 | Populations Projections of Major Development Areas | 4-3 |
| Table 4.3 | Proposed Zarqa Governorate Population Projection | 4-4 |
| Table 4.4 | Population Growth Rates in Project Areas | 4-5 |
| Table 4.5 | Projected Zarqa Governorate Population | 4-6 |
| Table 4.6 | Population Projections of Tributary Areas of Amman | 4-7 |
| Table 4.7 | Water Consumption Projections as per MWI Policy Note | 4-8 |
| Table 4.8 | Wastewater Generation Projections of Zarqa Governorate (m ³ /d) | 4-8 |
| Table 4.9 | Wastewater Flow Projections from Tributaries of Amman (m ³ /d) | 4-9 |
| Table 5.1 | Design Life | 5-1 |
| Table 5.2 | Design Flow Depth vs. Diameter | 5-3 |
| Table 5.3 | Minimum Gradients of Sewers vs. Pipe Diameters | 5-4 |
| Table 5.4 | Minimum Gradients of 200 mm Sewers for Self Cleansing as a Function of Connected Population | 5-4 |
| Table 5.5 | Peaking Factors for Design of Sewers | 5-5 |
| Table 5.6 | Bedding Factor for Concrete Pipes | 5-7 |
| Table 5.7 | Maximum Spacing between Manholes | 5-8 |
| Table 5.8 | Manhole Internal Diameters | 5-8 |
| Table 5.9 | Recommended Pipe Material | 5-11 |
| Table 5.10 | Design Criteria for Air Extraction Rates at Pumping Station Facilities | 5-17 |
| Table 5.11 | Stack Discharge Quality | 5-18 |
| Table 5.12 | Activated Carbon Quality Standards | 5-21 |
| Table 5.13 | Friction Coefficients (C values) | 5-22 |
| Table 6.1 | List of Benchmarks Obtained from the Royal Geographic Center | 6-1 |

| Table 6.2 | List of Triangulation Points Obtained from the Land and Survey Department | 6-1 |
|-----------|--|-----|
| Table 6.3 | Manhole Survey Summary | 6-3 |
| Table 6.4 | Summary of Proposed Main Trunk Line Land Survey | 6-4 |
| Table 7.1 | Summary of Daily Flow Averages Over 1 Week Monitoring Period | 7-2 |

LIST OF FIGURES

| Figure 1.1 | Location Map of Study Area | 1-4 |
|-------------|--|------|
| Figure 2.1 | Existing Service Area | 2-1 |
| Figure 2.2 | Monthly Rainfall at Zarqa Station | 2-3 |
| Figure 2.3 | Monthly Rainfall at Bala'ama Station | 2-3 |
| Figure 2.4 | Mean Monthly Temperature at Amman Airport Station | 2-4 |
| Figure 2.5 | Key Plan Showing Area of Geotechnical Study | 2-4 |
| Figure 2.6 | Dominant Soil Units in the Geotechnical Study Area | 2-5 |
| Figure 2.7 | Land Use Map of the Geotechnical Study Area | 2-7 |
| Figure 2.8 | Geology of the Amman-Zarqa Basin (AZB), Modified after the Natural Resources Authority (NRA), 2000 | 2-10 |
| Figure 2.9 | Geological Map of the Geotechnical Study Area | 2-12 |
| Figure 2.10 | Regional Groundwater Contour Map of the Amman – Wadi Sir (B2/A7) Aquifer (BGR and WAJ, 1996) | 2-14 |
| Figure 2.11 | Location Map of Groundwater Wells in the Vicinity of the Geotechnical Study Area | 2-15 |
| Figure 2.12 | Groundwater Contour Map of the B2/A7 Aquifer System in the Geotechnical Study Area (masl) | 2-16 |
| Figure 2.13 | Depth of Ground Water From Natural Ground | 2-17 |
| Figure 2.14 | Location Map of Springs in the Vicinity of the Geotechnical Study Area | 2-19 |
| Figure 2.15 | Exisitng Zarqa Wastewater System | 2-22 |
| Figure 4.1 | Proposed Study Service Area | 4-2 |
| Figure 5.1 | Typical Cross Section of Aerated Grit and Grease Removal Chamber | 5-16 |
| Figure 6.1 | Existing Main Lines (Surveyed) | 6-2 |
| Figure 6.2 | Survey of Existing Manholes | 6-3 |
| Figure 6.3 | Survey Benchmarks and Proposed Trunk Lines | 6-3 |
| Figure 7.1 | Locations of Flow Monitoring Stations | 7-3 |
| Figure 8.1 | Main Wastewater Collection Zones | 8-1 |
| Figure 8.2 | Proposed Collection System Extensions | 8-2 |
| Figure 8.3 | Option 1: Treatment at Wadi Zarqa WwTP | 8-4 |
| Figure 8.4 | Option 2: Treatment at As Samra WwTP and Conveyance of Sukhneh and Wadi Zarqa Zones to WZPS | 8-4 |

| Figure 8.5 | Option 3: Treatment at As Samra WwTP and Conveyance of Sukhneh and Wadi Zarqa Zones to EZPS | 8-4 |
|------------|---|-----|
| Figure 8.6 | Option 4: Treatment at As Samra WwTP and Local Plant for Birein towns Conveyance of Sukhneh Zone to WZPS | 8-4 |
| Figure 8.7 | Option 4a: Treatment at As Samra WwTP, Local Treatment for Birein Communities, Conveyance of Sukhneh Zone to EZPS, Colection of Hai Ameera Haya at Sukhneh PS | 8-4 |
| Figure 8.8 | Option 5: Treatment at As Samra WWTP, Local Treatment for Birein Communities, New WZPS in Sukhneh & New ZPS | 8-4 |

ACRONYMS AND ABBREVIATIONS

Institutions

| GoJ | Government of Jordan |
|------|--|
| JMD | Jordan Meteorology Department |
| MWI | Ministry of Water and Irrigation |
| WAJ | Water Authority of Jordan |
| MCC | Millennium Challenge Corporation |
| MCA | Millennium Challenge Account |
| GTZ | German Technical Cooperation |
| OMS | Operation and Management Systems Project |
| MoE | Ministry of Environment |
| RSCN | Royal Society for the Conservation of Nature |
| | |

DOS Department of Statistics

WHO World Health Organisation

Facilities

| AGTP | Ain Ghazal Preliminary Treatment Plant |
|------|--|
| WZPS | West Zarqa Pumping Station |
| EZPS | East Zarqa Pumping Station |

Technical Terms

| BOD | biochemical oxygen demand |
|-------|---------------------------------|
| cm | centimetre |
| COD | chemical oxygen demand |
| D, d | day |
| Dunum | 1000 square metres |
| EIA | environmental impact assessment |
| GIS | geographic information system |
| На | hectare (10,000 square metres) |
| Kg | kilogram |
| Km | kilometre |
| L, I | litre |
| М | metre |
| MCM/y | million cubic metres per year |
| mg | milligrams |
| mm | millimetre |
| TOR | Terms of reference |
| TWw | treated wastewater |
| WwTP | wastewater treatment plant |
| Ү, у | year |
| | |

1. INTRODUCTION

1.1 <u>General</u>

MWH was retained by the Ministry of Water & Irrigation / Water Authority of Jordan (MWI/WAJ) on November 19th, 2009 to perform consulting services for the preparation of the feasibility study, environmental and social impact assessment and detailed designs and bidding documents for Zarqa Governorate wastewater system reinforcement and expansion. The key objective of this programme is to provide a substantial improvement in the existing levels of service in terms of extending the collection services to as many of the population as possible and to eliminate the spilling of sewage from the collection systems and secure additional fresh volumes of water to Zarqa and Amman Governorates through the substitution of treated wastewater for the fresh water supplied from the Jordan Valley.

The study is divided into two stages: Stage I is the base contract, whereas Stage II is optional, and will start only upon authorization after a compact is signed with the Millennium Challenge Corporation (MCC). Stage I of the study includes preparatory studies that are required to define an investment programme; preliminary environmental and social assessment; preliminary designs; and the assessment of feasibility of the investment program, including economic analysis. Stage II is the preparation of an EIA, detailed design and contract documents; and is dependent upon the successful completion of Stage I.

The study area includes the whole of Zarqa Governorate. However flows from some of Amman catchment areas that flow downstream of Ain Ghazal pre-treatment facility will be considered in the upgrading measures of the existing Zarqa wastewater system as these areas are already connected to the Zarqa wastewater system.

1.2 Background

The Zarqa Governorate extends from Zarqa River in the west to the Saudi border in the east with year 2004 population of 799,000, about 15% of the national population. However, ninety percent of the population is concentrated in the Zarqa, Russeifa and al-Hashemiyah metropolitan area. This urban area is the second largest metropolitan area in Jordan after Amman with year 2004 population of 687,000 and because of its proximity to Amman many urban development projects are planned in the area such as the King Abdullah Bin Abdul Aziz City, with a planned population of 400,300 by year 2035.

The first piped sewerage system was constructed in 1985 serving the central areas of Zarqa and Russeifa cities. Today the total length of the gravity sewer network is about 851 km of diameter 200 – 1000 mm, serving most of Zarqa, Russeifa and al-Hashemiyah areas.

The existing collection systems are supported by three existing pumping stations (West Zarqa, East Zarqa and Hitteen). West Zarqa pumping station serves west Zarqa area that drains towards Zarqa River and Russeifa in addition to flows coming from parts of Amman that drain downstream of Ain Ghazal preliminary treatment plant. East Zarqa pumping station located in al-Hashemiyah serves the eastern parts of Zarqa and al-Hashemiyah. Hitteen pumping station is small lifting station serving a small section of Hitteen camp in Russeifa.

All collected wastewater at West Zarqa and East Zarqa pumping stations is delivered to As Samra WwTP via 1200 mm diameter and two-500 mm diameter pumping mains respectively.

The existing wastewater collection system is designed as a separate collection system, which is not sized for stormwater collection.

Presently, the deficiencies in the sewerage system in Zarqa Governorate are such that they represent a danger to public health. The deficiencies can be outlined as follows:

- 1. Blocked sewers by sand, silt and grease, causing spills of raw sewage into the street. Some of the sewers have been found to be more than half full with sediments. This can be explained in various ways: low velocities in sewers; poor condition of some pipes and manholes; and poor maintenance of the sewerage system.
- 2. Several segments of the collection system are overloaded during rain events, causing backup into streets, wadis, and, in some rare cases, into residences. These wet weather problems are largely attributed to unauthorized storm drain connections from many buildings, as well as open manhole covers in flooded streets and wadis.
- 3. Inadequate pumping (storage) capacity at the pumping stations to cater for rain events. Stormwater collected through the sewer system is allowed to overflow into Zarqa River.

The other major problem with the existing sewer system in Zarqa Governorate is its extent. The last records obtained from WAJ show that the total number of subscribers for water services in 2009 is 130,948, while the number of subscribers for wastewater services is 94,265, which indicates that approximately 72% of households with water connections are sewered.

Future wastewater generation rates are expected to increase to 192,000 m³/day by the year 2035, which is more than double the present level.. It is urgent to improve, renew and extend the wastewater collection, treatment and disposal systems.

To address these issues, this project will study the extension of the coverage of piped sewerage within Zarqa Governorate to areas that are not presently connected, the expansion of the trunk sewer system to better cope with present and future demand, the reduction of the number of blockages and sewage overflows through the upgrading of trunk sewers, and the increasing of wastewater volumes being collected and treated.

1.3 <u>Objective</u>

Jordan is considered to be one of the 10 poorest countries worldwide in water resources. The available renewable water resources per capita have dropped drastically to an annual per capita share of less than 160 m³ in recent years, compared to 3600 m³ per capita in 1946. Thus, the water sector strategy stresses the need for improved resource management, with particular emphasis being placed on the sustainability of the present and future uses. Special care is advocated for protection against pollution, quality degradation and depletion of water resources.

Accordingly, this project aims to plan and prepare urban sanitation improvements in Zarqa Governorate for a project proposal for MCC funding, with the intended purpose to provide collected wastewater, to be later processed and treated, and then used as a substitute for non-domestic purposes (irrigation, industrial, etc), in order to reduce demand on the limited domestic quality water resources.

Fulfilling the objectives of this project will result in a significant general benefit to the entire population of Zarqa due to the decrease or elimination of sewage overflows and the resulting health risks and costs and there will be specific benefit to that part of the population who are presently served only by water and not by sewer when the piped sewerage system is extended.

The project should also be a benefit to people living downstream from Zarqa, near the wadis, due to reduced pollution resulting from the extension of the piped sewerage coverage and the increase in treatment capacity.

Therefore, the objectives of this project are to:

- achieve an overall understanding of the present sanitation conditions and of future requirements;
- determine satisfactory service levels and standards commensurate with affordability and environmental concerns;
- project the long-term needs of physical works and how they should be phased in view of investment requirement and availability of funds and criteria to be set on priorities;
- provide justifications for investments in view of expected impacts;
- ensure that the facilities to be provided are least cost solutions, financially and environmentally sustainable and appropriate to the circumstances;
- arrive at the most feasible alternatives for expansion and upgrading of the wastewater collection systems;
- preparation of feasibility study and detail designs and tender documents for the expansion and upgrading of the sanitation systems in Zarqa Governorate.

In order to achieve these objectives, the following scope of services has been developed. The defined tasks are:

- 1. Stage I: Preliminary Design, ESA, Feasibility Study and Economic analysis
- Task 1: Collection of data and preparatory works
- Task 2: Hydraulic model, analysis of options and Master Plan
- Task 3: Preliminary environmental and social assessment
- Task 4: Feasibility study, preliminary design and work plan
- 2. Stage II: EIA and Detailed Design and Preparation of Contract Documents (optional)
- Option A: Environmental impact assessment
- Option B: Preparation of detailed designs and contract documents

The study will include developing and detailing an investment programme to reinforce and expand the wastewater system of Zarqa Governorate, conducting a feasibility study and undertaking environmental and social assessments, developing reliable and realistic cost estimates for the proposed investments and developing detailed engineering design and bidding documents for construction.

This study will then form the basis to identify the investment project to be potentially funded by MCC, under a compact that is currently under preparation.

1.4 <u>Project Location</u>

Zarqa Governorate is located in the central-northern part of Jordan with an area of 2,451 km². The location of the study area for the project is depicted in Figure 1.1.

Zarqa River, the second largest river in Jordan, runs through the cities of Russeifa and Zarqa and drains westward towards the Jordan Valley and the King Talal Reservoir.



Figure 1.1 Location Map of Study Area

1.5 <u>Preparatory Works Technical Report</u>

The purpose of this Preparatory Works Technical Report is:

- to present the Team's understanding of the exiting situation. The physical characteristics of the project area along with assessment of the existing wastewater facilities are presented in Section 2;
- to present the results of the review of the past reports for the study area;
- to present the planning considerations that will be adopted in developing the master plan. Planning criteria including population, water consumption and wastewater generation projections are presented in Section 4;
- to present the design criteria of the different project components that will be used in the design and costing of the wastewater system expansion and reinforcement programme;
- to present the results of the topographical survey of the main sewer system in the project area;
- to present the results of the flow monitoring survey; and
- to identify the different options for the expansion of the wastewater collection systems that will be evaluated.

2. EXISTING SITUATION

2.1 Introduction

To formulate a realistic Master Plan for the expansion and reinforcement of the Zarqa wastewater system, a thorough understanding of the existing situation within the study area is required. This section presents the team's understanding of the existing situation, covering such topics as a definition of the proposed study area, the physical characteristics of the study area and a description of the existing wastewater systems and their current condition.

2.2 Existing Service Area

The extent of the existing wastewater services within the Zarqa Governorate, which is under the direction of the Zarqa Water Directorate, is shown in Figure 2.1. In general, the existing sewerage system covers only the cities of Zarqa, Russeifa, al-Hashemiyah and the Zarqa Free Zone.

2.3 **Physical Characteristics**

2.3.1 Topography

The general topography of the project area is rolling to hilly, resulting in the formation of small catchment areas. Each catchment area drains locally into a tributary wadi that drains into a larger wadi and so on until all drain into Wadi Zarqa which represents the collector of the study area.

Wadi Zarqa flows north as it leaves the urban area, but at its confluence with Wadi Dhuleil near Sukhneh it turns west to flow into King Talal Reservoir (KTR). The elevation in the study area ranges from about 500 m to about 800 m.

Wastewater collection areas in the Amman-Zarqa River basin are designed based on topography to allow gravity collection. Based on the surface topography of the study area, the Zarqa wastewater network system could be divided into five major catchment zones:

- 1. West Zarqa Pumping Station (WZPS) Zone,
- 2. East Zarqa Pumping Station Zone (EZPS) Zone,
- 3. Sukhneh Zone, and
- 4. Wadi Zarqa Zone
- 5. Wadi Dhuleil Zone

Within each of the above mentioned major catchments, the topography allows sewers to drain by gravity through existing roads or through natural wadis.

The topography of the WZPS zone allows to serve by gravity the unsewered neighbourhoods in west of Zarqa such as Hai al-Falah, Hai al-Dweik, Hai Hai Umm Bayadhah, Hai al-Madadinah al-Munawarah, Hai al-Jneineh, and al-Majd City Also, in Russeifa the neighbourhoods of Hai al-Rasheed al-Shamali and Hai al-Qadissiyah will be served by gravity. All mentioned neighbourhoods within this zone will be served through the existing sewer networks. The topography of EZPS zone allows to serve the by gravity the unsewered neighbourhoods in eastern of Zarqa such as Hai al-Batrawi and King Abdullah City through the existing sewer network..

The topography of Sukhneh zone allows to serve by gravity the unsewered neighbourhoods in west of Zarqa such as such as Hai Makka al-Mukarramah, Hai Hai al-Ahmad, Hai al-Jabr, Hai Nassar, Hai al-Ameera Haya, Hai Shomar, Hai al-Bustan, Hai al-Hashemi, Salheyah, Abu al-Zeighan, and Sukhneh. All mentioned communities will be served via the proposed Sukhneh Pumping Station.

The topography of Wadi Zarqa Zone is relatively steep and allows to serve remote and isolated communities such as Birein, Umm Rummanah, Maqam Essa, Dogara, etc toward the proposed Wadi Zarqa Wastewater Treatment Plant.

The topography in the east is relatively milder than the west. In that area Dhuleil drains through Wadi Dhuleil until reaching the vicinity of As Samra Treatment Plant where a pumping facility is required to lift the flow up to the inlet.

2.3.2 Climate

The climate in Jordan is predominantly Mediterranean, with hot and dry summers and cool, wet winters with two short transitional periods in the autumn and spring. During those short transitional periods, most convective activity occurs, producing thunderstorms. The precipitation pattern is dependent upon both latitude and altitude. Rainfall decreases from north to south, west to east, and from higher elevations to lower ones (JMD 2003).

Most of the rainfall in Jordan occurs in the winter and spring, from November through April in some years. Historically, the maximum amount of rain occurs during January. The amount and the period of rainfall are highly variable, and they fluctuate widely from year to year. Within the study area, humidity and precipitation decrease rapidly moving from the Amman plateau towards the eastern deserts.

The average annual rainfall varies from less than 200 mm in the northeast to more than 500 mm in the northwest, close to Bal'ama. The average maximum daily rainfall is 61.8 mm/d in January. The average daily temperature is 12.4 °C during the wet season (from November to April) and 23.2 °C during the dry season (from May to October). The average minimum daily temperature in the study area, which occurs in January is about 4.1 °C and the average maximum daily temperature is about 33.1 °C. The prevailing wind direction in the study area is west-southwest in winter, shifting to west-northwest in summer. The average daily wind speed is 2.1 m/s, ranging between 1.9 and 2.3 m/s in winter and 1.6 and 2.4 m/s in summer. The average daily relative humidity varies from 65.2 to 82.6% in winter and from 59.2 to 71% in summer.



Figure 2.2 Monthly Rainfall at Zarqa Station



Figure 2.3 Monthly Rainfall at Bala'ama Station



Figure 2.4 Mean Monthly Temperature at Amman Airport Station

2.3.3 Geology and Geotechnical Study

The geology and geotechnical study is required to collect basic data for the establishment of design criteria and for design work within the frame of the Preliminary Study. Accordingly, the study area was selected based on the anticipated new construction works. A key plan showing the area in which a geotechnical study was conducted for the purposes of this project is presented in Figure 2.5.

Soil Units and Land Use of the Geotechnical Study Area

Soil Units of the Geotechnical Study Area

Soil is the uppermost layer of the earth's crust, which develops slowly as a result of weathering processes. Different types of soil develop at distinct sites, depending on the type of exposed rock, as well as parameters such as the amount of rainfall, wind, solar radiation, temperature, vegetation and land use. Generally, four soil groups can be distinguished in Jordan (Bender 1974):

Grey desert soils (Sierosem), formed under arid conditions (<150 mm precipitation/yr);

- Red Mediterranean soils, formed under sub-humid conditions (>600 mm precipitation/year) and semi-arid conditions (precipitation between 300 and 600 mm a year);
- Yellow steppe soils, formed under semi-arid and arid conditions (between 150-300 mm precipitation/yr); and
- Yellow Mediterranean soils (transitional type of soil between the red Mediterranean soils and the yellow steppe soils), formed under semi-arid climatic conditions (250-350 mm precipitation/yr).

In the study area Nisab (NIS) and Abu Salih (ALI) soil types are the dominant soil units as shown in Figure 2.6 and Table 2.1. The Nisab soil unit is a dissected plateau in the Belqa Group limestones producing narrow interfluve crests and long valley slopes with gradients between less than 10 and 20%. It contains silty clay loam and clay loam (very highly

calcareous and weakly to moderately saline) at depths of more than 80 cm. On the other hand, it contains very stony silty clay loam (very high calcareous and weakly saline) at depths of less than 50 cm.

The Abu Salih soil unit (ALI) is finely dissected limestone uplands and slopes with gradients ranging between 5-35 %, with some valley sides up to 70 %. It characterized by deep (at depths of more than 80 cm) silty clay that is highly calcareous and non-saline in some parts and very shallow (less than 25 cm) gravely silty clay loam on limestone, highly calcareous and non-saline.



Figure 2.6 Dominant Soil Units in the Geotechnical Study Area

Table 2.1 Description of Soil Units of the Geotechnical Study Area (Ministry of Agriculture (MOA), 1994)

| Soil Unit | Description | Soil association | Description |
|--------------------|---|---|---|
| Abu Salih (ALI) | Finely dissected limestone uplands and slopes: moderately dense dendritic drainage: gradients in range 5-35% with some valley sides up to 70%: altitude 500- 1000m: relative relief 100-150m. | Typic and Calcixerollic Xerochrept Rock | 40%: deep (>80cm) silty clay: highly calcareous and non-saline: occurs in colluvium of middle and lower slopes and in valley bottom alluvium: gradients 2- 35%. 20% |
| Nisab (NIS) | Dissected plateau Belqa Group limestones producing narrow interfluve crests and long valley slopes: colluvials mantle on upper and middle slopes, alluvial fans on lower slopes: altitude 550-750m: relative relief 100m | Xerochreptic Camborthid and Calciorthid Lithic (Xerochreptic) Camborthid Rock | 40%: deep (>80cm) silty clay loam and clay loam: very highly calcareous and weakly to moderately saline: formed in loessic gradients <10%. 40%: shallow and very shallow (<25-50cm) very stony silty clay loam: formed in thin loess mantle of upper slopes, crests and valley shoulders: very highly calcareous and weakly saline: gradients 0- 50%. 5%. |

Land Use Map of the Geotechnical Study Area

The land use map for the Geotechnical Study area is constructed based on the land use map of the Amman-Zarqa basin, and is presented as Figure 2.7. The land use types of the Geotechnical study area comprises 90 % as bare rock, thin soils and urbanization and 10% as natural vegetation, forest, irrigated agriculture (cereals, vegetables, fruit trees, olives, bananas and citrus) and rained agriculture (cereals, vegetables, fruit trees, olives, bananas and citrus). The land use ranges from urban and associated non-agricultural land (built-up areas, quarries and mines), to non-vegetated and sparsely vegetated land (basalt, bare rocks), to open field crops and fallow lands (rain-fed areas with a very low intensity of< 35 % cropping), and finally to ancient villages and archaeological sites.



Figure 2.7 Land Use Map of the Geotechnical Study Area

Geology

Geology of the Amman-Zarqa Basin

The geology of the Geotechnical study area falls within the geology of Amman-Zarqa Basin. The outcropping of Amman-Zarqa Basin extends from Lower Cretaceous (except wadi deposits which are Quaternary) to recent age, which is belonging to the Ajlun and Belqa Groups according to Jordanian classification (Table 2.2 and Figure 2.8). However, the Kurnub Group (Lower Cretaceous) is usually found at certain depths except where it outcrops in western parts of the study area (Baq'a Valley) along the axis of Suweileh anticline. In addition, the older Zarqa Group (Jurassic-Triassic age) occurs at considerable depth (Howard Humphreys 1983).

Lithologically, Amman-Zarqa Basin includes the following (from old to young):

- 1. Zarqa Group: this group consists of sandstone, shale, dolomite and dolomitic limestone, marl, gypsum and intercalation of volcanic ash. Its thickness reached up to 1000 meters as encountered at Wadi Rimam (south of Amman).
- 2. Kurnub Group: this group is exposed in the western parts of Amman-Zarqa Basin at Baq'a Valley. It mainly consists of white, grey and multicolored sandstone (weakly cemented fine-medium and coarse grained) with red silts, shales and dolomite streaks. The top of this group is known as the Subeihi Formation, which mainly consists of red-brown varicolored sandstone with a large portion of marl, clay and siltstone. On the other hand, the lower part of this group is known as Aarda Formation which consists of yellow-white sandstone with shale partings and dolomite streaks. The thickness of Kurnub Group has been encountered between 200-300 meters (USAID and WAJ 1989). The age of this formation is Lower Cretaceous.
- 3. The Ajlun Group overlays the Kurnub Group and consist of five formations, namely: the Naur (A1-2); the Fuheis (A3); the Hummar (A4); the Shuayb (A5-6) and the Wadi as Sir (A7).
- 4. The Belqa Group overlays the Ajlun Group and consists of five formations, namely: Wadi Umm Ghudran (B1); Amman-Al Hisa (B2); Muwaqqar (B3); Umm Rijam (B4) and Wadi Shallala (B5). However, Wadi Shallala formation is not represented in the geology of Amman-Zarqa Basin.

Geology of the Geotechnical Study Area

The outcropping rocks in the study area mainly consist of Ajlun group (A4, A5/6 and A7) and Balqa Group (B1 and B2). Soil cover is generally thin, although local topography has led to accumulation of wind-blow soils in numerous places. Valleys are generally filled with alluvial deposits of gravel, boulders, and pebbles. The Amman Formation B2 (Santonian – Campanian) consists of cyclic deposits of chalk, phosphate, silicified phosphate, limestone and chert. The limestone is occasionally silicified. In the Amman-Ruseifa and Zarqa areas, two members of the formation are recognized:

- Upper chalk-marl and phosphate member (26-27m thick in Russeifa); and
- Lower chert-limestone member (about 90m east of Amman).

Geologic Structures of the Project area

The study area possesses various structural features indicating that Jordan Dead Sea Transform represents the structural control of the region.

The Amman - Hallabat Structure is a major structure in the study area, which extends between the area southwest of Amman and northeast of Qasr Al-Hallabat. The structure was formed as a result of the lateral compression zone beginning from Siyagha at the northeastern comer of the Dead Sea towards Qasr Al-Hallabat, and passing through an echelon arrangement between Madaba and Amman to Tal Al-Sour.

The major element, which determines the configuration of the whole study area, is the Amman-Zarqa syncline structure represented by a syncline and adjoining folded layers. The syncline extends through the area southwest of Amman to northeast of Zarqa. It swings gradually to the north, widens behind Awajan, and plunges towards the east.

A fault zone exists within the Zarqa River Valley as a result of the relative 20° rotation of the block on both sides of the Zarqa River, which has a relationship with the structural history and tectonic factors of the region. The movement of this structure is thought to have taken place in the Quaternary Era.

The geological structures affecting groundwater movement. can be summarized as follows:

- Sweilih Anticline: The axis of this anticline strikes NE-SW. In its care, erosion has exposed the Kurnub Sandstone Aquifer in Ain el Basha and Baqa north of Sweilih. Modern recharge in this relatively high rainfall area directly and indirectly reaches the Kurnub and the underlying Zarqa aquifers.
- 2. Amman- Zarqa Syncline: The axis of this syncline strikes NE-SW. It extends from the southwestern side of Greater Amman to a point about 6.60 km southeast of Zarqa. The syncline is about 30 km long by 10-15 km wide. This synclinal zone is the highest potential area in the Hummar aquifer.
- 3. The Amman- Zarqa Monoclinal Flexure: The axis of this structure is parallel to the Amman-Zarqa syncline. It is to the southeast of the synclinal axis. They are 6.5-19 km apart. This monoclinal flexure and associated faulting form a hydraulic barrier to the eastward movement of water within the Hummar (A4) aquifer.





| Epoch | Age | Group | Formation | Symbol | Rock type | Thickness (m) | Aquifer Potentiality | Permeability (m/s) |
|---------------------|----------------|-------|-----------|---------------------------------|---|------------------|-------------------------|---|
| Tertiary | Holocene | | Wadi Fill | Wadi Fill Soil, Sand and Gravel | | Oct-40 | Good | 2.4 x10 ⁻⁷ |
| | Pleistocene | | Basalt | V | Basalt. Clay | 0-50 | Good | - |
| | Maestrichtain | alqa | Muwaqqar | B3 | Chalk, marl and Chalky limestone | 60-70 | Poor | - |
| | Campanian | ш | Amman | B2 | Chert, limestone with phosphate | 80-120 | Excellent | 10 ⁻⁵ - 3 x 10 ⁻⁴ |
| | Santonian | | Ghudran | B1 | Chalk, Marl and Marly limestone | 15-20 | Poor | - |
| Upper Cretaceous | Turonian | | Wadi Sir | A7 | Hard Crystalline Limestone. Dolomitic and Some Chert | 90-110 | Excellent | 1x10 ⁻⁷ - 1x10 ⁻⁴ |
| | | | Shueib | A5-6 | Light Grey limestone interbeded with Marls and Marly Limestone | 75-100 | Fair to poor | 6.3 x10 ⁻⁵ -7.2 x10 ⁻⁴ |
| | | Ajlun | Hummar | A4 | Hard dense limestone and Dolomitic Limestone | 40-60 | Good | 8.1 x 10 ⁻⁷ - 7.6 x10 ⁻⁴ |
| | Cenomanian | | Fuheis | A3 | Gary and Olive Green soft Marl. Marly limestone and limestone | 60-80 | Poor | 5.3 x 10 ⁻⁷ - 1.7 x 10 ⁻⁵ |
| | | | Na'ur | A1-2 | Limestone interbeded with a thick sequence of Marl and Marly Limestone | 150-220 | Poor | 2 x 10 ⁻⁸ - 3.1 x 10 ⁻⁵ |
| | Albian –Aptian | | Kurnub | к | Massive White and Varicolored Sandstone with layers of Reddish Silt and Shale | 300 | Good | 6.9 x 10 ⁻³ - 5.2 x 10 ⁻² |

Table 2.2 Geological and Hydrogeological Classification of the Rock Unit in Amman-Zarqa Area (Rimawi, 1985)



Figure 2.9 Geological Map of the Geotechnical Study Area

Hydro-geology

The Amman-Zarqa Basin is the most important basin in Jordan, because this basin is one of the transitional areas between high lands in the west and desert in the east. The two main aquifers in the Amman-Zarqa basin (the Amman/Wadi Sir formation (B2/A7) and the Hummar (A4) formation) are both exposed in the high rainfall region, where precipitation

reaches 400 mm/year, to the west of Amman. In the area, the rainfall does not exceed 150 mm/year. The major aquifer system in the geotechnical study area is (B2/A7), which is known as the Upper Aquifer. These aquifers are well jointed and fissured and on a local scale exhibit solution channels and karstic features. It is believed that the two aquifers are hydraulically connected and in some locations they are separated by an aquiclude (i.e. Ghudran Formation B1), which consists of chalk, marl and marly limestone. The Amman formation (B2), which acts as an aquifer, consists mainly of chert and limestone with phosphate beds. The Wadi Sir Aquifer lies below the Amman Formation and consists mainly of highly-fractured limestone, dolomitic limestone and some chert concretions. Most of the groundwater wells extract water from these aquifers.

Aquifer Systems

According to the potentiality of water bearing, three aquifer systems are available in Amman-Zarqa Basin:

- Upper aquifer system, which includes Basalt and underlying Amman-Wadi As Sir (B2/A7) formation;
- Middle aquifer system, consisting of Hummar (A4) and Naur (A1/2) formations;
- Lower aquifer system (Kurnub Group).

The Amman-Wadi Sir Aquifer System (B2/A7)

The B2/A7 aquifer is the most important aquifer in the geotechnical study area. It has a large and continuous extent, and a relatively high permeability. It receives the highest amount of modern recharge and is considered to be the principal source of fresh water for domestic as well as for irrigated agriculture in the study area. A regional groundwater level map of B2/A7 in Amman-Zarqa Basin is given in Fig. (0.3). Based on the groundwater flow pattern of B2/A7 aquifer, the groundwater flow directions are from south-west of Amman-Zarga Basin to Wadi Dhuleil and Azrag Basin in central and eastern parts, respectively, and from south-west where recharge occurs into Seil el Zarga north-west of the study area. In addition, the groundwater is moving from directions through the plateau of basalt into the Yarmouk and Azraq Basins in northwestern and eastern parts of Amman-Zarqa Basin, respectively. The depth to water table varies from 50 m in the southwest (closed to As-Samra wastewater treatm more than 400 m in the north-east and about 100 m at the central parts of the study area. Moreover, the elevation of the water surface varies from more than 750 m the south-west, and more than 675 masl in the south to less than 500 m (towards Yarmouk Basin), east (towards Azraq Basin) and central (towards Seil el Zarqa) of Amman-Zarqa Basin.

Groundwater in B2/A7 is under phreatic conditions over the Amman-Zarqa Basin, which is confirmed by wells drilling, however, in some wells there is indication to confined or semiconfined conditions occurred. The dominant direction of groundwater flow of B2/A7 is from south-west and northeast to the far northwest, east and center (Seil el Zarqa).



Figure 2.10 Regional Groundwater Contour Map of the Amman – Wadi Sir (B2/A7) Aquifer (BGR and WAJ, 1996)

The local groundwater contour map of the geotechnical study area is constructed based on the available groundwater wells in the vicinity of the geotechnical study area shown in Figure 2.11. The groundwater contour level map in the geotechnical study area is shown in Figure 2.12. The groundwater level varies from approximately 470 m to 690 m above sea level. The groundwater flows in a NE and NW directions, indicating that the groundwater flow is affected by the presence of faults prevailing in the project area. The red arrows in Figure 2.12 show the groundwater flow directions.



Figure 2.11 Location Map of Groundwater Wells in the Vicinity of the Geotechnical Study Area



Figure 2.12 Groundwater Contour Map of the B2/A7 Aquifer System in the Geotechnical Study Area (masl)



Figure 2.13 Depth of Ground Water From Natural Ground

Most of the springs in vicinity of the project area are emerging from two major aquifers (USAID and WAJ 1989):

• Amman-Wadi As Sir formations and recent alluvium (major springs are: Ras el Ain and Ruseifa); and

• Hummar and Naur aquifers (major springs are: Zarbi, Sukhneh, Fawwar, Suleihi, Maghasil, Nimra, Qunayyah and El Tannour).

The distribution of springs in the vicinity of the geotechnical study area is presented in Figure 2.14. There is one spring within the geotechnical study area (AL0522) which emerges from B2/A7 aquifer. The other springs surrounding the geotechnical study area such as (AL0514, AL0515, AL0517 and AL0518) are emerges from A4 aquifer. The spring discharge has declined over the past 10 years as a result of local or regional overexploitation of the aquifers; a decreased amount of rainfall over the period; and the fact that a portion of the spring discharge has been 'extracted from upstream wells and used for domestic purposes.

Preliminary Geotechnical Data

Types of Soils

Two main soil association units were recognized in the geotechnical study area. The first soil association unit is the Nisab (NIS) which has an average depth of > 80 cm and composed of silty clay loam and clay loam (very high calcareous and weakly to moderately saline) and on the other hand, it contains very stony silty clay loam (with very high calcareous and weakly saline) with depth less than 50 cm.

The second soil association units is known as Abu Salih (ALI) which characterized by deep (more than 80 cm) silty clay with highly calcareous and non-saline in some parts and very shallow (less than 25 cm) gravely silty clay loam on limestone with highly calcareous and non-saline.

Excavation Method and Slope Cuts

It is expected that most of the excavation will be through the silty clay loam and clay loam. Therefore, conventional excavation equipment such as loaders and bulldozers can be used. Also pneumatic and mechanical equipment such as jack hammers and rock breakers will be required for excavation of the stronger rock materials.

It is recommended to use the following slopes of cuts as summarized in Table 2.3

Table 2.3Summary of Slopes of Cuts in Soil and Rock Strata

| Encountered material type | Cuts height (m) | Slope |
|---------------------------|--------------------------|----------------|
| Different types of soils | – 3.0m More than 3.0m | 1V:2H 1V:1H |
| Rock strata | - 10.0 10.0 - 20.0m | 3V:1H 2V:1H |



Figure 2.14 Location Map of Springs in the Vicinity of the Geotechnical Study Area

Allowable bearing capacity

The recommended allowable bearing pressure on the foundation ground is summarized in Table 2.4

Table 2.4Allowable Bearing Capacity for Soil and Rock Material

| Type of Material | Allowable bearing capacity (kg/cm ²) |
|---|--|
| Soil material up to 1.5m depth | 1.50 |
| Carbonate Rock strata of 0.5m penetration | > 3.0 |

Summary and Recommendations

Amman-Zarqa Basin is one of the most important basins in Jordan because this basin is located in the transitional zone between highlands in the west and the desert in the east. The variation in altitude is not only reflected in the climatological changes from wet to dry but also in different land use patterns and also in large changes of habitat

The outcropping formations of the study area are extending from Lower Cretaceous (except wadi fill deposits) to recent age. Kurnub and Zarqa groups are exposed in the south-western (Baq'a Valley) and western parts (surrounding Jarash area) of the study area, respectively. Basalt outcrops in the eastern and northeastern parts of the study area. Belqa and Ajloun groups outcrop in other parts of the study area. The geological formations outcropping in the geotechnical study area mainly consist of Ajlun group (A4, A5/6 and A7) and Balqa Group (B1 and B2). Soil cover is generally thin, although local topography has led to accumulation of wind-blow soils in numerous places. The main geological structures dominating in the study area: Amman Syncline; Zarqa-Fault and Ramtha-Wadi Sirhan Fault.

The preliminary geotechnical data of soil and rock materials in the geotechnical study area which could be considered for a preliminary design criteria are summarized in Table 2.3. The allowable bearing capacity of soil up to 1.5 m depth is estimated to be 1.50 kg/cm^2 and for rock strata of 0.5 m penetration is 3.0 kg/cm² respectively.

It is highly recommended to carry out the following:

- 1. Detailed mapping of geological rock formations and geological structures prevailing in the study area;
- 2. Drilling of boreholes of a depth of 5 to 8 m;
- 3. Test pits for a depth not less than 3.0 m with the soil or until reaching the bedrock;
- 4. Conducting laboratory testing on representative soil samples collected from boreholes and test pits; and
- 5. Conduction Electrical Imaging Resistivity Tomography (ERT) lines to detect any cavities or subsurface structures affecting the sewer system pipelines.

2.4 <u>Wastewater System</u>

2.4.1 Wastewater Collection System

The existing collection system in the study area serve most of the built up areas in Zarqa, Russeifa and al-Hashemiyah consisting of main sewer trunk lines (generally 300 to 1000 mm in diameter) and a network of 200 mm diameter collector sewers. The collection system is split into two systems draining to West Zarqa and East Zarqa pumping stations. The following is brief description of the two collection systems:

- <u>Russeifa West Zarqa Sewer System</u>: The areas served by this system include Russeifa and west Zarqa. Flows from northeast Amman areas of Tariq, Marka and parts of Shafa Badran, Jubaiha and Nasser are also tributaries to the Russeifa/West Zarqa sewer system. This system forms about 70% of the collection systems of the study area. Flow collected by the Russeifa/West Zarqa system drains to the West Zarqa Pumping Station from where it is pumped to As Samra WwTP. Trunk sewers in the Russeifa/West Zarqa system are predominantly 300 to 1000 mm diameter.
- East Zarqa al-Hashemiyah Sewer System: This system serves developed areas in East Zarqa and al-Hashemiyah, resulting in a sub-system that accounts for about 30% of the collection system in the study area. Flows collected from the area are conveyed by gravity to the al-Hashemiyah Pumping Station and pumped to As Samra WwTP. Trunk sewers in the sub-system are predominantly 300 to 800 mm diameter.

The total length of the main trunk sewers with diameters equal to or above 300 mm is about 128 km. The secondary collection system is a dense network of 200 mm diameter sewers covering most of the populated areas of Zarqa, Russeifa and al-Hashemiyah with a total length of about 789 km. Most of the sewers are made of concrete, and a few are made of ductile iron and vitrified clay.

Investigations have shown that:

- Most of the low gradient sewers are blocked by sand, silt and grease; and
- Several segments of the collection system are overloaded during rain events, causing backup into streets, wadis, and in some rare cases into residences.

The last records obtained from WAJ show that the total number of subscribers for water services in 2009 is 130,948, while the number of subscribers for wastewater services is 94,265, which indicates that approximately 72% of households with water connections are sewered.

Although stormwater inflow is recognized as a significant source of excess flow into the collection system during rainfall events, the relative infrequency of significant rainfall events does not justify major upsizing of the system to accommodate storm flows. Rather, it is assumed that WAJ will continue efforts to promote compliance with current stormwater regulations that require that roof and area drains not be connected to the wastewater system.

In 2008, WAJ started a programme for cleaning the sewers using specialized bucket cleaning machines. About 23.1 km of sewers were cleaned by WAJ operators during the last two years and the cleaning of another 13.3 km was contracted to a local contractor. The lengths and diameters of the cleaned sewers are shown in Table 2.5. Results of the sewer cleaning operations are very promising as sewers blocked to more than half full have been fully cleared of the sediments. It is thought that such cleaning operations should be continued, as they will increase the expected life of the sewers considerably, and will eliminate the need for upgrading or replacement of many of the sewers.

| Diameter (mm) | Cleaned by WAJ | Cleaned by Contractor | |
|---------------|----------------|------------------------------|--|
| 200 | 17,756 | 11,507 | |
| 300 | 3,873 | 1,202 | |
| 400 | 175 | 626 | |
| 500 | 620 | - | |
| 800 | 700 | - | |
| Total | 23,124 | 13,335 | |

| Table 2.5 Len | gth of Sewers | Cleaned During | 2008-2009 (m) |
|---------------|---------------|-----------------------|---------------|
|---------------|---------------|-----------------------|---------------|

The basic layout of the sewer system, obtained from the GTZ/OMS team, was updated by the Team by comparing the GIS maps with the record drawings and through site visits and meetings with Zarqa wastewater operators. Sewer networks for areas such as Hai Ja'far al-Tayyar, Abu Ghalyoon in Russeifa and scattered sewers in al-Hashemiyah and Hai al-Batrawi in Zarqa were added to the OMS maps from the record drawings, and layouts of the main sewer systems in Hai al-Jundi and Hai al-Ameer Ali in Russeifa were added to the maps by field verifications.

The extent of the existing wastewater collection networks is shown in Figure 2.15 and the lengths of the sewers are summarized in Table 2.6.

| Sewer Diameter (mm) | West Zarqa System | East Zarqa System | Total |
|---------------------|----------------------|----------------------|---------|
| 200 | 570,101 | 219,310 | 789,411 |
| 300 | 43,944 | 11,210 | 55,154 |
| 400 | 8,381 | 7,287 | 15,668 |
| 500 | 7,351 | 12,443 | 19,794 |
| 700 | 1,422 | 6,975 | 8,397 |
| 800 | 20,167 | 6,996 | 27,163 |
| 1000 | 2,366 | | 2,366 |
| Total | 653,732 | 264,221 | 917,953 |

Table 2.6 Summary of Lengths of Existing Gravity Sewers *

The sewer networks are operated and maintained by WAJ Zarqa Directorate through two wastewater operation offices: one for the Zarqa and al-Hashemiyah networks and one for the Russeifa networks. The operation and maintenance activities are largely confined to clearing blocked manholes and sewers.

The operation and maintenance activities of the Zarqa and al-Hashemiyah collection networks are carried by a total workforce of 38 staff. This labour force are supported by 6 jet trucks, 1 rodding machine, 1 backhoe excavator, 1 compressor, 1 two-ton dump trucks, 2

portable pumps (which are not operational), 4 pick ups in addition to a bucket machine sewer cleaning.

The operation and maintenance activities of the Russeifa collection networks are carried by a total workforce of 27 staff. This labour force are supported by 6 jet trucks, of which only two are operational and the other four are in bad condition and 3 pickups in addition to various hand tools.

2.4.2 Wastewater Pumping Stations and Pumping Mains

Zarqa sewerage system includes two main pump stations; WZPS and EZPS that deliver wastewater to As Samra WwTP and a small lifting station, Hitteen Camp Pumping Station (HCPS) that serves a small section of the camp and delivers to the Russeifa collection network. WZPS and EZPS are currently operated and maintained by the Samra Plant Operation & Maintenance Co. Ltd., and Hitteen Camp pumping station is operated by WAJ / Russeifa operations department.

West Zarqa Pumping Station

Wastewater collected from Russeifa, west Zarqa and the northern parts of Amman that drain downstream of AGTP is directed to WZPS, which delivers to As Samra WwTP through a 1200 mm pumping main. The 1200 mm pumping main is the downstream end of the siphon that originally was the main wastewater conveyor (siphon) pipeline from AGTP to As Samra treatment plant. After the commissioning of the 1500 mm AGTP - As Samra conveyor, the 1200 mm pipeline is now utilized by WZPS although the siphon is considered as an emergency conveyor for AGTP – As Samra WwTP. In the past when the 1200 mm siphon was used by AGTP, WZPS was operating at a discharge pressure gauge of approximately 110 meters.

According to the pump station daily and hourly logs, the average daily and hourly flows during 2009 were about 52,700 m³/d, and 2220 m³/hr respectively.

The pumping station was commissioned in 1985 and was refurbished in 2009 by installation of new pumps and associated electrical works. The firm capacity of the refurbished pumping station is $72,000 \text{ m}^3/\text{d}$ operating at 65 m head.

The pumping station consists of:

- 1. Inlet Structure:
 - i.1000 mm diameter inlet pipe
 - ii.2 No. manual coarse screens of 50 mm bar spacing installed 80 cm wide channel,
 - iii.2 No. mechanical fine screens of 12 mm bar spacing installed in 120 cm wide channel
 - iv. Emergency overflow facility
 - v.Venturi chamber, with ultrasonic flow meter (up to 4,727 m³/hr)
- 2. Grit Removal System:
 - i. 2 No. aerated grit removal channels
 - ii. Blowers
 - iii. Classifier
 - iv. Mixer
- 3. Sewage grinder/macerator is installed as an additional pumps protection measure.
- 4. Wet Wells: Three open top wet wells with 256 m³ capacity;
- 5. Pumps: Four centrifugal variable speed pumps each with 1000 m³/hr flow and 120 m head, each equipped with 500 kW Siemens motor;
- 6. One discharge flow meter;
- 7. 10,000 m³ capacity emergency pond; and
- 8. 1500 kW emergency power generator.

The emergency pond often acts as additional wet well as the pumping capacity during peak flow hours is insufficient to pump the incoming flows. Thus, creating operation difficulties and odour nuisance.

East Zarqa Pumping Station

Wastewater collected from East Zarqa and al-Hashemiyah is collected at the EZPS, which discharges to As Samra WwTP through one of two 500 mm diameter, 7.2 km long force mains under a pressure head of approximately 74 meters. The pump station includes five pumps (4 duty + 1 standby) each rated to pump a flow of 420 m³/hr at 88 meters head. However currently at normal operating conditions only one or two pumps are operated. According to the pump station daily and hourly logs, the average daily and hourly flows during 2009 were about 12,000 m³/d, and 860 m³/hr respectively. It is noted that the pumping station is not working at full load.

The pumping station was commissioned in 1988 and was refurbished in 2006 by installation new screen and an additional 500 mm diameter pumping main. The firm capacity of the pumping station is $40,320 \text{ m}^3/\text{d}$ operating at 82 m head.

The pumping station consists of:

- 1. Inlet Structure:
 - i. 800 mm and 700 mm diameter inlet pipes
 - ii. 2 No. manual coarse screens
 - iii. 1 No. mechanical fine screen
- 2. Wet Wells: Two open top wet wells with 240 m3 capacity;
- 3. Pumps: Five centrifugal pumps (KSB); each with 420 m³/hr flow at design head of 88 m each, with 315 kW motor;
- 4. Outlet force main: 600 mm pipe branching into two 500 mm diameter force mains;
- 5. 1200 kW generator: (Mitsubishi).

Hitteen Camp Pumping Station

Wastewater collected from the lower elevations in Hitteen Camp and nearby areas is collected and lifted by the pump station to the nearby sewage collection system. The pump station is in a bad operational condition mainly attributed to inefficient screen, where it is not holding the relatively high quantities of screenings specially rugs that are clogging the pumps. Also, the station is lacking general equipment maintenance. There is a lack of records about the pump station details to give accurate information. The following are the general details of the pump station:

- 1. Pumping building including:
 - Inlet chamber with a screening basket
 - Wet well with three submersible pumps of 100 mm outlet but with unknown capacity
 - lifting crane;
 - None operational flow measurement device;
- 2. Guard room
- 3. Generator and transformer rooms

3. REVIEW AND COMMENTS ON PREVIOUS STUDIES

3.1 Introduction

The following main studies and reports were reviewed:

- The wastewater Master Plan, Feasibility Study and Preliminary Engineering Design for the Rehabilitation, Expansion and Development of the Wastewater Systems of the Municipalities and Communities within the Watershed of the Amman-Zarqa River Basin, by Harza, 1997;
- The Technical and Economic Review and Update Study of the Wastewater Studies Prepared for the Greater Amman Area, by MWH, 2006;
- The National Water Master Plan, by the Ministry of Water and Irrigation, the Hashemite Kingdom of Jordan and the German Technical Cooperation (GTZ), 2005;
- The Feasibility Study and Design of the Wastewater Collection, Treatment and Effluent Reuse for the West Jerash and al-Sukhneh Area, by C. Lotti & Associati and Engicon, 2004;
- Design of Sewer Networks in Zarqa (Fallah, Ma'asoum, Princess Haya areas), 2007and
- Conceptual Design Report for the Construction of a Closed Wastewater Canal of Wadi Zarqa, by CEC, 2009.

3.2 <u>Summary of Previous Studies</u>

Wastewater Master Plan, 1997

The study was prepared by Harza, with the primary objective of planning for adequate treatment facilities and collection and conveyance systems for the population of the Amman-Zarqa Basin through the year 2025.

The population projections in this study were based on the 1994 census. For the study area, the future population growth rates were estimated to decline from 4.4% per annum in 1995 to 3.7% per annum by the year 2025.

For Zarqa Governorate, "adjusted consumption" (water supplied minus physical leakage in transmission and distribution) was estimated at 85 and 116 l/c/d in 1994 and 2025 respectively. Wastewater flows were taken to be about 87% of adjusted consumption, estimated from measurements at AGTP and the pumping stations at West Zarqa and al-Hashemiyah.

The 1997 Master Plan recommended that flow from areas tributary to the Zarqa pump stations and al-Sukhneh should be conveyed by gravity to a new treatment facility along Wadi Zarqa. As part of this strategy, the 1997 Master Plan recommended implementation of the conveyance and treatment systems in two phases.

The conveyance will include mainly the construction of approximately 31 km of a new gravity sewer conveyance pipeline to accommodate peak sewer flow through the year 2025 from areas downstream of the existing AGTP to the new Wadi Zarqa WWTP. This pipeline plus the new Wadi Zarqa WWTP will eliminate the need for the existing West Zarqa and al-Hashemiyah (East Zarqa) Pumping Stations.

Preliminary treatment processes have been proposed at Sukhneh that will include coarse screening, manually and mechanically cleaned bar screens and aerated grit removal.

Wastewater Master Plan Update, 2006

In this revised master plan, the population projections were based on both the 1994 and 2004 census data. Therefore, the revised growth rates were estimated to decline from 2.6% in 2004 to 2.3% in 2025 for the whole Amman-Zarqa area.

The water consumption rates for Amman-Zarqa area were projected at 118 and 125 l/c/d in 2010 and 2025 respectively. The wastewater flow generation rate was kept at 87%, the same value used by the 1997 master plan.

The revised Amman-Zarqa Wastewater Master Plan has identified the following five alternatives when considering options for conveying the flows to treatment locations:

- 1. A new treatment facility along Wadi Zarqa to treat flows from Zarqa area (as proposed in the 1997 Master Plan);
- 2. A new treatment facility adjacent to the new As Samra Plant to treat flows from the Zarqa area, with a pre-treatment facility/pumping station at Sukhneh;
- 3. A new treatment facility adjacent to the new As Samra Plant to treat flows from Zarqa area, with existing pumping stations online;
- 4. Expansion of the new As Samra Plant, with a pre-treatment facility/pumping station at Sukhneh to treat projected flows from the entire study area; and
- 5. Expansion of the new As Samra Plant to treat projected flows from the entire study area, with existing pumping stations online.

Using the derived scoring mechanism, the Updated Master Plan considered Alternative 1 as the most preferred alternative.

National Water Master Plan, 2004

Population growth is considered the major parameter influencing future water demand development in this report. Although Jordan is striving to reduce population growth, it is likely to remain high. Up to the year 2020, Jordan's population is expected to grow between 7 and 9 million.

The National Water Master Plan has expected that the municipal per capita demands will rise significantly owing to increasing income and changes in the way of life. Higher per capita demands are particularly expected in the urban development areas of Greater Amman, Irbid and Aqaba, whereas per capita demands in other areas are expected to remain at a lower level.

Of interest is the water allocation in Urban Amman and Zarqa, where it is expected to rise from 136 to 150 I/c/d and from 108 to 132 I/c/d between 2005 and 2020 for Amman and Zarqa respectively.

West Jerash and Sukhneh Feasibility Study, 2004

The study has considered population projections for Sukhneh to the design horizon year 2015, based on 1994 census data. The growth rate for Sukhneh town was taken to decline from 2.6% in 2005 to 2.3% in 2015, while the growth rate for Sukhneh Camp was taken to be constant at 3.3% up to 2015.

The water consumption for Sukhneh town was projected to rise from 93 I/c/d in 2002 to about 141 I/c/d in 2015, while the water consumption of the camp was considered constant at 80 I/c/d. The wastewater generation percentage was assumed at 85% of the water consumption.

This study is concerned with the design of a new wastewater collection network in the al-Sukhneh area, which falls in the catchment area of Seil Al-Zarqa. The refugee camp has been designed separately by the Community Infrastructure Program. The study is also concerned with the design of a new pumping station that carries the flow generated from al-Sukhneh and its refugee camp to the existing West Zarqa Pumping Station through a 350 mm diameter, 6.5 km long force main.

The proposed Sukhneh pumping station was designed for the 2015 flows, considering a peaking factor of 3.09. This results in a total flow of 234.7 m^3/hr .

Design of Sewer Networks in Zarqa, 2007

The study area comprises of the following areas in Zarqa:

- 1. Princess Haya Housing Area;
- 2. Part of Hay al-Jabr;
- 3. Hay al-Hamad; and
- 4. Hay al-Madina al-Monawara.

The population of the selected areas is estimated by defining the number of inhabited plots with an assumption that each inhabited plot within residential areas in Zarqa consists of one building with an average of three floors, two apartments on each floor and six inhabitants per apartment. Forecasting up to the year 2032 is done using an annual growth rate of 2.5%.

Water consumption in Zarqa Governorate, as derived from the Water Administration in the year 2003 is 110 l/c/d and the recent data for the year 2006 is 122 l/c/d. According to that, the study estimated a consumption of 124 l/c/d in the year 2007 increasing up to 140 l/c/d in the year 2032. Wastewater flow is assumed to be 80% of the forecasted consumption.

Closed Canal Conceptual Design Report, 2009

The proposed closed canal will be tributary by gravity and collect all wastewater flows from the Amman-Zarqa basin, including the summer base flow. The proposed canal has been divided into two parts:

- 1. The first part will collect flows from most of Amman and discharge them at Ain Ghazal pre-treatment plant to the existing 1500 mm pipeline to As Samra WwTP;
- 2. The second part, which is relevant to our study, will start from Ain Ghazal pretreatment plant along Seil al-Zarqa to the proposed Wadi Zarqa Treatment Plant. This part will collect all flows that currently go through West Zarqa Pumping Station (generated from Amman areas downstream of Ain Ghazal pre-treatment plant), as well as Russeifa and West Zarqa.

The overall objective of the project is to prevent pollution of surface and groundwater, through the construction of a new wastewater closed canal with enough capacity until the year 2060.

For the population projections, a model prepared by the Department of Statistics for the study area has been used. From the derived projected population growth it can be noted that one growth rate of 2.43% up to the year 2025 was used for both Amman and Zarqa areas.

However, two different growth rates of 1.6% and 2.1% up to the year 2060 were used for Amman and Zarqa, respectively.

3.3 <u>Comments on Previous Studies</u>

Wastewater Master Plan, 1997

The population growth rates used by the 1997 master plan for the Amman-Zarqa Basin were relatively high (4.4% and 3.7% for the years 1995 and 2025), compared to the actual growth rates of 2.1% and 1.9% for Amman and Zarqa respectively in the inter-censal period 1994 and 2004.

The water consumption rate of 116 l/c/d for 2025 used in the study is much lower than the rate suggested by the National Water Master Plan (150 l/c/d for Amman and 132 l/c/d for Zarqa in 2020).

The study considered only the populated areas within the study area, and therefore planning, analysis, and preliminary engineering design were made without considering any possible future development areas such as those that happened in west Zarqa and is now happening in east Zarqa.

The study recommended implementation of its study actions regarding sewer networks, conveyance system, and treatment facilities to meet the needs by growth of population as foreseen by the study. The study suggested to implement its recommendations into two phases; phase 1 up to 2015 and phase 2 up to the end of the study period in 2025.

The 1997 Master Plan recommended the construction of a new Wadi Zarqa Wastewater Treatment Plant to eliminate the need for pumping facilities in Zarqa.

In general, the recommended implementation programmes of the study concerning the population of Zarqa were not materialised until now. However, an update of the study was conducted in 2006.

Wastewater Master Plan Update, 2006

Although the revised master plan has updated the estimated population growth rates based on the actual rates between 1994 and 2004 census data, it still used one combined rate of 2.3% for both Amman and Zarqa population projections until 2025. This contradicts actual growth rates for Zarqa, which was lower than that of Amman rates.

The water consumption rate proposed by the revised master plan is still lower than the rate suggested by the National Water Master Plan (125 I/c/d in 2025 compared to 150 I/c/d in 2020).

The revised master plan considered the same populated areas as proposed by the original 1997 master without considering the new development areas in east and west of Zarqa. As a result, population and flow projections of the report need to revised to take account of the new available information regarding the growth rates and development plans.

The revised master plan supported the original 1997 master plan with the proposal to construct a new wastewater treatment plant in Wadi Zarqa, after evaluating several alternatives. The proposed Wadi Zarqa Treatment Plant of 145,000 m³/d capacity using activated sludge with nitrification/denitrification process is to be located along Wadi Zarqa to treat flows from the Zarqa area by year 2016.

The study also proposed that West Zarqa Pump Station and East Zarqa Pump Station to continue to operate until 2016. By 2016, with the proposed Wadi Zarqa WWTP online, these pump stations along with their force mains will be decommissioned.

The existing 1200mm siphon will be designated exclusively as the standby conveyor from AGTP to As Samra after 2016 or when WZPS is decommissioned.

Although the study has proposed to decommission the West Zarqa Pump Station but it proposed that the new pump station at Sukhneh, being planned as part of the Irbid-Jerash Treatment Contract, will be online to collect flows from the Sukhneh area and convey it to the WZPS. Which could be understood that this will be done until 2016 only.

West Jerash and Sukhneh Feasibility Study, 2004

We believe the project design period (through the year 2015) is too short. Additionally, the design of al-Sukhneh pumping station took into consideration al-Sukhneh town and the camp within the town, without considering any future connections from populated areas that drain towards the same site. Our study of the boundaries of the Zarqa catchments shows that al-Sukhneh pumping station can cover several additional populated neighbourhoods in Zarqa and along Wadi Zarqa, such as Hai al-Bustan, Hai al-Jabr, Hai Nassar, Hai al-Ahmad, Hai Makka al-Mukarramah and Abu Zeighan.

The location and sizing of the pumping station and sewers will need to be reviewed to bring the design horizon in line with the current study and also to enable the pumping station to serve all the communities that could drain into it.

Design of Sewer Networks in Zarqa, 2007

The design of this project includes the design of a gravity trunk sewer to collect the flow generated from the concerned neighbourhoods towards al-Sukhneh pumping station. This trunk sewer line has been designed without giving consideration to any future connections from areas within its catchment.

Also, the flows from the service areas are drained to the proposed Sukhneh pumping station under the West Jerash and Sukhneh Feasibility Study. without studying the capacity of the pumping station. As mentioned before, the design of the proposed al-Sukhneh pumping station should be reviewed to cope with these flows or with other future flows in the catchment area.

Closed Canal Conceptual Design Report, 2009

This study assumed an overall constant population growth rate for Zarqa at 2.2% until year 2060, which the MWH Team believes to be high when compared with the historical growth rate for the governorate.

Relevant to our study is the second part of the proposed canal, which will collect all generated wastewater from contributing catchment areas of West Zarqa WWPS (WZPS), in addition to al-Sukhneh catchment area (with a design horizon through the year 2060). The implementation of this canal will eliminate the need for the West and East Zarqa pumping stations and the need for many of the existing or proposed sewer trunks along Wadi Zarqa.

4. PLANNING CONSIDERATIONS AND PROJECTIONS

4.1 Introduction

The establishment of basic planning criteria and the subsequent projection of wastewater services requirements using these criteria are crucial to the formation of a proper Wastewater Development Plan for Zarqa. The following criteria and projections have been established and will be used by the Project Team in its formation of the Master Plan.

For the most part, the criteria and projections summarised herein are based on the experiences of WAJ and on the past studies conducted within the planning area supplemented with additional data and information collected by the Team under this current study.

4.2 <u>Planning Criteria</u>

The planning and design criteria defined and reported herein include:

- General planning criteria:
 - Planning period;
 - Geographical service area;
 - Population projections
 - Level of service to be provided;
 - Income levels and its spatial distribution;
 - Planned economic and industrial activities; and
- Water consumption:
- Wastewater systems:
 - Wastewater generation factors;
 - Wastewater flow quantities

4.2.1 General Criteria

The following general planning criteria covers the key basic planning considerations.

4.2.2 Planning Period

The planning period for this project was established to be the period through year 2035. Therefore, key planning parameters, such as population, water consumption and wastewater production projections, have been defined in five-year increments, with the first being 2010.

4.2.3 Service Area

In accordance with the Terms of Reference all villages and towns in the Governorate of Zarqa shall be included in the study.

After discussions with WAJ it was understood that a feasibility study and final design and preparation of bidding documents project for the wastewater collection, treatment and reuse for Azraq, in the eastern parts of the governorate, is currently underway. Therefore this area will be excluded from this Study.

The proposed area, shown in Figure 4.1 consists of the existing wastewater service area plus approximately 3,222 hectares within the current municipality boundaries encircling the existing service from west and north directions in addition to the proposed development areas in the King Abdullah Bin Abdul Aziz City and al-Majd City and the towns and villages in Birein, al-Hashemiyah and al-Dhuleil districts. This area has been developed in conjunction with WAJ and is also consistent with the planning boundaries of the municipalities of Zarqa, Russeifa and al-Hashemiyah.

4.2.4 Level of Service – Sewer Coverage

The initial focus of the reinforcement and expansion program will be on bringing sewers to areas that are currently only served by water and to areas that have inadequate wastewater collection systems. These areas will be given high priority under the evaluation of areas to be included in the MCC funded Investment Program. As future areas develop, the plan will be formulated on the basis that both water and sewerage services will be provided to each new development at the same time.

All of Zarqa Governorate communities, except for the Azraq district, have been studied for coverage by the proposed collection networks. However, sewers will be provided for areas and towns with paved roads.

The currently unserved communities and new expansion areas within Zarqa, Russeifa, and al-Hashemiyah municipalities will be served by the existing Zarqa systems (WZPS System and EZPS System). The Zarqa Free Zone, al-Hashemiyah University, and the new King Abdullah Bin Abdul Aziz City will be served through the EZPS System, while the new al-Majd City will be served through the WZPS system.

The new service areas within the catchments of the existing networks consist mainly of the newly developed neighbourhoods of Zarqa and Russeifa west of the Zarqa River and some parts of Hai al-Batrawi in north Zarqa.

A new pumping station is proposed at Sukhneh to convey the flows from areas that drain downstream of WZPS. This catchment zones includes the western neighbourhoods of Zarqa such as Hai al-Bustan; Hai Shomar; Hai al-Hashemi; Hai al-Jneineh; Hai al-Ameera Haya; Hai Nassar; Hai al-Jabr; Hai al-Ahmad; Hai Makka al-Mukarramah; and part of Hai al-Madinah al-Munawwarah. Also, the Sukhneh PS Zone system covers the communities north of Zarqa such as Sukhneh; Salheyah; Abu al-Zeighan; Ghareisa; and Umm Suleih.

Flows from eastern parts of al-Hashemiyah district could be collected at the proposed Sukhneh pumping station, which lies at the confluence of Zarqa River and Wadi Dhuleil.

Most areas of Birein district drain to Zarqa River downstream of Sukhneh. Therefore a separate system will be required to collect the flows from these areas at pumping stations in Wadi Zarqa to deliver their flows to the proposed Sukhneh pumping station. This system will be serving the towns and villages of Birein, Umm Rummaneh, Maqam Eissa, al-Alouk, Sarrout, etc.

The town of al-Dhuleil and nearby villages drain to Wadi Dhuleil which passes near As Samra WwTP. This system could also in future serve more communities within Zarqa Governorate such as Hallabat communities and outside Zarqa Governorate such as Khalediyah and Khirbet al-Samra communities in Mafraq Governorate.

Other remaining scattered communities with less than 1,000 population that could not be served by gravity neither by the existing systems nor by the above proposed new systems

due to their remote distances from the networks such as Kamshah, Umm al-Makman, Rujm al-Shoak, Tafeh, Hallabat, Dhaythem, etc. will remain on private on-site disposal systems using cesspools or septic tanks.

4.3 <u>Population</u>

The results of the 2004 Census revealed that the resident population of Zarqa Governorate for that year was approximately 799,000, about 15% of the national population. This indicated a growth rate for the governorate of 2.2% per annum between the 1994 and 2004 inter-censal period. The national and Amman Governorate growth rates were 2.6% and 2.8% respectively for the same period. It is considered that migration to Amman skews the population growth rates below the average for Amman Governorate.

4.3.1 Projections

The population projections are based on the Department of Statistics (DOS) projections and the planning considerations of the major urban development areas. The DOS projected population of the Zarqa Governorate is presented in Table 4.1.

| Year | Population | Growth rate |
|------|------------|-------------|
| 2004 | 799,000 | |
| 2010 | 921,451 | 2.40% |
| 2015 | 1,033,404 | 2.32% |
| 2020 | 1,133,368 | 1.86% |
| 2025 | 1,231,580 | 1.68% |
| 2030 | 1,329,048 | 1.53% |
| 2035 | 1,426,229 | 1.42% |

Table 4.1 Department of Statistics Zarqa Governorate Projected Population

Source: Department of Statistics

In discussions with DOS officials it was understood that the above projections do not consider the effects of the two major urban development projects of King Abdullah Bin Abdul Aziz City and al-Majd City in east Zarqa. The planned population of these two areas at year 2035, as collected from the developers, are shown in Table 4.2.

| Year | King Abdullah Bin Abdul Aziz City | Al-Majd City | Total |
|------|--------------------------------------|--------------|---------|
| 2010 | | - | - |
| 2015 | 50,000 | 31,800 | 81,800 |
| 2020 | 135,000 | 42,400 | 177,400 |
| 2025 | 230,000 | 42,400 | 272,400 |
| 2030 | 340,000 | 42,400 | 382,400 |
| 2035 | 450,400 | 42,400 | 492,800 |

Table 4.2 Populations Projections of Major Development Areas

It can be seen from the above two tables that the expected population of the two development areas at year 2035 will be about 35 percent of the total projected population of Zarqa Governorate and that these two areas could contain almost all the natural population increase of Zarqa Governorate until year 2035.

There is currently no information available at DOS or other governmental departments nor the developers about the nature of the future inhabitants of the two development areas and whether they would entirely be from Zarqa Governorate or will be incomers from other parts of Jordan.

Therefore, to arrive at a reasonable population projection for the project area in the absence of any official studies about the nature of the future inhabitants of the two developments, it is considered that half of the population of the new developments would come from outside Zarqa Governorate.

This means that the DOS projected population for Zarqa Governorate would need to be adjusted to allow for the increase in population that would migrate to the governorate attracted by the new development areas. If no such assumption is made then it would mean that population in other parts of the governorate will not start to increase until year 2035 as all the increase in population until then would be accommodated in the two development areas.

The population projection at five year intervals up to year 2035 based on the above criterion and the resulting growth rates are shown in Table 4.3.

| Year | Migration from other governorates | DOS population projection | Proposed projected population | Overall growth rate |
|------|---|---------------------------------|-------------------------------------|------------------------|
| 2010 | | 921,451 | 921,451 | |
| 2015 | 40,900 | 1,033,404 | 1,074,304 | 3.12% |
| 2020 | 88,700 | 1,133,368 | 1,222,068 | 2.61% |
| 2025 | 136,200 | 1,231,580 | 1,367,780 | 2.28% |
| 2030 | 191,200 | 1,329,048 | 1,521,518 | 2.15% |
| 2035 | 246,400 | 1,426,229 | 1,672,629 | 1.91% |

Table 4.3 Proposed Zarqa Governorate Population Projection

4.3.2 Spatial Distribution

The spatial distribution of the projected total population of Zarqa Governorate over the municipal planned areas and in towns and villages is required for the proper planning of the wastewater collection and conveyance systems.

The population distribution projection in the towns and villages outside the municipality planning boundaries of Zarqa, Russeifa and al-Hashemiyah is based on the growth rates projected by DOS.

The projected population distribution within the municipal planning boundaries of Zarqa, Russeifa and al-Hashemiyah is based on assuming different growth rates for each Hai (neighbourhood) depending on the degree of current saturation levels in these neighbourhoods. For population distribution purposes the neighbourhoods within the town planning boundaries were classified in three categories by judgement of the present saturation levels determined from examination of the satellite images and observations made by the Team during reconnaissance trips. The three categories are as follows:

- Neighbourhoods with current saturation levels more than 60%;
- Neighbourhoods with current saturation levels between 40 to 60%;
- Neighbourhoods with current saturation levels less than 40%;

For areas judged to be currently built up more than 60% of saturation levels an annual growth rate of 1% was adopted for the period from 2004 to 2015 and a constant growth rate of 0.5% thereafter until 2035 or until the area reached saturation levels.

For areas judged to be to currently saturated between 40% and 60% of saturation levels an growth rates of 1.5%, 1.0% and 0.5% were adopted for the periods from 2004 to 2015, 2016 to 2025 and 2026 to 2035 respectively or until the area reached saturation levels.

After calculation of the population projections at each five year interval for the towns and villages outside the municipal planning boundaries and for the first two neighbourhood categories within the planned municipality boundaries using the above mentioned growth rates the remaining population were distributed over the third neighbourhood category by applying a different growth rate for each five year interval for this category to make up the total population for each five year interval.

The applied growth rates for each neighbourhood category at each five year interval are shown in Table 4.4.

| Period | Towns and | Zarqa, Russeifa and al-Hashemiyah areas | | | | |
|-----------|--|--|---|--|--|--|
| | Zarqa, Russeifa and al- Hashemiyah | Current saturation level more than 60% | Current saturation level between 40-60% | Current saturation level less than 40% | | |
| 2004-2010 | 2.40% | 1.0% | 1.5% | 20.5% | | |
| 2010-2015 | 2.32% | 1.0% | 1.5% | 4.8% | | |
| 2015-2020 | 1.86% | 0.5% | 1.0% | 3.5% | | |
| 2020-2025 | 1.68% | 0.5% | 1.0% | 2.8% | | |
| 2025-2030 | 1.53% | 0.5% | 0.5% | 1.8% | | |
| 2030-2035 | 1.42% | 0.5% | 0.5% | 1.6% | | |

Table 4.4Population Growth Rates in Project Areas

Detailed population distribution projections in the neighbourhoods and towns and villages are presented in Appendix 1 and are summarized in Table 4.5.

Table 4.5 Projected Zarqa Governorate Population

| District / Community | Year | | | | | | |
|-----------------------------------|---------|---------|-----------|-----------|-----------|-----------|-----------|
| | 2004 | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
| Zarqa District * | 1,410 | 1,626 | 1,823 | 1,999 | 2,173 | 2,345 | 2,516 |
| Zarqa Municipality | 412,982 | 505,704 | 550,560 | 584,514 | 617,013 | 642,749 | 666,320 |
| Birein District | 12,434 | 14,339 | 16,081 | 17,637 | 19,165 | 20,682 | 22,194 |
| Dhuleil District | 34,071 | 39,292 | 44,066 | 48,329 | 52,517 | 56,673 | 60,817 |
| Russeifa District | 280,287 | 296,254 | 309,924 | 317,487 | 325,206 | 332,770 | 339,479 |
| al-Hashemiyah Municipality | 26,619 | 28,257 | 29,698 | 30,448 | 31,217 | 32,005 | 32,814 |
| al-Hashemiyah District * | 21,772 | 25,109 | 28,159 | 30,883 | 33,559 | 36,215 | 38,863 |
| Azraq District | 9,426 | 10,871 | 12,192 | 13,371 | 14,530 | 15,680 | 16,826 |
| King Abdullah Bin Abdul Aziz City | | | 50,000 | 135,000 | 230,000 | 340,000 | 450,400 |
| al-Majd City | | | 31,800 | 42,400 | 42,400 | 42,400 | 42,400 |
| Total | 799,000 | 921,451 | 1,074,304 | 1,222,068 | 1,367,780 | 1,521,518 | 1,672,629 |

Note: * Population of towns and villages outside planned municipality boundaries

4.3.3 Population Projections of Tributaries from Amman Areas

As mentioned previously flows from the north eastern parts of Amman that drain downstream of AGTP flow into the Zarqa wastewater system. The areas of Amman that contribute flows to the system are Shafa Badran (partly), Jbaiha (partly), Tareq, Marka (partly), al-Nasr (partly) and Basman (partly).

The 2004 population of the contributing areas of these five areas estimated as a percentage of the contributing area delineated around the layout of the existing sewer systems of the total land area of each of these areas was 260,818.

The population projection of the Amman contributing areas over the project horizon over 5year periods is shown in Table 4.6.

| Year | 2004 | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|--------------|---------|---------|---------|---------|---------|---------|---------|
| Growth rate | | 2.4% | 2.3% | 1.9% | 1.7% | 1.5% | 1.4% |
| Area | | | | | | | |
| Shafa Badran | 12,115 | 13,972 | 15,670 | 17,185 | 18,674 | 20,152 | 21,626 |
| Jbaiha | 15,567 | 17,953 | 20,134 | 22,082 | 23,995 | 25,894 | 27,788 |
| Tareq | 47,629 | 54,928 | 61,601 | 67,560 | 73,415 | 79,225 | 85,018 |
| Marka | 89,218 | 102,891 | 115,392 | 126,554 | 137,521 | 148,404 | 159,256 |
| Al Nasr | 63,531 | 73,267 | 82,169 | 90,118 | 97,927 | 105,677 | 113,404 |
| Basman | 3,695 | 4,262 | 4,780 | 5,242 | 5,696 | 6,147 | 6,596 |
| Total | 231,755 | 267,273 | 299,746 | 328,741 | 357,228 | 385,499 | 413,687 |

 Table 4.6
 Population Projections of Tributary Areas of Amman

4.4 <u>Wastewater Flow</u>

4.4.1 Water Consumption

Current Consumption

Based on a review of the water billing data for the period between 2006 and 2009, the average per capita billed amount was 64.6 L/d. The reported average unaccounted-for water during the same period was 46%, with the administrative losses being 80% of the physical losses (25.5% for physical losses and 20.5% for administrative losses). Consequently, the average water consumption during this period was about 90 lpcd, assuming all of the administrative losses were consumed by the population.

Projected Consumption

The recommendations of the MWI Policy Note, issued on 21 April 2010, on water allocation for municipal water use is adopted to estimate the water consumption for the project area. The MWI Policy Note municipal water consumptions are presented in Table 4.7. These consumption figures will be used for the design and sizing of wastewater system facilities

and they include all municipal uses such as residential, commercial, institutional and light industrial

| Location | Water consumption (lpcd) |
|--------------|--------------------------|
| Amman | 120 |
| Other cities | 100 |
| Villages | 80 |
| Suburbs | 80 |

Table 4.7 Water Consumption Projections as per MWI Policy Note

4.4.2 Wastewater Generation Factors

In the 1997 Master Plan, wastewater flows were calculated to be about 87% of water consumption based on wastewater flows measured at AGTP and the WZPS and EZPS. This same proportion was used as the basis of projecting wastewater flow in the1997 master plan. The 2006 update of the 1997 master plan also recommended the use of this percentage, so for the purpose of this study it is also assumed that 87% of the water consumed results in wastewater generation.

4.4.3 Wastewater Projection

Future wastewater generation rates estimated based on population forecasts, water consumption rates and the wastewater return value are presented in Appendix 2 and are summarised in Table 4.8.

| District | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|-----------------------------------|--------|--------|---------|---------|---------|---------|
| Zarqa District * | 113 | 127 | 139 | 151 | 163 | 175 |
| Zarqa Municipality | 43,996 | 47,899 | 50,853 | 53,680 | 55,919 | 57,970 |
| Birein District | 998 | 1,119 | 1,228 | 1,334 | 1,439 | 1,545 |
| Dhuleil District | 2,735 | 3,067 | 3,364 | 3,655 | 3,944 | 4,233 |
| Russeifa District | 25,732 | 26,916 | 27,570 | 28,237 | 28,890 | 29,470 |
| al-Hashemiyah Municipality | 2,458 | 2,584 | 2,649 | 2,716 | 2,784 | 2,855 |
| al-Hashemiyah District * | 2,014 | 2,258 | 2,477 | 2,691 | 2,904 | 3,117 |
| Azraq District | 757 | 849 | 931 | 1,011 | 1,091 | 1,171 |
| King Abdullah Bin Abdul Aziz City | | 4,350 | 11,745 | 20,010 | 29,580 | 39,185 |
| al-Majd City | | 2,767 | 3,689 | 3,689 | 3,689 | 3,689 |
| Total | 78,803 | 91,935 | 104,643 | 117,175 | 130,406 | 143,408 |

 Table 4.8
 Wastewater Generation Projections of Zarqa Governorate (m³/d)

Note: * Population of towns and villages outside planned municipality boundaries

4.4.4 Wastewater Flow Projections from Amman Tributaries

Applying the water consumption rates recommended by the MWI Policy Note and the same return factor of 87% as used for Zarqa areas, the projected wastewater flow quantities from the Amman Tributaries are as summarised in Table 4.9.

| Area | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|--------------|--------|--------|--------|--------|--------|--------|
| Shafa Badran | 1,459 | 1,636 | 1,794 | 1,950 | 2,104 | 2,258 |
| Jbaiha | 1,874 | 2,102 | 2,305 | 2,505 | 2,703 | 2,901 |
| Tareq | 5,734 | 6,431 | 7,053 | 7,664 | 8,271 | 8,876 |
| Marka | 10,742 | 12,047 | 13,212 | 14,357 | 15,493 | 16,626 |
| Al Nasr | 7,649 | 8,578 | 9,408 | 10,224 | 11,033 | 11,839 |
| Basman | 445 | 499 | 547 | 595 | 642 | 689 |
| Total | 27,903 | 31,293 | 34,321 | 37,295 | 40,246 | 43,189 |

Table 4.9 Wastewater Flow Projections from Tributaries of Amman (m³/d)

5. DESIGN CRITERIA

5.1 Introduction

The establishment of basic design criteria is critical to the formation of a proper wastewater system reinforcement and expansion plan for Zarqa. The following criteria have been established for use in the formation of the Master Plan.

These design criteria are consistent with best engineering practice and the Consultant's experience in similar regions, and they incorporate the comments made by WAJ on the design criteria presented in the Draft Preparatory Works Technical Report.

5.2 <u>General Criteria</u>

5.2.1 Design Horizon

The design horizon follows the planning period for the master plan as outlined in the previous section. The design horizon for all wastewater facilities is year 2035. Construction of facilities such as electromechanical equipment of pumping stations will be phased out in two phases with the first phase being year 2020.

In circumstances where the pumping station is planned for interim use the planning period for establishing flow rate can be shorter. For all pumping stations, consideration shall be given to future upgrading flexibility necessary to accommodate flows beyond the planning horizon. This is especially important for the larger sewage pumping stations.

5.2.2 Design Life

Design life is defined as the period of time that the asset (a structure or element) is designed to operate for under a normal maintenance regime, without detriment to its function and without major deterioration. After the design life has expired major renovation or refurbishment may be necessary to further extend the asset life beyond its original design life.

The design life for the project facilities is presented in Table 5.1.

Table 5.1Design Life

| Facility | Design Life (Year) |
|-----------------------------|--------------------|
| Civil works | 50 |
| Sewers and pumping mains | 50 |
| Power cables | 40 |
| Mechanical equipment | 15 |
| Electrical equipment | 25 |
| Instrumentation and control | 10 |

5.3 Collection Network Design Criteria

5.3.1 Hydraulic Design of Gravity Sewers

Gravity sewers should flow freely and with a velocity which prevents the deposition of solids within them. This is accomplished by providing sufficient slope to achieve a velocity of 0.9 m/s when flowing half full.

Flow Equations

For the purposes of this study, the Manning formula is used for gravity pipelines.

The Manning equation is as follows:

$$Q = \frac{1}{n} A R^{2/3} S^{1/2}$$

Where $Q = flow rate (m^3/s)$

- A = cross sectional area of flow (m^2)
- *R* = hydraulic radius of flow area in (m) [flow area/wetted perimeter]
- S = hydraulic gradient (m/m)
- n = Manning roughness coefficient

Friction Factor

It is common to relate friction factors to the materials involved, particularly in the design of systems handling clean water. Polyvinyl Chloride (PVC) and Glass Reinforced Plastic (GRP) have a very smooth surface when fabricated and their laboratory friction factor is small. In a sewer environment, however, the pipe quickly becomes coated with slime, grease and sediments that are deposited during low flow conditions. The sediments, once deposited, are rarely removed at low flow velocities, because they are combined with grease and thus become cemented. For these reasons, it is considered good practice to correlate the friction factors to flow velocities in addition to pipe material properties in the hydraulic design of sewers and to use conservative friction factors to compensate for the loss of capacity due to slime, grease and sediment build-up.

The roughness coefficients for different pipe material and velocities for sewers slimed to half depth will be as follows:

| Velocity when flowing half full | Manning's n value [s/m ^{1/3} | | |
|---------------------------------|---------------------------------------|--|--|
| Up to 0.75 m/s | | | |
| Concrete | 0.015 | | |
| DI (cement lined) | 0.014 | | |
| Clayware | 0.013 | | |
| Plastic | 0.012 | | |
| Greater than 1.2 m/s | | | |
| Concrete | 0.013 | | |
| DI (cement lined) | 0.012 | | |
| Clayware | 0.011 | | |
| Plastic | 0.010 | | |

The above values are recommended following review and experimental work undertaken at HR Wallingford during 1995 to 1996. The value of n should be interpolated for velocities between 0.75 and 1.2 m/s.

Design Flow Depth

The design depth of a sewer is always less than 100 percent of the diameter to accommodate deviations from the design slope and flow rates, to ensure adequate ventilation and to protect against the possibility of choking. Recommended design depths given in various literature and design guidelines vary between 30% to 85% of sewer diameter.

The variation in design depth with diameter used in past projects in Jordan is as shown in Table 5.2. These flow depths allow for adequate ventilation in small diameter sewers and also allow for additional capacity to carry some of the stormwater flows that are illegally connected to the sewer system.

| Diameter [mm] | Maximum design flow depth [as % of diameter] |
|---------------|---|
| 200 | 50 |
| 250 | 50 |
| 300 | 67 |
| 400 | 67 |
| 500 & larger | 75 |

Table 5.2Design Flow Depth vs. Diameter

Minimum Velocity

The minimum flushing velocity of flow in a sewer is taken to be 0.75 m/sec for the calculated hourly peak flow, achieved at least once per day, to prevent the deposition of mineral matter, such as sand and gravel.

All main sewers are designed to achieve this velocity during the early years of the operation of the system, while secondary sewers are designed to achieve this velocity at the design horizon flows because the design flow quantities in these sewers will not be achieved during the early years of the operation of the system.

Minimum Gradient

Table 5.3 presents the minimum slopes needed to achieve a velocity of 0.9 m/s at half full flow for concrete pipe against different pipe diameters. These minimum slopes will be adopted when designing new sewers.

For diameters of 700 mm and larger, an absolute minimum slope 0.2 % is taken, because lower slopes will be influenced too much by the uncertainty due to the construction.

It is important to note that for the smallest pipe diameter of 200 mm at upstream ends of sewers and until the connection of 900 persons, the above mentioned minimum gradients will not achieve the required minimum velocities because of the low flows and flow depths.

| Pipe Diameter (mm) | Minimum slope to achieve a velocity of 0.9 m/s when flowing full (mm/m) |
|--------------------|---|
| 200 | 9.9 |
| 300 | 5.8 |
| 400 | 3.9 |
| 500 | 2.9 |
| 600 | 2.3 |
| 700 and larger | 2.0 |

Table 5.3Minimum Gradients of Sewers vs. Pipe Diameters

The minimum gradients for the 200 mm diameter sewers for self cleansing pipes (calculated based on internal diameters) that would achieve a sheer stress of 3 N/m^2 for the assumed per capita flow generation rates of 79.1 lpcd in winter season at 2010 flow conditions are shown in Table 5.4.

| Connected population | Minimum Gradient for Self Cleansing (mm/m) |
|----------------------|---|
| 10 | 20.0 |
| 200 | 20.0 |
| 250 | 19.0 |
| 300 | 17.0 |
| 350 | 16.0 |
| 400 | 15.0 |
| 450 | 14.0 |
| 500 | 13.0 |
| 700 | 12.0 |
| 800 | 11.0 |
| 900 | 10.0 |

| Table 5.4 | Minimum Gradients of 200 mm Sewers for Self Cleansing as a Function |
|-----------|---|
| | of Connected Population |

The gradients of the pipes should be chosen in such a way that the velocity in all pipes is maximized. This means that along a sewer stretch with the same diameter, the sewer gradients should be as equal as possible, certainly where they are near the minimum gradients.

In order to maximize the benefit of the terrain slope for the self-cleansing behaviour, the pipes will follow as much as possible the shortest path to the main sewers. This will minimize deep excavations and also residence times.

Maximum Velocity

The maximum velocity at design flow depth in concrete and plastic pipe sewers shall be limited to 4.0 m/sec to prevent damage to sewers from the erosive action of the materials suspended in the wastewater.

At velocities higher than 4 m/s ductile iron pipe sewers shall be used.

Flow Pattern and Peaking Factor

Since wastewater flows vary substantially throughout the day, peaking factors for sewers are applied to the average design flow as a function of the connected population. The smaller the population, the larger the peaking factor.

An applicable formula for calculating the daily peaking factor (PF) for populations of 1,000 to 80,000 is the Babbitt formula, which is as follows:

$$PF = \frac{5}{\left(\frac{P}{1000}\right)^{1/6}}$$

And the applicable formula for calculating the daily peaking factor (PF) for populations exceeding 80,000 is the Bauman formula, which is as follows:

$$PF = \frac{18 + \sqrt{P/1000}}{4 + \sqrt{P/1000}}$$

Where PF = Peak Factor P = Population

The derivation of the peaking factors (PF) for sewer design based on the above is summarised in Table 5.5.

| Table 5.5 | Peaking Factors f | for Design of Sewers |
|-----------|-------------------|----------------------|
|-----------|-------------------|----------------------|

| Population | Daily peaking factor |
|------------|----------------------|
| 1,000 | 5.0 |
| 2,000 | 4.5 |
| 3,000 | 4.2 |
| 4,000 | 4.0 |
| 5,000 | 3.8 |
| 10,000 | 3.4 |
| 20,000 | 3.0 |
| 40,000 | 2.7 |
| 50,000 | 2.6 |
| 60,000 | 2.5 |
| 80,000 | 2.08 |
| 100,000 | 2.0 |
| 150,000 | 1.86 |

| Population | Daily peaking factor |
|------------|----------------------|
| 200,000 | 1.77 |
| 300,000 | 1.66 |
| 400,000 | 1.58 |
| 500,000 | 1.53 |

For the design of the extensions of Zarqa wastewater system more representative peaking factors derived from the analysis of the results of the flow measuring programme conducted under this study will be used.

5.3.2 Sewer Design and Installation Considerations

Size of Sewers

The minimum size of sewer pipe, to prevent clogging shall be:

Minimum service connection diameter: 150 mm

Minimum sewer diameter: 200 mm

Installation and Connection Details

The local details in the connections, junctions, etc are very important for the minimizing of the head losses and the prevention of flow disturbance that leads to deposits.

For this reason, the flowing aspects should be taken into account:

- All house connections should be made using the proper fittings of a Y-junction and a 45 degree bend;
- Connections at angles of 90 degrees should be avoided;
- Manhole floors should have proper benching for a fluent flow through them; and
- Sudden flattening of gradients after steep gradient sections should be avoided.

Depth of Sewers

The minimum depth of sewers shall be 1.50 m to allow house connections to be made and to reduce the crossing probabilities with other utilities such as water, electricity and telephone.

The minimum cover of the sewer pipe shall be 1.0 m to protect the pipe from traffic loads. If this protection is not achieved then the sewers shall be encased in concrete.

The maximum depth depends on the slope, topography, ground conditions and other factors, but typically should be limited to 6 m.

Separation Distance between Sewers and Water Mains

The horizontal separation distance between sewers and water mains shall not be less than 3.0 m. The vertical separation distance at crossings between inverts of water lines and crown of sewers shall not be less than 0.5 m. Where this vertical separation distance in not secured, both lines shall be concrete encased for at least 3.0 m from both sides of the crossings.

Width of Trenches

Width of trenches shall be limited to outside pipe diameter plus 600 mm. Minimum working space around the sides of the pipe shall be 200 mm.

Pipe Bedding

Pipe bedding is the prepared layer of granular or concrete material acting as a support under a pipe, and determined by calculating external loads in conjunction with pipe strength and engineering requirements. Type and class of bedding for concrete pipes shall be determined by the following formula:

 $BeddingFactor = \frac{ExternalLoad * SafetyFactor}{PipeStrength}$

Where: External Load is the total soil and traffic load on the pipe (KN/m)

Pipe strength is defined as the line load that a pipe can sustain without the development of cracks of width greater than 0.25 mm over a distance greater than 300 mm in a two or three edge bearing test (KN/m)

Safety factor is usually taken as 1.0 and 1.3 for reinforced and non-reinforced pipes, respectively

The type of bedding used with respect to bedding factor shall be as given in Table 5.6

| Bedding details | | | Bedding factor |
|-----------------|---------------------|---------------|----------------|
| Class | Material | Bedding angle | |
| A | Reinforced concrete | 180° | 3.4 |
| В | Granular | 180° | 2.0 |
| В | Shaped sub-grade | 120° | 1.9 |
| С | Granular | 60° | 1.5 |
| D | Granular | 0° | 1.1 |

Table 5.6 Bedding Factor for Concrete Pipes

Notes:

- 1. The bedding angle refers to the width of bedding support under the pipe
- 2. Class D bedding should only be used when suitable bedding material is not available.
- 3. Class A concrete bedding should not be used unless there are special requirements for shall sewers installed under heavily trafficked roadway.

The minimum thickness of the pipe bedding under pipe barrel shall be 25 percent of the outside pipe diameter or 100 mm whichever is more.

5.3.3 House Connections

House connections, usually 150 mm in diameter, shall preferably be connected to the main sewers at manholes or at Y-junctions if distances to manholes are long. These shall be installed at a minimum gradient of 2 percent and at 90 degrees to the centreline of the sewer.

House connections shall end with plug end half meter outside the property wall to permit house connection to be made.

All house connections inside the properties shall be provided with ventilation pipes.

5.3.4 Manholes

Manholes are provided on sewers as a means of access for inspection, testing and clearance of obstructions. Except for very shallow sewers of less than one metre depth to invert, all manholes should be of adequate dimensions to facilitate entry and for the operation of cleaning apparatus while wearing full safety equipment.

Manholes shall be provided at the head of a sewer, at every junction of two or more sewers and wherever there is a change in its alignment, gradient, diameter or material. Otherwise maximum spacing should be as listed in Table 5.7.

Table 5.7Maximum Spacing between Manholes

| Sewer diameter | Maximum spacing |
|-------------------|-----------------|
| 200 mm | 50 m |
| 300 & 400 mm | 60 m |
| 500 mm and larger | 90 m |

Standard manholes for sewers shall be of cast-in-situ or precast reinforced concrete circular rings. Manhole size selection is a function of main sewer diameter, number of pipe entries together with depth of the manhole but, to avoid individually designing every chamber, standardization has been introduced. The sizes of the manholes shall be as shown in Table 5.8:

| Maximum pipo | Depth to soffit of main inlet sewer less than 3 m | | inlet sewer | Depth to soffit of main inlet sewer more than 3 m | | |
|---------------|--|---------|-------------|--|---------|---------|
| diameter (mm) | Number of incoming pipes | | | Number of incoming pipes | | |
| | 1 | 2 | 3 | 1 | 2 | 3 |
| 200 | 900 | 900 | 1000 | 1000 | 1000 | 1200 |
| 300 | 900 | 1000 | 1200 | 1000 | 1200 | 1500 |
| 400 | 1000 | 1200 | 1500 | 1200 | 1500 | 1500 |
| 500 | 1200 | 1500 | 1500 | 1500 | 1500 | 1800 |
| 600 | 1500 | 1500 | 1800 | 1500 | 1800 | 1800 |
| 700 | 1500 | 1800 | Special | 1800 | 1800 | Special |
| 800 | 1800 | Special | Special | 1800 | Special | Special |
| 900 | 1800 | Special | Special | 1800 | Special | Special |
| 1000 | 2100 | Special | Special | 2100 | Special | Special |
| 1200 | 2100 | Special | Special | 2100 | Special | Special |

Table 5.8Manhole Internal Diameters

When two sewers are connected at a manhole or special structure, the crowns of the two sewers should be at the same elevation.

Materials used in the construction of manholes will be resistant to or protected from attack by the aggressive environment which exists in sewers. Sulphate resisting concrete will be used for all concrete works coming in contact with sewers.

Manhole covers and frames are to be circular and manufactured from ductile iron. A minimum clear opening of 660-700 mm shall be specified to facilitate man entry to the sewer with breathing equipment. Heavy duty (40 ton bearing capacity) covers and frames shall be specified for all manholes in roads and streets. Medium duty (25 ton bearing capacity) are specified for footpaths.

Drop manholes are used to connect two sewers where the incoming sewer is shallow and the other sewer is deep or to permit the use of flatter slopes when a sewer is descending a steep slope. When the difference between the elevations of the crowns of the two sewers is greater than 600 mm, a drop manhole shall be used for sewers up to 300 mm diameter.

Vertical drops in sewers larger than 300 mm should be avoided to minimize sewage turbulence inside the manhole and hence minimize the release of H_2S . The higher sewer shall be deepened and, if necessary, a special junction structure shall be provided.

5.3.5 Pipe Material for Gravity Sewers

The various elements of sewerage systems; pipelines, manholes, pumping stations etc., should be constructed from materials which enable them to be readily constructed, and then to be operated with a minimum of maintenance for the required service lifetime, so as to achieve the optimum economic benefits.

Fundamental to the achievement of the above objective is the need to employ materials, which will give a long service life in the environmental conditions to which they will be exposed. Inspection of the existing sewerage system in Zarqa shows that concrete pipes installed from the mid 1980s are still in good condition.

Biological oxidation of hydrogen sulphide (H_2S) by bacteria of the genus thiobacillus on the moist surfaces of the sewer will produce free sulphuric acid. This acid will attack concrete, asbestos cement, and metal appurtenances unless washed off and made harmless by dilution. The generation of hydrogen sulphide (H_2S) increases with high air temperatures, high strength sewage and low velocities in the sewer. The acid attacks concrete and ferrous materials rapidly so it is critical to select pipe materials that are corrosion resistant and will not suffer from the generation of sulphuric acid in it.

Because Zarqa has moderate air temperatures with steep topography generating high velocities and low retention times, it is considered that generation of hydrogen sulphide (H_2S) in the sewers will not be a problem.

Two types of material capable of resisting sulphuric acid attack are available for use in sewer pipes: vitrified clay and polymeric materials (plastics).

Metal pipes, though suitable for sewer construction, are only likely to be preferred to other materials in circumstances where their extremely high strength is needed to sustain abnormally high loadings or where high velocities are expected. They are therefore not considered suitable for general use in sewers.

The most commonly accepted pipe materials currently used worldwide for sanitary sewer application include:

- Polyethylene (PE)
- Unplasticised Polyvinyl Chloride (uPVC)
- Glass Reinforced Plastic (GRP)

- Vitrified Clay Pipe (VC)
- Concrete Pipe (unreinforced)
- Reinforced Concrete Pipe (RCP)

It is believed that, except for concrete pipe and small diameter uPVC pipe, none of the abovementioned pipes is manufactured in Jordan.

Following is a brief discussion of the above mentioned pipe material:

PE Pipe

PE pipe is used for both gravity and force main sewers. Jointing is primarily accomplished by butt fusion or flanged adapters.

Advantages of PE pipe include:

- 1. Long laying lengths
- 2. Light weight
- 3. Ease in field cutting

Disadvantages include:

- 1. Relatively low tensile strength and pipe stiffness.
- 2. Requires high quality workmanship for placing bedding and backfilling otherwise pipe will fail by excessive deflections.
- 3. Requires special tool for jointing (fusion welding machines).
- 4. Possible leakage at connection point with manholes if not properly installed.
- 5. Limited range of size.

uPVC Pipe

uPCV is used for both gravity and force main sewers. Jointing is primarily accomplished with elastomeric seal gasket joint, although solvent cement joints for small diameters are available.

Potential advantages of uPVC pipes include:

- 1. Light weight
- 2. High impact strength.
- 3. Easy to install and cut.

Disadvantages include:

- 1. Subject to excessive deflection when improperly bedded and backfilled.
- 2. Limited range of sizes
- 3. Can be affected by UV.

GRP Pipe

GRP pipe is used for both gravity and force main sewers. Advantages and disadvantages of GRP pipe are similar to uPVC except that large diameter GRP pipe is available.

GRP is specified by nominal diameter, pipe stiffness and pipe class. Standard pipes utilize couplings for jointing to each other and also spigotted fittings.

VC Pipe

VC pipe is used for gravity sewers only. The product is manufactured from clay and shales.

VC pipe is manufactured in standard and extra strength classifications. VC pipe is specified by nominal pipe diameter, strength and type of joint.

Main advantages include:

- 1. High resistance to chemical corrosion
- 2. High resistance to abrasion.

Disadvantages include:

- 1. Heavy pipe
- 2. Subject to shear and beam breakage if improperly bedded.
- 3. More expensive than GRP or uPVC pipe.

Concrete Pipe

Reinforced (RCP) and non reinforced concrete are used for gravity sewers. Reinforced concrete pressure pipe is used for pressure as well as gravity sewers.

Standard specification, advantages, disadvantages of concrete pipes are well known as they are the most common pipe material used in Jordan.

Recommended Pipe Materials

Based on the above, it is recommended that the technical specifications for the construction of gravity sewers in Zarqa permit only the pipe materials shown in Table 5.9.

Table 5.9 Recommended Pipe Material

| Pipe diameter | Pipe material |
|-------------------|-----------------------|
| Up to 200 mm | Concrete, uPVC |
| 300 mm to 1000 mm | RCP |
| Over 1000 mm | RCP, GRP, profiled PE |

5.4 <u>Pumping Station Design Criteria</u>

5.4.1 General

Pumping stations are provided in a sewerage system generally to either avoid the construction of uneconomically deep gravity sewers or to transfer sewage flows from isolated communities which cannot be connected to the treatment works or point of disposal by a gravity pipeline.

The pumping station must be located so that neither noise nor odours are potential causes of nuisance. The location of all pumping stations should be such as to permit reasonable vehicular access for the purposes of repair and maintenance.

5.4.2 Pumping Station

Submersible wastewater non-clog pumps shall be used for wastewater pump stations. Pumping stations shall be designed to pump the peak flow with minimum two pumps (1 duty + 1 standby) with consideration for future expansion.

Ductile Iron pipework will be used in the pump station and for inter-connecting pipework.

All main pumping station sumps should be constructed in reinforced concrete.

A single manhole outside the station sump shall be provided at all pumping stations into which all incoming sewers are collected so that there is only one inlet to the sump itself. This simplifies the problem of sewage diversion in the event of a major failure of the pumping station.

Sluice valves and non-return valves are fitted to each pump outlet, and a sluice valve at the suction pipe when pumps are installed in a dry well. Further valves are often not necessary unless it is intended to be able to isolate the rising main for washing out purposes or for the addition of further pumping units in the station at some future date.

If twin rising mains are installed, an emergency by-pass should be provided between the two pipelines, and sufficient sluice valves must then be fitted immediately outside the station, so that either main can operate as the duty main or both pipelines can operate either separately or together.

Although the sumps are entirely closed there is the possibility of odour problem at most main pumping stations. De-odourisation equipment may therefore need to be provided.

Flow metering is to be provided as standard in all pumping stations. Ultrasonic flow measurement installed in a venturi flume will be designed for the measurement of incoming flow. Whereas, electromagnetic flow meters will be utilised for outlet flow measurement.

Sewage composition can vary widely, adequate consideration and necessary provisions shall be taken to ensure that sewage pumping station equipment and materials are suitable for the anticipated composition of sewage. Mechanical screens and in some cases grit removal systems should be provided to protect pumps and prevent the pumps being clogged by large objects.

Also, consideration should be given to providing main pumping stations with emergency storage facilities sized according to design requirements, should space permit.

Sewerage systems normally incorporate two types of pumping stations:

- 1. Submersible stations
- 2. Wet well / dry well stations.

Submersible Pumping Stations

Could be used to serve average wastewater flows up to 100 L/s at maximum 80 m head, the submersible station basically comprises a wet well with two or more submersible pump sets.

Submersible pumps must be provided with corrosion resistant guide rails, chains and special automatic coupling flanges to permit routine withdrawal and replacement of the pumps without undue difficulty and without entry into the well.

Access covers must have a clear opening of at least 600 mm; one or more covers being provided so as to enable each pump to be withdrawn vertically. The covers must be lockable, of adequate strength for vehicular traffic as may be appropriate, and capable of being lifted by not more than two operators.

Access ladders must be provided and bolted in place in order to facilitate future renewal.

Wet Well / Dry Well Stations

Wet well / dry well pumping stations are designed essentially to be able to isolate the pumping equipment from the sewage without moving the equipment, for ease of maintenance. Large pumps can therefore be installed to handle the major flows. These main pumping stations normally operate on trunk sewers.

In addition to most of the characteristics listed for the submersible stations, the pumps of wet well / dry well pumping stations should be able to handle solids of minimum size of 60 mm and the pumping stations also include a superstructure to house control and switchgear to accommodate full time attendance, all within a walled enclosure.

5.4.3 Pump Station Components

Wet Wells

Wet wells should preferably be reinforced concrete structure. The design of wet wells must be such as to ensure satisfactory flow conditions to the pumps, and in particular to avoid the formation of vortices. There must be a minimum capacity between first start and cut-out level controls to give between ten and fifteen starts per hour. The inlets must each be provided with a sluice valve or penstock.

Pump start/stop sensors should be spaced to suit a pumping regime which produces the best compromise between stop/start and "continuous" flow. The minimum live volume in the sump per pump is:

$$V = \frac{QT}{4}$$

Where V = live volume of wet well (m³)

 $Q = pump \ capacity \ (m^3/min)$

T = *minimum* on/off cycle time offered by pump manufacturer (min)

In addition to the minimum live volumes the size of the wet well is to allow for the required minimum submergence of the pumps and minimum floor clearance which are given by the following formulas:

Minimum submergence (m) = $0.04 \times (pump \ capacity)^{1/2} + 0.2$

Minimum floor clearance (m) = 0.5 X pump suction diameter (m)

For an installation with several identical duty pumps, the start and stop levels of all pumps differ by a constant value determined by the characteristics of the control system. The difference in levels should be large enough to eliminate pump starts and is normally in the range of 200 - 300 mm.

Side slopes to wet well benching should be a minimum of 40 to 45° to the horizontal.

Pumps

Pumps are to be of a submersible type with a minimum of two sets provided (one duty and one stand-by). However, it might be necessary to use overhung impeller pumps for the large capacity high head pumps.

The following criteria are to apply to pumps:

- The pump station total pumping capacity must be able to pump the peak design flow. In other words, the single pump capacity must be equal to peak design flow divided by the total number of operational pumps with the head required for pumping at peak flow.
- Pumps must be heavy duty, non-clog type with double machined shaft seals.
- Impeller design and motor selection should preferably be such that the unit is of the non-overloading type.
- Pump motors must be designed to provide for 30% overload to the working load.
- Impeller speeds must not exceed 1500 rpm. However, for cases of low flows against high heads impeller speeds of 3000 rpm shall be acceptable.
- Impellers must be of cast construction capable of passing solids. Impeller passages shall be smooth so that rags and stringy matter will not adhere to them and shall be capable of passing a sphere of 60 mm dia. without choking.
- Screw-on impellers are not acceptable.
- Impellers must be keyed or pinned to the drive shaft or fixed by other approved methods.
- Under normal operating conditions the pump should run close to its best efficiency point.

5.4.4 Pre-treatment Facilities

Screens

The following criteria are to apply to screens:

Coarse Screens

| Screen Type | Travelling band, rake type bar screens, multiple rake type bar screens |
|----------------------------------|--|
| Screen Operation | Automatic |
| Bar spacing | 40-50 mm |
| Bar width | 3-6mm (depends on the manufacturer) |
| Min velocity u/s screens | 0.5 m/s |
| Velocity through screens | 1.0-1.2 m/s |
| Slope | $0-90^{\circ}$ (depends on the type) |
| Blinding factor for max headloss | 50% |
| Maximum allowable headloss | 400 mm |
| Material | AISI 316 (L) |
| | |

Fine Screens

Screen Type Screen Operation Drum screens , multi rake climber type screens Automatic

| Perforated or bi-directional |
|---|
| can be operated under (n-1) conditions or standby to be provided |
| 15-20 mm |
| 3-6mm |
| 0.5 m/s |
| 1.0-1.2 m/s |
| 0-40° (depends on the type) |
| 50% |
| 400 mm |
| AISI 316 (L) |
| |

General Consideration for design of the Screening Facilities

- Screen channels must be equipped with ON/OFF actuated penstocks.
- Each screen channel must be covered with closed fitting removable covers (preferably GRP)
- Sufficient lifting equipment must be installed to lift the screening skips for removal.
- Service water must be provided for each screen and sluice trough with the required pressure (usually 4-6 bars)
- The screens should be able to handle flows when one unit is out of service so the design must be based on (n-1) conditions or a standby channel must be provided
- Hydraulic jumps must be avoided in the water surface profile which will create turbulence and release excessive H2S.
- Air inlet and extraction dampers must be provided on the covers
- It is advisable to have a sump in the screening channel for complete emptying of the channel during maintenance.
- Inlet and outlet arrangement of the screens must be carefully designed to avoid dead spots and hence settlements.
- Connection from the washpactors back to the screen channel must be provided for organics discharge.
- Wash water feed should be arranged using solenoid valves.

Aerated Grit and Grease Removal

The following criteria are to apply to grit and grease removal facilities:

Grit and Grease Removal

| Туре | Aerated combined grit and grease removal |
|-------------------|---|
| Number | Sufficient number of multiple units must be provided to allow cleaning , service and repair |
| Detention time | 5 mins @ Peak flow (excluding grease compartment) |
| Aeration Requirt. | 0.4-0.6 Nm3/min-m tank length |
| Blowers | 1 per channel + standby , to be designed according to site conditions |

| Aeration Type | Coarse bubble diffusers | | |
|----------------------|--|--|--|
| Grit Scraping Mech. | Traveling bridge or screw conveyor | | |
| Grit removal Mech. | Via centrifugal or submersible wear resistant | | |
| | 1 4 2 m/c in grit transfer pipe | | |
| | | | |
| | 2.5-7 11 | | |
| Tank Length | 7.5-20 m | | |
| Width : Depth Ratio | 1:1 to 5:1 (Typical value 1.5:1) | | |
| Length : Width Ratio | 3:1 to 5:1 (Typical value 4:1) | | |
| Surface Loading | 16.6 – 35.6 m3/m2-h | | |
| Removal Efficiency | 95% removal of grit particles having 20 microns | | |
| | size | | |
| Grit Quantity | 0.004 – 0.2 m3 / 1000 m3 influent wastewater | | |
| Grit SG | 2.65 | | |
| Inlet Grit conc. | 30-80 mg/L | | |
| Settled grit conc. | 3000-1000 mg/L | | |
| Bulk density of grit | 500 kg/m3 (grit-water mixture) | | |
| Bottom cone slope | 35-450 | | |
| Grease removal | | | |
| Mechanism | Flotation effect created by the spiral roll pattern with aeration Followed by surface skimming | | |

Grease chamber

| 25 -35 m3/m2-h @ maximum flow |
|--|
| Equal to grit tank length |
| Determined by the surface loading rate and |
| length of grit tank |
| max 10 minutes @ Peak flow |
| : 0.8-1.2 |
| |

Typical cross section of aerated grit removal chamber is shown in Figure 5.1.





General Consideration for design of the Grit/Grease Removal Facilities

- Inlet to the grit tanks must be equipped with ON/OFF actuated penstocks.
- Each grit tank and the connecting channels must be covered with closed fitting removable covers (preferably GRP)
- Air inlet and extraction dampers must be provided on the covers
- Sufficient lifting equipment must be installed to lift the skips for removal.
- Service water must be provided for grit fluidization, flushing and for the grit classifier
- Grit fluidization must be done prior to pumping grit
- Grit classifier operation must be interlocked to the operation of the grit pumps.
- Discharge piping with nominal diameters of min 100mm must be used to avoid high pressure and scouring velocities that will result in wear
- Length of grit suction pipe must be minimized
- A connection must be provided from the grit classifier to the inlet of the screens to allow organics discharge
- Wash water feed should be arranged using solenoid valves.
- Tank inlet and outlet should be positioned so that the flow through the tank is perpendicular to the spiral roll pattern.
- The concentration of fats, oil and grease (FOG) must be analyzed during the detailed design stage.

5.4.5 Odour Control Works Design Criteria

Odour control

To ensure adequate odour control system performance, all of the pre-treatment works including the coarse screens, fine screens, grit removal tanks, the connecting channels in between and the wet well of the pumping station must be covered with closed fitting removable GRP or other type of covers which will be resistant to heavy corrosion.

Extraction Rates

The headspace under the covers must be connected to an odour control system where the foul air will be treated to the required standards. The air extraction shall be sufficient to maintain a negative pressure under the covers and to avoid elevated levels of H_2S . The criteria given Table 5.10 will be followed for extraction rates:

Table 5.10 Design Criteria for Air Extraction Rates at Pumping Station Facilities

| Process unit | Air changes per hour (ACPH)* |
|---------------------|--------------------------------|
| Coarse Screens | 6-12 |
| Fine Screens | 6-12 |
| Grit Removal Tanks | 1.2 x Q _{process} air |
| Connecting Channels | 6-12 |
| Wet Well | 12 |

*: to be finalized during detailed design

The covers must be fitted with sufficient number of air inlet and extraction dampers over each process unit. Then the combined foul air will be fed to the odour control system.

Inlet Pollutant Concentrations and Load to the Odour Control System

The inlet pollutant concentrations are a key to the selection and design of the odour control system. The major odour pollutants generated from the pumping stations and the sewage treatment plants can be listed as H_2S , mercaptans (R-SH), dimethyl sulfide (DMS), dimethyldisulfide (DMDS) and volatile organic compounds (VOCs).

The H_2S concentration depends on a number of factors including sewage age, sewage temperature, load and the degree of aeration in the network. The length of the sewers feeding the pumping stations has a direct effect on the age of sewage. Measurement of the inlet pollutants and odour levels is required prior to determining appropriate odour control measures.

The design criteria for the inlet pollutant concentrations will have to be finalized during detailed design supported by actual measurement at East and West Zarqa pumping stations.

Performance Criteria for Odour Control Systems

The required stack discharge quality shall be as shown in Table 5.11:

| Contaminant | Expected Design % removal at peak inlet design load | Maximum discharge concentration at peak load (ppm) | Maximum discharge concentration at peak load |
|---------------------------|--|---|---|
| Hydrogen sulphide (H2S) | 99.95 | 0.05 | Total including all |
| Dimethyl sulphide (DMS) | 99.9 | 0.01 | contaminants not to exceed 500 OU/m3 |
| Mercaptans (R-SH) | 99.9 | 0.003 | |
| VOC (average Mol. Wt 120) | There shall be sufficient removal of VOCs to achieve stack discharge max. concentration specified (at peak load) | | |

Table 5.11 Stack Discharge Quality

General Design Considerations for Odour Control Systems

- The odour control system must be designed, operated, maintained, and managed under Good Industry Practice.
- All components of the OCU(s) must be compatible with the conditions and chemicals to which they will be subjected to during normal operation. Compounds with which the materials of construction must be compatible with are Hydrogen Sulphide, Sulphuric Acid, Ammonia, Dimethyl Sulphide, Mercaptans, and any other corrosive gases that may be present.
- Odour control system must provide redundancy (level of redundancy to be confirmed during detailed design stage) in its design concept to eliminate any possibility of odorous discharge. This may be achieved by redundancy of equipment of the same kind or by a combination of odour control technologies. (details to be finalized during detailed design)
- Prevent odour complaints from the public by reducing concentrations of hydrogen sulfide, mercaptans, other sulfur-containing compounds and Volatile Organic Carbons

(VOCs) such that those from the site are undetectable at the site boundaries. The odour level at the site's boundary must not be above 5 ppb on an one hourly average basis based on the AS4323.2 standard odour measurement method.

- The discharge of odorous air at the odour control system stack under no circumstances must ever exceed 0.1 PPM of H₂S for more than one day. The odour control system design must stipulate for sufficient redundancy and robustness to guaranty this level of performance under all circumstances.
- The discharge of Hydrogen Sulphide at the odour control system stack must remain below 0.05 ppm under normal operating condition at expected peak loads.
- The stack must be sized tall enough (not less than 3 meter taller than the nearest interfering structure) to disperse the discharge with a minimum discharge velocity of 15 m/s.

Acceptable Technologies for Odour Control

- Wet chemical scrubber utilizing sodium hydroxide and sodium hypochlorite as the scrubbing liquor for removal of odorous compounds and neutralizing the scrubbing solutions salts to a stable condition. The chemical scrubber may be followed by an Activated Carbon (AC) filter as a polishing stage to remove the remaining VOC's. The disadvantage of Wet Chemical Scrubber is the continuous use of chemical solutions, which requires continuous monitioring and adds high operational costs.
- 2. Bio-scrubbers and AC filter. The biological system must remove the bulk of odorous compounds followed by a polishing AC system. Bio-scrubber design and specification must be per guidelines to be provided in the detailed design stage.
- 3. Biofilters or biotrickling filters. These are reliable and proven technologies that has been used in many plants. The operating cost of these systems are low as they do not require any chemicals however it cannot handle high and variable H2S loads. It requires a high footprint.
- 4. Combination of bioscrubbers and wet chemical scrubbers can also be used to substantially lower the chemical costs.

According to the above description, it is recommended to consider the Bioscrubber followed by activated carbon filter.

Design Criteria for Bioscrubber followed by Activated Carbon Polishing Filter

Bioscrubbers

The bio-scrubber treatment stage will contain biologically active synthetic media layers to facilitate the growth of bacteria necessary for biological oxidation of odorous compounds. The media must have the following properties:

- 1. It should be a dual-density structured media made entirely of a synthetic, non-reactive material. Organic and/or non-synthetic inorganic media materials or any random-packed media shall not be allowed.
- 2. The media is to facilitate efficient mass transfer of odour compounds and growth of bacteria used to oxidize odour compounds.
- 3. Media must be designed to be compatible with all process contaminants and their byproducts; and;
- 4. It must be suitable for use at pH levels as low as 1.0.

The bio-scrubber design criteria must be selected to fulfil the following requirements:

- 1. The system must utilize an intermittent irrigation system consisting of a single spray nozzle per media layer to maintain a wetted surface on the media and provide chemical nutrients to the bacteria on the media.
- 2. The system must be designed to allow the formation of a pH gradient within the media bed, to allow the growth of autotrophic bacteria for hydrogen sulphide oxidation, and heterotrophic bacteria for the oxidation of other Reduced Sulphur Compounds (RSC's).
- 3. The reactor(s) must be configured with one fluid injection spray nozzle for each treatment layer.
- 4. The spray nozzle must be located above the treatment layer and must disperse the fluid evenly over the entire treatment layer.
- 5. Systems using multiple spray nozzles and/or a spray header will not be acceptable.

The design criteria for the Biofilter is summarized as follows:

| No of Biofilters | two (as minimum) |
|-------------------------|--|
| Media loading rate | 50-850 m/hr |
| 3 | 0.014-0.25 m/s |
| Packing depth range | 150-3000 mm |
| Main media size | 6-8 mm |
| Support media material | Wood chips or equivalnet |
| Support media size | 25-75 mm |
| Support media depth | 150 mm |
| Underdrain system | Perforated PVC pipe |
| Perforation size | 15 mm |
| Air distribution system | Solid supply header with air manifold and perforated PVC laterals |
| Other components | Spray Nozzle |
| | FRP Fans |
| | Irrigation system (sprinklers) to moisturize the |
| | biofilter media |
| | Alkalinity media make up |
| | Media moisture control system |

Activated Carbon

Carbon adsorption system may be utilized as a polishing stage to the chemical or bioscrubbers. Activated carbon is to remove residual sulphur based compounds or any other non-soluble VOCs. The performance of the carbon adsorption system as a standalone unit must meet the minimum requirement of the specification namely 0.1 ppm of H2S concentration if the bio-scrubbers for any reason are by-passed. The carbon must be a Virgin, granular activated carbon derived from bituminous coal suitable for the vapor phase adsorption and catalytic oxidation of odour causing substances. The carbon must be suitable for regeneration of its adsorptive capacity by washing with water with no other chemical added or required. No more than one regeneration per six month is permitted. Carbon must have a minimum operative capacity of 3 years. A system of continuous monitoring of smell in the stream of air leaving the odour control facility must indicate the required regeneration of the carbon unit. The carbon must be of acceptable quality standards in industry and have equal or similar properties shown in Table 5.12:
Table 5.12 Activated Carbon Quality Standards

| Property | Value |
|---|-----------------------------------|
| Apparent density (kg/m ³) | >560 |
| Mesh size (U.S. sieve) greater than 4 mesh | <15% |
| Mesh size less than 7 mesh | <8% |
| Hardness number (min.) | >97 |
| Moisture (w/w max.) | 2% max. |
| Minimum H ₂ S saturation capacity | 0.16 g H_2S removed /1 g carbon |
| H_2S breakthrough capacity (g H_2S removed / cc carbon) | >0.09 |
| Ash (%w) | <8 |
| lodine Number (mg/g) | >800 |
| Butane Activity (%w) | >16 |

Chemically impregnated carbon is not acceptable.

Adsorber vessels with single or double activated carbon bed must be designed to prevent bed fluidization. The minimum contact time for the foul air passing through the carbon bed is 2.5 seconds(empty bed contact time, EBCT). The units must be complete with bed(s) supports, nozzles, piping, valves, instrumentation and controls. The design must provide 33% standing-by capacity to be used when any of the duty vessels undergoes regeneration.

5.4.6 Pumping Mains

Hydraulic Design

Pumping mains, must be designed to withstand the total manometric head on the pumps (static head plus friction loss). An additional allowance should be made for surge in cases of high pumping velocity, or in very long rising mains.

Materials commonly used for rising mains include steel, ductile iron, uPVC, PE and GRP. Welded steel pipe or ductile iron pipe shall be used for pumping mains due to relative large diameters involved.

The diameter of pumping mains should be such that the flow velocity will be in the range 0.75 to 1.8 m/sec.

Single pump vertical discharge pipes should be sized such that the discharge velocities in these pipes will be in the range of 1.8 to 3.5 m/s and collector headers should be sized to achieve a discharge velocity in the range of 1.2 to 2.4 m/s.

Of the numerous formulae used for pressure mains, Colebrook-White and Hazen Williams gives a good degree of accuracy. In metric terms, the Colebrook-White formula is:

V = -2
$$\sqrt{(2gDi)} \log \left(\frac{Ks}{3.7D} + \frac{2.51v}{D\sqrt{(2gDi)}}\right)$$

Where V = velocity (m/s)

g = gravitational acceleration (m/s²)

- *i* = hydraulic gradient (m/m)
- v = kinematic viscosity of fluid (m^2/s)
- K_s = effective roughness (mm)
- *D* = internal pipe diameter (m)

Experimental results have shown that pipe roughness coefficients for sewage pumping mains are more related to flow velocities rather than to pipe material or condition of pipe because of the effects of build up of slime and grease on the inner walls of pipe. Recent experiments have shown that the roughness values are determined by the following relationship:

 $Ks = \alpha V^{-2.34}$

Where Ks = roughness value (mm)

- α = factor usually taken as 2.053 for upper bound design
- *V* = mean velocity (averaged across the pipe cross section) for the actual flow through the pipe (m/s)

In metric terms, Hazen Williams' formula is given below:

$$V = 0.849 C r^{0.63} s^{0.54}$$

Where V = *velocity in meters/sec*

C = Hazen Williams C-value

r = hydraulic radius in meters

s = hydraulic slope, in meters/meter

Typical C-values used for design are tabulated in Table 5.13.

| Material | New pipes | Old pipes | |
|----------------------|-----------|-----------|--|
| Ductile Iron (lined) | 130 | 90 - 110 | |
| Cast Iron | 130 | 80 - 100 | |
| Steel (lined) | 130 | 80 - 100 | |

Valves and Fittings

A pumping main is a pressure pipeline, and its design differs in many respects from the design of a gravity sewer. The basic principles of structural design will equally apply, and to some extent the hydraulic design is similar, but in addition, as the pipeline will normally be laid to follow the ground contours (minimum cover generally about 1.0 m), provision must be made for the release of trapped air at high points, and for washing out at low points. Air valves suitable for use with sewage must be provided at all high points on the line, and may also be required at intermediate positions along long lengths of even gradient, activated carbon odour control units should be installed at the air valve chamber outlet.

A washout should take the form of a tee-junction and valve, and should discharge into a gravity sewer if possible. Valves and connecting pipelines should be at least 80 mm diameter. Where no suitable sewer is available, the washout may have to discharge to a specially constructed sump, which must then be emptied after use. The section of the rising main near the pumping station can sometimes be arranged so that a washout can discharge

to the wet well of the pumping station; if so, the wet well must be of adequate capacity, or alternatively, if a second rising main is installed the pumps can be used to control the level in the well during the period of washing out.

Thrust Blocks and Anchorage

Thrust blocking should be provided on the pumping mains as necessary to prevent movement of pipe or appurtenances in response to thrust. Thrust blocking is required whenever the pipeline:

- Changes direction (for example, tees, bends, elbows, and crosses),
- Changes size such as at reducers,
- Stops such as at dead ends, or
- Connects to valves, at which thrust develops when closed.

Size and type of thrust blocking depends on:

- Maximum system operating pressure or test pressure,
- Pipe size,
- Appurtenance size,
- Type of fitting or appurtenance,
- Line profile (for example, horizontal or vertical bends), and
- Soil strength.

Forces due to expansion and contraction should not be allowed to reach valves, pumps, or other appurtenances that might be damaged by these forces. Appurtenances can be protected by making the connection between pipe and appurtenance with an expansion joint or sleeve coupling, or by providing anchor rings and thrust blocks of sufficient size and weight to prevent the forces from reaching the appurtenance to be protected.

Thrust blocks shall be made of grade 30 reinforced concrete.

5.4.7 Water Hammer

Water hammer is a series of pressure surges or waves resulting when a fluid in motion is forced to stop or change direction suddenly which may be heard emanating from pipe work.

The noise is caused mainly by shock waves which occur at the sonic velocity of sound when water flowing at high velocity is suddenly arrested by rapid closure of online valve(s), check valve(s) in normal operating condition and in common power failure case(s)

In many instances although audible sound is not present, water hammer effect could be observed by pressure gauge reading. Some of water hammer effects are:

- premature failure of valves,
- leakage at joints,
- loosening of supports, and
- burst of pipe.

The rigid pipes experience higher surge pressure than flexible pipes.

Surge Control Criteria

The sum of the operating pressure and the maximum positive pressure surge should not exceed the pipe's allowable pressure class. The following procedure should be followed:

- 1. Calculation of the theoretical pressure surge: Initially, this shall be carried out using the theoretical water hammer calculation. The surge is a function of elasticity of pipe, thickness, pipeline installation and the critical time closing period of valves.
- 2. For small diameters, choose pipelines with pressure class that can withstand the surge pressure.
- 3. For large diameters, if the theoretical surge is higher than the standard pipeline nominal pressure classes, surge suppression equipment must be used.

In case of large pumps, inertia of pumping unit has an effect in minimizing surge pressure.

- 4. Check for the formation of negative pressures in the pipeline during surge events. Provide surge suppression or ensure that the pipeline can withstand the negative surge pressures.
- 5. Control measurements carried out at the installation at the time of commencement of operation should be compared with the values calculated previously. If the pressure surge is observed at an early stage, the risk of failure can be reduced by the installation of pressure surge reduction equipment.
- 6. The maximum negative pressure that the pipe can handle before buckling depends on the surrounding material, the pipe material and wall thickness. Pipes laid in wellcompacted bedding will have a higher permitted negative pressure.

5.4.8 Electrical Design Criteria

All electrical works shall be carried out in accordance with the regulations and guidelines laid down by the Electricity Authority.

Standby generators will be included for in the design of pumping stations.

Duty and standby pumping cycles will be set up to ensure alternate pump operation takes place as standard.

Facilities will also be provided for the installation of a SCADA control system.

Standards

The electrical works will be designed in accordance to the following standards:

- General Technical Specification for Buildings, Electrical Installation, Part 3, 1996, Ministry of Public Works & Housing – Jordan
- Jordan Standards Specifications (JSS) Jordan
- Requirements for Electrical Installations for Buildings (IEE Wiring Regulations), published by the Institute of Electrical Engineers London (UK).
- International Electro-technical Commission (IEC) Standards as applicable
- American National Standard Institute (ANSI)
- Insulated Cable Engineers Association (ICEA)
- National Electrical Code (NEC)

- National Electrical Manufacturers Association (NEMA)
- Underwrites' Laboratories (UL)

Electrical Components

Power Transformer

Power transformer will be designed in accordance with ANSI or IEC Publication 726. The power transformer will operate at (11/0.4) KV or (33/0.4) KV and the capacity of the transformer will be determined after the detailed design of the plant. The transformer will be of outdoor type. The transformer will be supplied and erected by Jordan electric power company (JEPCO).

Stand-By Power Diesel Generator Set

In case of failure of the utility power source, the source of power is automatically transferred by auto transfer switch, and the emergency diesel generator will provide emergency power so as to keep continuous operation.

The Stand-by diesel generator will be designed, rated, assembled and installed in accordance with all applicable standards of ANSI, NEC, U.K. and NEMA.

The generator will be a complete integrated emergency generator system. The system consists of a diesel generator set with related component accessories and automatic transfer switch.

The capacity of the generator will be determined after the design and calculation the load of the pumping station. The generator set will be housed inside a generator room.

Automatic Transfer Switch (ATS)

Separate (ATS) panel will be designed and will comprise of:

- Two contactors, 4 pole with electrical and mechanical interlock
- Status lights indicate which contactor is ON
- Set of control terminals
- Set of load terminals
- Set of protecting fuse
- Front access hinged door with key lock

The (ATS) will be located at the electrical room near the main distribution board.

Main Distribution Board

Main Distribution Board (MDB) will be designed to feed power to the Motor Control Centres (MCC) and secondary distribution board. The MDB will be 3 phase, 400V, 50 Hz. This MDB will be fed by power from both the transformer and the diesel generator through the ATS. Power cable of appropriate size shall be designed to feed the MDB from the ATS.

The MDB will be designed to have a main circuit breaker (MCCB), main busbar, number of outgoing moulded case circuit breakers, in addition to all instruments and accessories needed for the board.

The MDB will be located inside the electric room. The dimensions of the MDB will be determined based upon the plant equipment power.

Secondary Distribution Board

3 phase, 400/230 volt, 50 Hz secondary distribution board will be designed to serve the loads of lighting, power, socket outlets, and power for mechanical equipments.

This distribution board will have a (100) A, 3 pole main isolator and a number of single or 3 pole outgoing breakers, to meet the requirements of lighting and power circuits.

The secondary distribution board will be supplied by power from the MDB through PVC/PVC, or XLPE/PVC cable with size suitable to the load and current designed.

This distribution boards will comply the BS 5486-part 13-1984 requirements or IEC-439 part 1 and 3.

Motor Control Centre (MCC)

Motor Control Centre (MCC) 3 phase, 400 volt, 50Hz will be designed to feed power and control the pumps motors. This MCC will have its own cabinet, main incoming breaker, outgoing breakers, bus bars, starters, protection and monitoring relays, instruments.... Etc. Power cables of appropriate size will feed these MCCs from the (MDB).

System Power Factor

The overall system power factor, including reactive power losses in transformers and other distribution equipment, will not be allowed to fall below 0.92 for the entire plant.

The location of power factor correction facilities will be such as to minimize distribution system power losses.

Cabling and Wires

Wherever possible, underground cabling will be used for inherent protection against fire and mechanical damage. All power, lighting, control and earthing cables will have copper conductors. Cables shall comply with ANSI or IEC 228, 287, 502 and wires will comply with ANSI or IEC 227, 502, 540.

Cables will be sized taking into account the following:

- System voltage and type of system (3-phase or 1 phase)
- Expected short circuit capacity
- Voltage drop
- Current rating
- Conditions of installations

The short circuit rating of cables will correspond to the clearing time of the associated protective device.

The voltage drop in cables will not be more than 4% based on continuous maximum current loading and rated voltage.

Fire Alarm System

The pumping stations will be provided by conventional or addressable type fire alarm system, in order to protect the operators and pumping station contents from fire hazards. The system will include alarm initiating, and signalling devices such as smoke and heat detectors, alarm bells, pull stations. The main control panel of the system will be installed in the administration building.

The fire alarm system design will be based on one of the following standards:

- BS 5839 Fire Defection and alarm Systems in Buildings
- BS 3116 Automatic Fire Alarm Systems in Building
- BS 5445 Specification for components of automatic fire detection System.
- (NFPA-72E) USA
- (IEC 839-1-4)

Earthing System

Earthing of electrical systems, equipment and structures in the installation will be designed to the relative standards.

Instrumentation Control and Automation System

The pumping stations will be provided with instrumentation control and automation system (ICA) to enable the control of the operation of the pumping station facilities, such as operational status equipment, water levels, flow rates, etc., by using central monitoring control system in the administration building. The system will consist of PLC. I/O cards, modems, instrumentation wiring...etc.

6. TOPOGRAPHICAL SURVEY OF MAIN SEWER SYSTEM

6.1 Introduction

The field survey works started at an early stage of this project. The survey works included a topographic survey of 250 km of main and sub-main sewer systems (all sewers with diameters equal to or greater than 300 mm, in addition to the collector pipes with diameters 200 mm).

The survey works were conducted to collect the data required for building the hydraulic model, since the identified 250 km of main and sub-main sewers are the ones that were ultimately represented in the hydraulic models.

The field survey works also included surveying of approximately 50 km of proposed trunk sewer mains route. Work under this activity included taking levels at 20 meter intervals and documenting the landmarks (streets, wadis, etc) that the proposed lines pass through, within a width of 30 meters.

6.2 Benchmarks and Triangle Points

The field surveying works were started by obtaining bench marks from the Royal Geographic Center. These benchmarks were used to define all elevations within the study area and are shown in Table 6.1.

| Benchmark | Elevation |
|-----------|-----------|
| JZ 21 | 578.17 |
| JZ 16 | 539.584 |
| ZW 4 | 604.389 |
| ZW 5 | 582.811 |
| ZW 7 | 674.621 |
| ZW 2 | 528.43 |

Table 6.1 List of Benchmarks Obtained from the Royal Geographic Center

Additionally, Survey Triangulation Points that fall within the required survey area were obtained from the Land and Survey Department to connect the project with the national Jordanian coordinates. The obtained triangulation points are listed in Table 6.2

Table 6.2List of Triangulation Points Obtained from the Land and Survey
Department

| Triangulation Point | Northing | Easting |
|---------------------|-------------|-------------|
| ZR-74 | 168,165.334 | 256,194.694 |
| ZR-43 | 169,910.470 | 249,852.550 |
| ZR-11 | 173,086.491 | 256,813.540 |
| ZR-203 | 158,353.340 | 247,866.370 |
| ZR-79 | 167,774.940 | 261,088.610 |

| Triangulation Point | Northing | Easting |
|---------------------|-------------|-------------|
| ZR-209 | 185,107.398 | 254,243.673 |
| ZR-6 | 173,856.560 | 253,858.190 |
| ZR-204 | 157,833.300 | 249,093.330 |
| ZR-11 | 173,086.490 | 256,813.540 |
| TR-950 | 178,664.820 | 260,944.560 |
| FA-215 | 171,146.770 | 271,441.580 |
| AC-1705 | 166,819.222 | 267,501.464 |

6.3 <u>Surveying Works</u>

The field surveying works consisted of the following main activities:

- The survey of existing manholes on the identified 250 km. Works under this activity included defining the location of each manhole (x, y and z coordinates), opening the manhole cover, measuring the invert levels of inlet and outlet pipes and describing the situation of each manhole including cover, steps, sediments, etc. The identified 250 km are shown in Figure 6.1.
- 2. The survey of about 50 km of the route of proposed trunk sewer mains. Work under this activity included taking levels at 20 meter intervals and documenting the landmarks (streets, wadis, etc) that the proposed lines pass through, within a width of 30 meters.

Based on obtained benchmarks and triangulation points, secondary bench marks and traverse have been created to cover the entire project area.

Each surveyed sewer line was categorized according to diameter and numbered within the category of its diameter, in order to obtain a unique number for each sewer line. Additionally, manholes were given numbers based on their line number and an additional serial number allocated per line.

The coordinates of each manhole were computed from the base map, and the tentative locations were identified in the field using GPS differential instruments. Once a manhole was located the cover was opened and invert levels and other required information were recorded.

The manhole survey works required significant time and effort than anticipated at site to find, identify and open the required manholes to collect the required data. Nevertheless, with all the efforts and attempts including; several site visits, as built drawings verification and WAJ/Zarqa assistance, there was a considerable number of manholes that could not be opened or not found. However, most of the important required manholes have been found and recorded. The remaining manholes, as built drawings have been used to complete the data and where as built drawings are not available, interpolation between the surveyed manholes was used.

The manholes that could not be found can be attributed to one or more of the following reasons:

1. Some sewer lines were buried deep below high constructed fill, embankment, streets, etc;

- 2. Some sewer lines were constructed within private boundaries, and as such no access was allowed to even search for the required manholes; and
- 3. Some sewer lines have been re-aligned and moved from their original location without updated record drawings that show the new location.

Additionally, there was a number of manholes which were found but could not be opened for several reason, as follows:

- 1. Some manholes have not been opened for decades and they will require covers to be broken in order to access them
- 2. Some had flipped over covers and they will require covers to be broken in order to access them
- 3. Some were covered by a large concrete block or a pile of stones or concrete to prevent cover removal.
- 4. Some were covered by street asphalt.

For these manholes, coordinates and levels of the covers (x, y and z) were surveyed, but the invert levels of inlet and outlet pipes could not be taken.

Furthermore, the important unopened manholes with a diameter above 200 mm were identified (Approximately 76 manholes). With a representative from WAJ / Zarqa, these manholes were revisited and the reasons for not being opened have been identified. Table 1 in Appendix 6 is a summary of the findings of these manholes.

The summary of the number of surveyed, could not be opened and not found manholes is shown in Table 6.3.

| Zone | Surveyed (No.) | Could Not Be Opened (No.) | Not Found (No.) | Total (No.) |
|-------------|-------------------|------------------------------|--------------------|-------------|
| EAST ZARQA | 1302 | 342 | 311 | 1955 |
| WEST ZARQA | 2169 | 510 | 944 | 3623 |
| Total (No.) | 3471 | 852 | 1255 | 5578 |

Table 6.3Manhole Survey Summary

The layout of the main surveyed sewer system manhole locations and status are shown in Figure 6.2.

Survey Benchmarks and surveyed trunk mains are shown in Figure 6.3.

6.4 <u>Surveying Data</u>

The data obtained from the surveying works includes the following:

- 1. An AutoCAD file containing:
 - Network layout with coordinates;
 - Pipeline numbers with diameters; and
 - Manhole numbers.
- 2. An excel sheet for the manholes for each pipeline containing:

- Manhole numbers;
- Easting and Northing for each manhole;
- Elevation of each manhole;
- Inlet and outlet invert levels at each manhole, and
- Invert level of pipes connected to the manhole.
- 3. An excel sheet for each manhole containing:
 - Manhole number;
 - Diameters of connecting pipes;
 - Condition of cover and frame;
 - Condition of iron steps; and
 - Sediments in the manhole.

As previously mentioned, a field survey was conducted along the proposed alignment of the new proposed trunk main sewers. Profiles were made for about 50 km of proposed trunk lines, with levels taken at 20 meter intervals. All land marks within a 30 m width at each interval were documented. Profiles were produced for the proposed mains of new served areas such as Hai al-Batrawi, Hai al-Ahmad, Hai Nassar, Dhuleil, Ghareisa and Umm Sulleih. The summary of surveyed main trunks line routes are shown in Table 6.4

| Table 6.4 | Summary of Prop | osed Main Trunk | Line Land Survey |
|-----------|-----------------|-----------------|------------------|
|-----------|-----------------|-----------------|------------------|

| Trunk Line Route | distance (km) |
|------------------------|---------------|
| Wadi Aldlial | 18.956 |
| AlKherbeh AlSamra | 1.963 |
| Wadi Garesa - AlSokhna | 15.463 |
| Wadi al Sokna | 5.088 |
| Wadi al Batrawi | 5.053 |
| Wadi Shnelar | 1.401 |
| Wadi Berin 1 | 1.543 |
| Wadi Berin 2 | 0.646 |
| Wadi Berin 3 | 2.282 |
| Total Surveyed (km) | 52.395 |

Detail survey data are attached in a CD in Appendix 6.

7. FLOW MONITORING

7.1 Introduction

As per the Terms of Reference (TOR) for this Project, the Consultant was required to monitor flow in 10 stations using Flo-Dar flow measurement equipment and data loggers for the calibration of the hydraulic model. However ,the MWH Team has deemed it more useful to have 12 monitored stations instead of the proposed 10. Further, owing to tight schedule of works, 4 flow meters were provided instead of the required 2, in order to accelerate measurements. The flow monitoring data from these 12 stations will be used to calibrate the hydraulic model during the hydraulic analysis stage of works.

7.2 Flow Monitoring Location Selection and Preparation

The locations of the measurement stations were determined in agreement with WAJ and the local operators in Zarqa. The two main criteria upon which the decisions relied were the monitoring of critical flow sections and problematic sections of pipes. The locations of the 12 flow monitoring stations are shown in Figure 7.1.

- MH-2: The location of this monitoring station is south-east of WZPS on 400mm diameter sewer that serves Hai Ma;asoum.
- MH-3: The location of this monitoring station is south of WZPS on 240mm diameter sewer that serves Hai al-Basateen.
- MH-4: The location of this monitoring station is at Msheirfah-Russeifa on 800mm diameter sewer that serves Hutteen Camp and surrounding areas, in addition to part of Marka-Amman.
- MH-5: The location of this monitoring station is near Zarqa-Russeifa main road on 800mm diameter sewer that serves Russeifa and parts of Amman that drain through Zarqa wastewater system.
- MH-6: The location of this monitoring station is at Amman-Zarqa Highway on 700mm diameter sewer that serves parts of Marka and Nasr in Amman.
- MH-7: The location of this monitoring station is between Amman and Russeifa on 800mm diameter sewer that serves parts in Tareq and Basman in Amman.
- MH-8: The location of this monitoring station is between Amman and Russeifa on 700mm diameter sewer that serves parts in Shafa Badran and Jubaiha in Amman.
- MH-9: The location of this monitoring station is near EZPS on 300mm diameter sewer that serves Hashemiyah.
- MH-10: The location of this monitoring station is at EZPS on 800mm diameter sewer that serves east parts of Zarqa.
- MH-11: The location of this monitoring station is at Hashemiyah on 500mm diameter sewer that serves Zarqa Free Zone and Hashemiyah University.
- MH-12: The location of this monitoring station is at main Jaish Street in Zarqa on 700mm diameter sewer that serves central commercial part of Zarqa city.

• WZPS: The location of this monitoring station is at WZPS that serves Russeifa, west parts of Zarqa, in addition to north-west parts of Amman that drain within Zarqa wastewater system.

WAJ operators were instrumental in the fulfilment of this task, as they provided assistance in cleaning the manholes that contained large amounts of sediments using water Jet Cleaning equipment. This procedure was necessary to ensure the accurate measurement of flow, since it depended on the shape of the pipe as well as the free discharge of flow.

Some of the initially assigned manholes were flooded, and as such it was not possible to monitor flows passing through them. In these situations, other representative manholes were selected to carry out the flow measurement.

7.3 Flow Monitoring

Flows at each of the selected stations were measured continuously over a period of 7 days (at 5-minute intervals), ensuring that the water supply period in areas where water distribution is rationed (such that water from the municipality is only available for a day or two each week) is covered. Data loggers were checked regularly during the monitoring period to ensure correct functioning and were moved if problems were encountered.

Average daily flows and diurnal peak and minimum flows were estimated using the continuously monitored flows to enable the MWH Team to estimate the actual daily peak and minimum flow factors. Additionally, measurements of flows during rainy periods were conducted to monitor the amount of inflows into the sewer networks.

7.4 Flow Monitoring Data

The measurement data was received for each monitoring station once the monitoring was completed. The received data shows the manhole reference number, pipe ID, location and flow data at 5 minute intervals for the full seven monitoring days. The flow data obtained includes velocity, water level, battery voltage, and flow.

A summary of the daily flow averages over the one-week monitoring period at each of the monitored manhole is shown in Table 7.1. All manholes were monitored for 7 days, but flow data for MH-3 was recorded for three days only due to flow monitor fault. More details about flow monitoring data are shown in Appendix 7.

| Manhole ID | Min Daily Flow (m ³ /hr) | Max Daily Flow (m ³ /hr) | Avg. Daily Flow (m³/hr) | Avg total daily flow (m³/day) |
|------------|--|--|----------------------------|-------------------------------------|
| MH-2 | 48.02 | 413.64 | 161.58 | 3,877.98 |
| MH-3 | 22.31 | 82.62 | 45.48 | 1,091.56 |
| MH-4 | 42.79 | 655.17 | 217.83 | 5,227.90 |
| MH-5 | 237.99 | 5,583.89 | 1,926.23 | 46,229.50 |
| MH-6 | 26.65 | 534.99 | 191.66 | 4,599.76 |

Table 7.1 Summary of Daily Flow Averages Over 1 Week Monitoring Period

| Manhole ID | Min Daily Flow | Max Daily Flow | Avg. Daily Flow | Avg total daily flow |
|---------------|----------------|----------------|-----------------|-------------------------|
| | (m³/hr) | (m³/hr) | (m³/hr) | (m³/day) |
| MH-7 | 0.00 | 633.75 | 89.41 | 2,145.78 |
| MH-8 | 143.92 | 493.35 | 238.37 | 5,720.81 |
| MH-9 | 11.45 | 154.53 | 58.31 | 1,399.34 |
| MH-10 | 188.42 | 980.49 | 505.98 | 12,143.49 |
| MH-11 | 33.89 | 305.01 | 119.49 | 2,867.72 |
| MH-12 | 61.73 | 347.26 | 164.70 | 3,952.88 |
| Inlet to WZPS | 891.77 | 3,824.14 | 2,445.55 | 58,693.20 |

Flow monitoring data analysis will be presented in the Hydraulic Analysis Report.

8. WASTEWATER MANAGEMENT STRATEGY

8.1 Introduction

To meet the needs of the Zarqa wastewater system over the proposed project area through the year 2035, improvements to the existing systems will be required. In this section, alternatives to improve and extend these utility systems are identified to be subjected to later evaluation. The resulting information will be used to select a recommended long-term plan for the expansion and reinforcement of the wastewater systems over the planning horizon.

8.2 <u>Main Wastewater Collection Zones</u>

Based on an investigation of the existing drainage pattern, the topography, the existing wastewater facilities and planned growth of the service area over the planning period, the study area is divided into five main wastewater collection zones each draining into an existing or a proposed pumping station as illustrated in Figure 8.1.The five zones are:

- West Zarqa Pumping Station Zone: This zone includes the areas that drain to the existing WZPS. The main service areas of this zone are the old developed parts of west Zarqa, new extension areas of Zarqa (such as Hai Umm Bayadhah, Hai al-Duwaik, Hai al-Falah and parts of Hai al-Madinah al-Munawwarah), Russeifa and the northeast areas of Amman (parts of Marka, Tareq, parts of Shafa Badran, parts of Jubaiha and parts of Nasser) that currently drain to this pumping station;
- 2. East Zarqa Pumping Station Zone: This zone includes the areas that drain towards the existing EZPS. The main areas of this zone are the currently served areas of east Zarqa and al-Hashemiyah and new extension areas of Hai al-Batrawi in Zarqa in addition to the new development area of King Abdullah Bin Abdul Aziz City;
- 3. Al-Sukhneh Pumping Station Zone: This zone includes the areas that drain towards the confluence of Zarqa River and Wadi Dhuleil. A proposed pumping station at the confluence of the two wadis would be able to serve the town of Sukhneh, new developed neighbourhoods west of Zarqa (such as Hai al-Ameera Haya, Hai al-Hashemi, Hai al-Bustan, Hai Shomar, Hai al-Jabr, Hai Nassar, Hai al-Ahmad, Hai Makka al-Mukarramah and parts of Hai al-Madinah al-Munawwara). It also includes communities along Wadi Zarqa and upstream of Sukhneh such as Abu Zeighan, Salheyah, Ghareisa and Umm Suleih;
- 4. Wadi Zarqa Zone: This zone includes the areas in Birein and al-Hashemiyah districts that drain downstream of the proposed al-Sukhneh Pumping Station. This zone includes mainly the staggered communities located in the northwestern part of Zarqa Governorate, such as Birein, Umm Rummaneh, Maqam Eisa, al-Khillah, Sarout, al-Alouk and Dogara.
- 5. Wadi Dhuleil Pumping Station Zone: This zone includes the eastern communities that drain into Wadi Dhuleil. The main communities that could be served in this zone by a proposed pumping station near the As Samra WwTP include Dhuleil, Khirbet al-Samra, Hallabat in addition to the town of khalediyah in the Mafraq governorate.

8.3 <u>Extension Areas</u>

The ToR asked that all communities within Zarqa Governorate be included in the study for extension of wastewater collection services.

Accordingly, and based on our findings regarding the extent of the existing wastewater network, a layout of the proposed wastewater network extensions was prepared that covers the unserved areas within the main Zarqa zones described above, as shown on Figure 8.2. The proposed networks were first delineated on the most updated topographical maps (scale 1:25,000) and then verified on site.

The extension service areas can be classified into two main categories:

8.3.1 Extension Areas that Drain into Existing System

This category includes all the neighbourhoods in Zarqa, Russeifa and al-Hashemiyah municipalities that drain into the existing systems. The main service extension areas within this category are:

- a. Hai Batrawi;
- b. Hai al-Madinah al-Munawwarah (partially);
- c. Hai Umm Bayadhah;
- d. Hai al-Duwaik;
- e. Hai al-Falah;
- f. Hai al-Rasheed al-Shamali;
- g. Hai al-Tatweer al-Hadari;
- h. Hai al-Jraiba;
- i. Abu Sayyah area;
- j. King Abdullah Bin Abdul Aziz City;
- k. Al-Majd City; and
- I. Networks to fill gaps (scattered in various areas).

8.3.2 Extension Areas that Drain into New Pumping Stations / WwTP

This category includes all the communities in Project Study area that will need new pumping stations to connect to the existing system or that drain into new treatment facilities. The communities of this category are further classified by areas that drain into a pumping station as follows:

- 1) Central communities that drain into the proposed Sukhneh pumping station. These include:
- a. Hai al-Bustan;
- b. Hai Shomar;
- c. Hai al-Hashemi;
- d. Hai al-Jneineh;
- e. Hai al-Ameera Haya;
- f. Hai Nassar;
- g. Hai al-Jabr;
- h. Hai al-Ahmad;
- i. Hai Makka al-Mukarramah;

- j. Al-Sukhneh town;
- k. Salheyah;
- I. Abu al-Zeighan;
- m. Hai al-Madinah al-Munawwarah (partially);

The Sukhneh pumping station will only be required in the event that all treatment is carried out at As Samra WWTP. In this even the pumping station would deliver either to WZPS or EZPS.

- 2) West communities that could be served either by gravity to the proposed Wadi Zarqa Treatment Plant, or by sewage force main from a proposed Wadi Zarqa pumping station back to the proposed Sukhneh Pumping Station. These communities include:
 - Maqam Eisa;
 - Umm Rummaneh;
 - Birein;
 - al-Khillah;
 - al-Alouk;
 - Sarout;
 - Ghareisa;
 - Umm Suleih; and
 - Dogara.

Another pumping station will be required to deliver the flows from the small community of al-Alouk to the Wadi Zarqa pumping station or to Wadi Zarqa treatment plant.

- 3) East communities that could be served by a sewer trunk line along Wadi Dhuleil and force main from a proposed pumping station north of As Samra WWTP up to the as-Samra Wastewater Treatment Plant. The communities are:
 - Dhuleil; and
 - Khirbet al-Samra.

8.4 <u>Main Wastewater Options</u>

Based on an investigation of the existing drainage pattern, the topography and planned growth of the service area over the planning period, the following alternative wastewater collection and pumping scenarios have been identified:

- Option 1 Treatment at New Wadi Zarqa WwTP
- Option 2 Treatment at As Samra WwTP Conveyance of Sukhneh & Wadi Zarqa
 Zones to WZPS
- Option 3 Treatment at As Samra WwTP Conveyance of Sukhneh & Wadi Zarqa Zones to EZPS
- **Option 4** Treatment at As Samra WwTP, Local Treatment for Birein Communities, Conveyance of Sukhneh Zone to EZPS

- Option 4a Treatment at As Samra WwTP, Local Treatment for Birein Communities, Conveyance of Sukhneh Zone to EZPS, Colection of Hai Ameera Haya at Sukhneh PS
- Option 5 Treatment at As Samra WWTP, Local Treatment for Birein Communities, New WZPS in Sukhneh & New ZPS

These options are illustrated in Figure 8.3 through Figure 8.8

Several other secondary options such as using more than one pumping station to subdivide the identified main collection zone will be evaluated later under these four main options.

APPENDIX 1 LIST OF COLLECTED DATA

| Туре | No | Name/Title |
|-----------|----|---|
| | 1 | WAJ Network Operation Report |
| | 2 | GTD WW Prices Analysis |
| | 3 | Amman-Zarqa Wastewater Master Plan Update, Final Report, 2006 (by MWH) |
| | 4 | Construction of WW Collection and Treatment Plant for Five Municipalities in Jerash area and Pumping Station and Force Main in Sukhna Area, Package 1 Tender Documents (by Engicon) |
| | 5 | Wastewater Collection, Treatment and Effluent Reuse for Jerash and Sukhna Areas, Package 2 Tender Documents (Sukhna Collection Network) |
| | 6 | Feasibility Study, Detailed Design and Preparation of Tender Documents for Wastewater Network Mains and Sub-mains and House Connections in Zarqa Governorate, Variation Order No. 1, Final Report (Tender M/14/2003/Special works, prepared by ACE) |
| | 7 | Zarqa River Problem Analysis Report by OPTIMA |
| | 8 | Spacial Distribution and Environmental Implications of Lead and Zinc in Urban Soils and Street Dusts Samples in al-Hashimeyeh Municipality. |
| Documents | 9 | Hydrological Modelling of Ungauged Wadis and Arid Environments Using GIS: a Case Study of Wadi Madoneh in Jordan |
| | 10 | GIS-based Evaluation of the Groundwater Vulnerability in the Russeifa Area, Jordan. |
| | 11 | National Water Master Plan, Amman, 2004. |
| | 12 | Conceptual Design Report for the Construction of a Closed Wastewater Canal of Wadi Zarqa, by CEC, 2009. |
| | 13 | The Wastewater Master Plan, Feasibility Study and Preliminary Engineering Design for the Rehabilitation, Expansion and Development of the Wastewater Systems of the Municipalities and Communities within the Watershed of the Amman-Zarqa River Basin, by Harza, 1997. |
| | 14 | Zarqa Billing Data |
| | 15 | Country Concept Paper, by MCA-Jordan, 2008 |
| | 16 | The National Water Master Plan, by the Ministry of Water and Irrigation, the Hashemite Kingdom of Jordan and German Technical Cooperation (GTZ), 2005. |

Table 1 Data Collected by MWH Team to Date

| 17 | The Feasibility Study and Design for the Wastewater Collection, Treatment and Effluent Reuse for the West Jerash and Sukhnah Area, by C. Lotte & Associati and Engicon, 2007. |
|----|---|
| 18 | WZPS year 2009 flow and operation data |
| 19 | EZPS year 2009 flow data |
| 20 | Zarqa Governorate Water Billing Data (years 2006 – 2009) |
| 21 | Operation Issues and Problems for Networks and Facilities |
| 22 | Biological Baseline Assessment for the JOSCO Oil Shale Concession Area. This report was prepared in 2009 for a number of governorates within the kingdom, including the Zarqa Governorate. |
| 23 | Social and Health Impact Assessment (ESHIA), Social Impact Assessment (SIA). This report was issued in 2009 covering a number of governorates within the kingdom including the Zarqa Governorate. |
| 24 | Archaeological & Cultural Heritage Study of Exploration and Drilling in Jordan. This report was issued in 2009, covering a number of governorates within the kingdom including the Zarqa Governorate. |
| 25 | Detailed climate data (monthly averages of the past 5 years: 2004 – 2008) concerning the project area has been obtained from the Jordanian Department of Meteorology. Data was obtained from a total of two meteorological stations falling within the Zarqa Governorate. |
| 26 | Population and employment data. |
| 27 | Construction of WW Collection Networks for Mazar Area, Two Force Mains and Two Pumping Stations, February 2009, Cost Data. |
| 28 | Construction of Sewerage Pumping Station, Force Main and Wastewater Collection Networks for Mu'ta Area, Cost Data. |
| 29 | Construction of Wastewater Collection Networks for Adnaniyyeh, Merwed and Median Areas, Two force mains and two pumping stations, February 2009, Cost Data. |
| 30 | GTD Yearly Report, 2008 |
| 31 | The Integrated Environmental Management of the Zarqa River: A Proposal for the Restoration of the Zarqa River. |
| 32 | Zarqa River Basin Wastewater and Solid Waste Treatment Project. |

| | 33 | Environment Profile of Jordan, 2006 |
|----------|----|---|
| | 34 | Demographic and Socioeconomic Information from DoS. |
| | 1 | Schneller Camp, Project No SH-S2 by Habib & Associates (1982) – plans & profiles |
| | 2 | Jabal El Shamali, Project No 129/91 by ACE (1991) - plans |
| | 3 | Schneller Camp, Project No 72/85 SHN-1 by Habib & Associates (1985) - profiles |
| | 4 | Schneller Camp 2, Project No 85/99 by Habib & Associates (1987)- plans and profiles |
| | 5 | Jabal El Shamali (ZQ-III), Project No 130/91 by ACE (1993) - plans & profiles |
| | 6 | Jabal El Shamali (IIA), Project No 129/91 by ACE - profiles |
| | 7 | Al Hashimiya, Project No ZQ 73/89 by Jardaneh (1990) - plans |
| | 8 | Jabal El Shamali (ZQ-III), Project No 130/91 by ACE (1993) - plans |
| | 9 | Jabal Al-Bayan (ZQ-III), Project No ZQ-III, by Habib & Associates (1988) - plans |
| | 10 | Zarqa-Rusiefa, Project No 6A, by Jouzy & Partners (1986) - plans |
| Drawings | 11 | Zarqa-Rusiefa, Project No 7C, by Jouzy & Partners (1986) – plans & profiles |
| | 12 | Zarqa-Rusiefa, Project No 7A, by Jouzy & Partners (1987) – plans & profiles |
| | 13 | Zarqa-Rusiefa, Project No 7B, by Jouzy & Partners (1985) – plans |
| | 14 | Zarqa-Rusiefa, Project No ZQII by Habib & Associates - plans |
| | 15 | Zarqa-Rusiefa, Project No 3A by Jouzy & Partners (1984) – plans |
| | 16 | Al-Hashimiya Housing & North Hashimiya, Project No 60/90, by Jardaneh (1990) – plans & profiles |
| | 17 | Zarqa-Rusiefa, Project No 6B, by Jouzy & Partners (1988) – plans & profiles |
| | 18 | Awajan, Project ZQ-II, by Habib & Associates - profiles |
| | 19 | Al Batrawi I, Project 126/91, by Arabtech Jardaneh (1991) – plans & profiles |
| | 20 | North Rusiefa, Project S.C4-1, by Arabtech Jardaneh (1994) - |

| | | plans & profiles | | | | | |
|----------|----|---|--|--|--|--|--|
| | 21 | Zarqa Free Zone, Project 131/94, by Arabtech Jardaneh (1995) - plans & profiles | | | | | |
| | 22 | Zarqa-Rusiefa, Project 10/205, by Jouzy & Partners (1987) - plans | | | | | |
| | 23 | Zarqa - Rusiefa, Project No 10, by Jouzy & Partners (1987) - plans | | | | | |
| | 24 | Zarqa - Rusiefa, Project No 3B, by Jouzy & Partners (1987) - profiles | | | | | |
| | 25 | Jabal Faisal, Project No 131/91, by ACE (1994) – plans & profiles | | | | | |
| | 26 | Project No 132/94, by Arabtech Jardaneh (1994) - profiles | | | | | |
| | 27 | Zarqa-Rusiefa, Project No 3A by ACE (1990) - plans | | | | | |
| | 28 | Wadi Al-Hajar, Project ZQ-1, by Habib and Associates (1988) – plans & profiles | | | | | |
| | 29 | Al Hashimiya LS, Project 4G/88/694/4 (1988) - plans | | | | | |
| Drawings | 30 | Al Hashimiya PS, Project 131/96 (1987) - plans | | | | | |
| | 31 | Al Batrawi ZQ VI, Project 127/9, by Arabtech Jardaneh (1992) - plans & profiles | | | | | |
| | 32 | Al Zahrawi, Project No 74/89, by Jardaneh (1990) – plans & profiles | | | | | |
| | 33 | Al Batrawi, Project No 128/91, by Arabtech Jardaneh (1991) - plans & profiles | | | | | |
| | 34 | Birin Rehabilitation Center, Project No 68/92, by Arabtic Jardaneh (1992) - plans | | | | | |
| | 35 | Zarqa Rusiefa, Project No 4-B, by ACE – plans & profiles | | | | | |
| | 36 | Zarqa-Rusiefa (Al Jabal Al-Abyad), Project No ZQ-III, by Habib & Associates - plans | | | | | |
| | 37 | Zarqa-Rusiefa, Project 4A, by ACE - plans | | | | | |
| | 38 | Zarqa-Rusiefa (Wadi Al Hajar), Project No ZQ-I, by Habib & Associates - plans | | | | | |
| | 29 | Zarqa-Rusiefa, Project ZQ-I, by Habib & Associates - plans | | | | | |
| | 30 | Zarqa-Rusiefa, Project S-C4-5 by Arabtech Jardaneh - plans | | | | | |
| | 31 | Zarqa-Rusiefa (Al Hashmiyeh Housing), Project ZQ-IX, by Arabtech Jardaneh - plans | | | | | |

| | 32 | Zarqa-Rusiefa (Al Zawahri), Project ZQ-IV, by Jardaneh – plans | | | | | |
|----------|----|--|--|--|--|--|--|
| | 33 | Zarqa-Rusiefa (North Ruseifa), Project 7B - plans | | | | | |
| | 34 | Al Batrawi II, Project s-c5-12, by Arabtech Jardaneh - plans | | | | | |
| | 35 | Al Batrawi III by Arabtech Jardaneh - plans | | | | | |
| | 36 | Zarqa-Rusiefa, Project 4B, by ACE - plans | | | | | |
| | 37 | Al Batrawi Housing, Project 4/90, by Jardaneh (1990) - plans | | | | | |
| | 38 | Zarqa-Rusiefa, Project 5, by Jouzy & Partners (1987) – plans & profiles | | | | | |
| | 39 | Zarqa-Rusiefa, Project 7B, by Jouzy & Partners (1987) – plans | | | | | |
| | 40 | Al-Batrawi Housing, Project 4/sh/90, by Jardaneh (1990) – plans & profiles | | | | | |
| | 41 | Yajuz / Jafar Tayyar Wastewater Collection Networks, Project JF, by Engicon (2004) - plans | | | | | |
| Drawings | 42 | Sukhnah Collection Network Package II Drawings | | | | | |
| | 43 | Jerash Package 1, Aprile 05: Part I (WWTP Final Drawings); Part II (PS + Force Mains + Final Drawings) | | | | | |
| | 44 | Zarqa Sewer Network | | | | | |
| | 45 | Zarqa Water Network | | | | | |
| | 46 | King Abdullah City Drawings | | | | | |
| | 47 | Topographic Maps of scale 25,000 | | | | | |
| | 48 | Land and Survey Maps | | | | | |
| | 49 | Planning (land use) maps for the municipalities of Zarqa, Russeifa, al-Hashemiyah and Sukhneh | | | | | |
| | 50 | Sukhnea Collection System and Pumping Station by Engicon, 2006 (proposed design drawings) | | | | | |
| | 51 | Miscellaneous Wastewater Networks in Zarqa (Hshemiyah, Russeifeh, Massoum, etc) by Engicon – Proposed Design Drawings. | | | | | |
| | 52 | Conceptual Design of Closed Wastewater Canal of Wadi Zarqa by CEC, 2009 – Proposed Design Drawings. | | | | | |
| GIS Data | 1 | Jerash GIS Data | | | | | |
| | 2 | Zarqa GIS Data, Basemap and Sewer Merge. | | | | | |

APPENDIX 2 WZPS YEAR 2009 OPERATIONAL DATA

Table 1West Zarqa Pumping Station Hourly Pumping Log, Summer 2009 (Flows
are given in m³/hour)

| Time | 01/06/2009 | 02/06/2009 | 03/06/2009 | 04/06/2009 | 05/06/2009 | 06/06/2009 | 07/06/2009 |
|---------|------------|------------|------------|------------|------------|------------|------------|
| (Hour) | Monday | Tuesday | Wednesday | Thursday | Friday | Saturday | Sunday |
| 0 | 3008 | 2540 | 2715 | 2918 | 2882 | 2690 | 2193 |
| 1 | 3070 | 2246 | 1934 | 2708 | 2774 | 1767 | 2053 |
| 2 | 2444 | 1069 | 1561 | 916 | 1687 | 1797 | 2000 |
| 3 | 1339 | 1795 | 1574 | 1201 | 901 | 2169 | 1206 |
| 4 | 1299 | 1020 | 1633 | 1013 | 1270 | 1277 | 1161 |
| 5 | 1081 | 0 | 1040 | 1220 | 1155 | 1250 | 967 |
| 6 | 481 | 503 | 1131 | 1226 | 1213 | 1125 | 963 |
| 7 | 1217 | 1171 | 1034 | 1139 | 1199 | 1020 | 1318 |
| 8 | 1221 | 1167 | 1500 | 1101 | 1162 | 1001 | 1312 |
| 9 | 1596 | 1619 | 1504 | 2125 | 898 | 2298 | 1108 |
| 10 | 2484 | 2400 | 1508 | 2102 | 1984 | 2210 | 2430 |
| 11 | 2078 | 2070 | 2504 | 2041 | 1839 | 2044 | 3324 |
| 12 | 2737 | 2466 | 2426 | 2990 | 2855 | 2314 | 2044 |
| 13 | 2400 | 2908 | 2058 | 2933 | 3281 | 2101 | 3128 |
| 14 | 2983 | 2441 | 2966 | 2827 | 3016 | 2420 | 2284 |
| 15 | 2695 | 2899 | 2946 | 2777 | 2812 | 3222 | 3080 |
| 16 | 2732 | 2959 | 2933 | 2715 | 2876 | 2952 | 2922 |
| 17 | 2198 | 2893 | 2819 | 2700 | 2865 | 2984 | 2875 |
| 18 | 2905 | 2843 | 2824 | 3041 | 3111 | 3069 | 2792 |
| 19 | 2796 | 2797 | 2843 | 3210 | 3066 | 3028 | 1976 |
| 20 | 2777 | 2735 | 2777 | 3011 | 2999 | 2998 | 3004 |
| 21 | 0 | 2741 | 2765 | 3189 | 2821 | 2969 | 2265 |
| 22 | 0 | 2650 | 2682 | 2881 | 2983 | 2870 | 2097 |
| 23 | 3171 | 2559 | 2636 | 2793 | 2778 | 2998 | 2225 |
| Average | 2030 | 2104 | 2180 | 2282 | 2268 | 2274 | 2114 |

| Table 2 | West Zarqa | Pumping | Station | Hourly | Pumping | Log, | Winter | 2009 | (Flows |
|---------|--------------|----------|---------|--------|---------|------|--------|------|--------|
| | are given in | m³/hour) | | | | | | | |

| Time | 07/12/2009 | 08/12/2009 | 09/12/2009 | 10/12/2009 | 11/12/2009 | 12/12/2009 | 13/12/2009 |
|---------|------------|------------|------------|------------|------------|------------|------------|
| (Hour) | Monday | Tuesday | Wednesday | Thursday | Friday | Saturday | Sunday |
| 0 | 2466 | 1075 | 1955 | 2002 | 2991 | 2013 | 2031 |
| 1 | 3064 | 1860 | 2132 | 1967 | 2866 | 2071 | 1959 |
| 2 | 2665 | 875 | 1135 | 1104 | 2789 | 2005 | 2126 |
| 3 | 2656 | 1070 | 1062 | 2091 | 1023 | 2029 | 1132 |
| 4 | 947 | 1075 | 1090 | 1119 | 984 | 2061 | 2110 |
| 5 | 1913 | 1080 | 1005 | 1079 | 1002 | 1028 | 1101 |
| 6 | 2001 | 1159 | 1011 | 1101 | 977 | 1004 | 1062 |
| 7 | 1102 | 999 | 1156 | 1117 | 1090 | 2102 | 1968 |
| 8 | 1937 | 1829 | 1950 | 2203 | 1156 | 1135 | 2115 |
| 9 | 2010 | 1809 | 1985 | 2084 | 2165 | 2177 | 2055 |
| 10 | 1005 | 2004 | 2074 | 2000 | 24.02 | 1000 | 2405 |
| 10 | 1995 | 2064 | 2074 | 2060 | 2123 | 1003 | 2105 |
| 11 | 2033 | 2070 | 0 | 2065 | 1975 | 2130 | 3078 |
| 12 | 2030 | 2020 | 2155 | 2053 | 3036 | 3101 | 2130 |
| 13 | 2902 | 2722 | 2948 | 2211 | 3052 | 3035 | 3080 |
| 14 | 2850 | 2650 | 3017 | 2954 | 2892 | 2955 | 3750 |
| 15 | 2900 | 2636 | 2950 | 3006 | 2806 | 2860 | 3015 |
| 16 | 2890 | 2773 | 2915 | 2975 | 2927 | 2811 | 2974 |
| 17 | 2950 | 2716 | 2911 | 2920 | 2923 | 2933 | 2979 |
| 18 | 3060 | 2663 | 2879 | 2911 | 2910 | 2910 | 2855 |
| 19 | 2895 | 2613 | 2899 | 3037 | 2943 | 2983 | 2872 |
| 20 | 2820 | 2784 | 2017 | 3001 | 2889 | 2922 | 2847 |
| 21 | 2678 | 2772 | 1941 | 2898 | 2855 | 2957 | 1994 |
| 22 | 2438 | 2009 | 2005 | 1959 | 2931 | 3041 | 2978 |
| 23 | 2498 | 1980 | 2021 | 1991 | 2842 | 2919 | 2041 |
| Average | 2404 | 1971 | 1967 | 2163 | 2339 | 2341 | 2348 |

| Part I | | | | | | | | |
|------------|--------|------------|--------|------------|--------|------------|--------|--|
| Date | m³/day | Date | m³/day | Date | m³/day | Date | m³/day | |
| 01/01/2009 | 46870 | 17/02/2009 | 45745 | 05/04/2009 | 52726 | 22/05/2009 | 55404 | |
| 02/01/2009 | 45494 | 18/02/2009 | 47952 | 06/04/2009 | 49028 | 23/05/2009 | 56490 | |
| 03/01/2009 | 45222 | 19/02/2009 | 50566 | 07/04/2009 | 52103 | 24/05/2009 | 51971 | |
| 04/01/2009 | 42173 | 20/02/2009 | 53594 | 08/04/2009 | 55711 | 25/05/2009 | 50224 | |
| 05/01/2009 | 43705 | 21/02/2009 | 47271 | 09/04/2009 | 56394 | 26/05/2009 | 52481 | |
| 06/01/2009 | 46443 | 22/02/2009 | 46073 | 10/04/2009 | 59000 | 27/05/2009 | 51026 | |
| 07/01/2009 | 47806 | 23/02/2009 | 46619 | 11/04/2009 | 59642 | 28/05/2009 | 53398 | |
| 08/01/2009 | 50188 | 24/02/2009 | 45399 | 12/04/2009 | 55952 | 29/05/2009 | 54030 | |
| 09/01/2009 | 52020 | 25/02/2009 | 44659 | 13/04/2009 | 53685 | 30/05/2009 | 56465 | |
| 10/01/2009 | 50317 | 26/02/2009 | 48121 | 14/04/2009 | 55023 | 31/05/2009 | 52531 | |
| 11/01/2009 | 48583 | 27/02/2009 | 46339 | 15/04/2009 | 54306 | 01/06/2009 | 49990 | |
| 12/01/2009 | 47813 | 28/02/2009 | 49061 | 16/04/2009 | 54499 | 02/06/2009 | 52440 | |
| 13/01/2009 | 47159 | 01/03/2009 | 16721 | 17/04/2009 | 56354 | 03/06/2009 | 51820 | |
| 14/01/2009 | 46477 | 02/03/2009 | | 18/04/2009 | 59487 | 04/06/2009 | 54807 | |
| 15/01/2009 | 50256 | 03/03/2009 | 35955 | 19/04/2009 | 56394 | 05/06/2009 | 54242 | |
| 16/01/2009 | 49519 | 04/03/2009 | 51248 | 20/04/2009 | 59200 | 06/06/2009 | 53460 | |
| 17/01/2009 | 50109 | 05/03/2009 | 56290 | 21/04/2009 | 59642 | 07/06/2009 | 50549 | |
| 18/01/2009 | 46743 | 06/03/2009 | 54881 | 22/04/2009 | 55902 | 08/06/2009 | 50212 | |
| 19/01/2009 | 44429 | 07/03/2009 | 54210 | 23/04/2009 | 53685 | 09/06/2009 | 51307 | |
| 20/01/2009 | 45947 | 08/03/2009 | 51536 | 24/04/2009 | 55023 | 10/06/2009 | 51381 | |
| 21/01/2009 | 46113 | 09/03/2009 | 45885 | 25/04/2009 | 54306 | 11/06/2009 | 52122 | |
| 22/01/2009 | 50338 | 10/03/2009 | 48768 | 26/04/2009 | 52726 | 12/06/2009 | 55449 | |
| 23/01/2009 | 46551 | 11/03/2009 | 52416 | 27/04/2009 | 50088 | 13/06/2009 | 52557 | |
| 24/01/2009 | 47225 | 12/03/2009 | 55741 | 28/04/2009 | 52217 | 14/06/2009 | 54803 | |
| 25/01/2009 | 46477 | 13/03/2009 | 54364 | 29/04/2009 | 56711 | 15/06/2009 | 52492 | |
| 26/01/2009 | 45285 | 14/03/2009 | 51365 | 30/04/2009 | 54108 | 16/06/2009 | 52372 | |
| 27/01/2009 | 45151 | 15/03/2009 | 49933 | 01/05/2009 | 56003 | 17/06/2009 | 52570 | |
| 28/01/2009 | 46458 | 16/03/2009 | 52583 | 02/05/2009 | 56407 | 18/06/2009 | 57580 | |
| 29/01/2009 | 48338 | 17/03/2009 | 53062 | 03/05/2009 | 58630 | 19/06/2009 | 57060 | |
| 30/01/2009 | 47698 | 18/03/2009 | 53260 | 04/05/2009 | 52621 | 20/06/2009 | 56255 | |
| 31/01/2009 | 57704 | 19/03/2009 | 55160 | 05/05/2009 | 56349 | 21/06/2009 | 51987 | |
| 01/02/2009 | 40940 | 20/03/2009 | 54255 | 06/05/2009 | 51324 | 22/06/2009 | 52655 | |
| 02/02/2009 | 43302 | 21/03/2009 | 55395 | 07/05/2009 | 54917 | 23/06/2009 | 54327 | |
| 03/02/2009 | 45395 | 22/03/2009 | 50660 | 08/05/2009 | 58698 | 24/06/2009 | 55451 | |
| 04/02/2009 | 48348 | 23/03/2009 | 47696 | 09/05/2009 | 56114 | 25/06/2009 | 58984 | |
| 05/02/2009 | 48285 | 24/03/2009 | 54286 | 10/05/2009 | 52117 | 26/06/2009 | 57736 | |
| 06/02/2009 | 49802 | 25/03/2009 | 49238 | 11/05/2009 | 50741 | 27/06/2009 | 57396 | |
| 07/02/2009 | 49722 | 26/03/2009 | 55881 | 12/05/2009 | 53861 | 28/06/2009 | 56181 | |
| 08/02/2009 | 46314 | 27/03/2009 | 57498 | 13/05/2009 | 54283 | 29/06/2009 | 56896 | |
| 09/02/2009 | 46201 | 28/03/2009 | 56566 | 14/05/2009 | 56748 | 30/06/2009 | 56098 | |
| 10/02/2009 | 52156 | 29/03/2009 | 54364 | 15/05/2009 | 57174 | 01/07/2009 | 58184 | |

Table 3 West Zarqa Pumping Station Daily Log for the Year 2009

| 11/02/2009 | 46286 | 30/03/2009 | 51365 | 16/05/2009 | 56902 | 02/07/2009 | 59640 |
|------------|--------|------------|---------------------|------------|--------|------------|--------|
| 12/02/2009 | 50901 | 31/03/2009 | 49933 | 17/05/2009 | 54905 | 03/07/2009 | 58985 |
| 13/02/2009 | 52834 | 01/04/2009 | 54046 | 18/05/2009 | 56369 | 04/07/2009 | 59246 |
| 14/02/2009 | 50633 | 02/04/2009 | 58500 | 19/05/2009 | 53948 | 05/07/2009 | 57945 |
| 15/02/2009 | 46074 | 03/04/2009 | 55708 | 20/05/2009 | 53366 | 06/07/2009 | 56021 |
| 16/02/2009 | 44451 | 04/04/2009 | 57702 | 21/05/2009 | 54591 | 07/07/2009 | 57143 |
| | | | Pa | art II | | | |
| Date | m³/day | Date | m ³ /day | Date | m³/day | Date | m³/day |
| 08/07/2009 | 55920 | 24/08/2009 | 54099 | 10/10/2009 | 56505 | 26/11/2009 | 59283 |
| 09/07/2009 | 58046 | 25/08/2009 | 52654 | 11/10/2009 | 51269 | 27/11/2009 | 51139 |
| 10/07/2009 | 57665 | 26/08/2009 | 53073 | 12/10/2009 | 50798 | 28/11/2009 | 50756 |
| 11/07/2009 | 57670 | 27/08/2009 | 53961 | 13/10/2009 | 51404 | 29/11/2009 | 46704 |
| 12/07/2009 | 55539 | 28/08/2009 | 55907 | 14/10/2009 | 53057 | 30/11/2009 | 48009 |
| 13/07/2009 | 54086 | 29/08/2009 | 56407 | 15/10/2009 | 57151 | 01/12/2009 | 50432 |
| 14/07/2009 | 56581 | 30/08/2009 | 52193 | 16/10/2009 | 55786 | 02/12/2009 | 49815 |
| 15/07/2009 | 55083 | 31/08/2009 | 50444 | 17/10/2009 | 52201 | 03/12/2009 | 52150 |
| 16/07/2009 | 58199 | 01/09/2009 | 50246 | 18/10/2009 | 51471 | 04/12/2009 | 54806 |
| 17/07/2009 | 56651 | 02/09/2009 | 50062 | 19/10/2009 | 48020 | 05/12/2009 | 55988 |
| 18/07/2009 | 57910 | 03/09/2009 | 53999 | 20/10/2009 | 48684 | 06/12/2009 | 48730 |
| 19/07/2009 | 55871 | 04/09/2009 | 56000 | 21/10/2009 | 45852 | 07/12/2009 | 54622 |
| 20/07/2009 | 55061 | 05/09/2009 | 56271 | 22/10/2009 | 51193 | 08/12/2009 | 47386 |
| 21/07/2009 | 54293 | 06/09/2009 | 50216 | 23/10/2009 | 55024 | 09/12/2009 | 48055 |
| 22/07/2009 | 55060 | 07/09/2009 | 49396 | 24/10/2009 | 54506 | 10/12/2009 | 52333 |
| 23/07/2009 | 57734 | 08/09/2009 | 50068 | 25/10/2009 | 49358 | 11/12/2009 | 55197 |
| 24/07/2009 | 57854 | 09/09/2009 | 48380 | 26/10/2009 | 48373 | 12/12/2009 | 55208 |
| 25/07/2009 | 57618 | 10/09/2009 | 52411 | 27/10/2009 | 47953 | 13/12/2009 | 52615 |
| 26/07/2009 | 55655 | 11/09/2009 | 53440 | 28/10/2009 | 49917 | 14/12/2009 | 49508 |
| 27/07/2009 | 54760 | 12/09/2009 | 55386 | 29/10/2009 | 53048 | 15/12/2009 | 51849 |
| 28/07/2009 | 56810 | 13/09/2009 | 47230 | 30/10/2009 | 59372 | 16/12/2009 | 52982 |
| 29/07/2009 | 54906 | 14/09/2009 | 50122 | 31/10/2009 | 56594 | 17/12/2009 | 59999 |
| 30/07/2009 | 57612 | 15/09/2009 | 49708 | 01/11/2009 | 51529 | 18/12/2009 | 53711 |
| 31/07/2009 | 59439 | 16/09/2009 | 52686 | 02/11/2009 | 57326 | 19/12/2009 | 54667 |
| 01/08/2009 | 58296 | 17/09/2009 | 55018 | 03/11/2009 | 60901 | 20/12/2009 | 43719 |
| 02/08/2009 | 54683 | 18/09/2009 | 56385 | 04/11/2009 | 51546 | 21/12/2009 | 54450 |
| 03/08/2009 | 53181 | 19/09/2009 | 60138 | 05/11/2009 | 53135 | 22/12/2009 | 54972 |
| 04/08/2009 | 53349 | 20/09/2009 | 50503 | 06/11/2009 | 52946 | 23/12/2009 | 55804 |
| 05/08/2009 | 53167 | 21/09/2009 | 44676 | 07/11/2009 | 53919 | 24/12/2009 | 60774 |
| 06/08/2009 | 57406 | 22/09/2009 | 45385 | 08/11/2009 | 54192 | 25/12/2009 | 61135 |
| 07/08/2009 | 56453 | 23/09/2009 | 47942 | 09/11/2009 | 54943 | 26/12/2009 | 61374 |
| 08/08/2009 | 57436 | 24/09/2009 | 49483 | 10/11/2009 | 55898 | 27/12/2009 | 50047 |
| 09/08/2009 | 54935 | 25/09/2009 | 54008 | 11/11/2009 | 53404 | 28/12/2009 | 57370 |
| 10/08/2009 | 53748 | 26/09/2009 | 55870 | 12/11/2009 | 56446 | 29/12/2009 | 45190 |
| 11/08/2009 | 53576 | 27/09/2009 | 50160 | 13/11/2009 | 53960 | 30/12/2009 | 56837 |
| 12/08/2009 | 52875 | 28/09/2009 | 45634 | 14/11/2009 | 58271 | 31/12/2009 | 61311 |
| 13/08/2009 | 57954 | 29/09/2009 | 46279 | 15/11/2009 | 52089 | 01/01/2010 | 60100 |

| 14/08/2009 | 58188 | 30/09/2009 | 48182 | 16/11/2009 | 48519 | - | - |
|------------|-------|------------|-------|------------|-------|---|---|
| 15/08/2009 | 58391 | 01/10/2009 | 51115 | 17/11/2009 | 54452 | - | - |
| 16/08/2009 | 54933 | 02/10/2009 | 55190 | 18/11/2009 | 48482 | - | - |
| 17/08/2009 | 51867 | 03/10/2009 | 55392 | 19/11/2009 | 53685 | - | - |
| 18/08/2009 | 52702 | 04/10/2009 | 46313 | 20/11/2009 | 53959 | - | - |
| 19/08/2009 | 53234 | 05/10/2009 | 44681 | 21/11/2009 | 57238 | - | - |
| 20/08/2009 | 57076 | 06/10/2009 | 46391 | 22/11/2009 | 49509 | - | - |
| 21/08/2009 | 57162 | 07/10/2009 | 48023 | 23/11/2009 | 50944 | - | - |
| 22/08/2009 | 55479 | 08/10/2009 | 54760 | 24/11/2009 | 57227 | - | - |
| 23/08/2009 | 53854 | 09/10/2009 | 55978 | 25/11/2009 | 50620 | - | - |

Average Daily Flow: 52,701 m³/day

Maximum Daily Flow: 61,374 m³/day

Minimum Daily Flow: 16,721 m³/day

APPENDIX 3 EZPS YEAR 2009 OPERATIONAL DATA

Table 1East Zarqa Pumping Station Hourly Pumping Log, Summer 2009 (Flows
are given in m³/hour)

| | 06/06/2009 | 07/06/2009 | 08/06/2009 | 09/06/2009 | 10/06/2009 | 11/06/2009 | 12/06/2009 |
|---------|------------|------------|------------|------------|------------|------------|------------|
| Time | Saturday | Sunday | Monday | Tuesday | Wednesday | Thursday | Friday |
| 0 | 820 | 880 | 820 | 830 | 850 | 810 | 820 |
| 1 | 880 | 820 | 830 | 870 | 810 | 830 | 870 |
| 2 | 870 | 810 | 820 | 870 | 820 | 840 | 860 |
| 3 | 870 | 820 | 820 | 860 | 810 | 830 | 880 |
| 4 | 860 | 830 | 810 | 830 | 810 | 830 | 860 |
| 5 | 870 | 820 | 810 | 870 | 800 | 820 | 860 |
| 6 | 870 | 810 | 830 | 870 | 810 | 830 | 870 |
| 7 | 870 | 820 | 830 | 880 | 820 | 830 | 880 |
| 8 | 880 | 820 | 820 | 870 | 810 | 830 | 880 |
| 9 | 880 | 830 | 820 | 870 | 820 | 830 | 880 |
| 10 | 880 | 820 | 810 | 860 | 810 | 830 | 880 |
| 11 | 880 | 820 | 830 | 870 | 810 | 830 | 860 |
| 12 | 880 | 810 | 820 | 870 | 800 | 830 | 860 |
| 13 | 1250 | 1300 | 1290 | 820 | 830 | 860 | 1280 |
| 14 | 1250 | 1100 | 1300 | 1250 | 840 | 1270 | 1250 |
| 15 | 1280 | 820 | 1290 | 1260 | 830 | 1280 | 1210 |
| 16 | 1260 | 830 | 870 | 1250 | 1280 | 1270 | 1240 |
| 17 | 1280 | 820 | 860 | 1260 | 1290 | 1290 | 1240 |
| 18 | 830 | 810 | 870 | 1250 | 1280 | 1270 | 1230 |
| 19 | 810 | 840 | 830 | 830 | 1270 | 840 | 830 |
| 20 | 820 | 870 | 820 | 810 | 1300 | 820 | 820 |
| 21 | 810 | 860 | 830 | 810 | 860 | 810 | 840 |
| 22 | 820 | 880 | 820 | 820 | 840 | 820 | 810 |
| 23 | 830 | 860 | 830 | 810 | 860 | 820 | 810 |
| Average | 940 | 863 | 887 | 933 | 919 | 922 | 951 |

Table 2East Zarqa Pumping Station Hourly Pumping Log, Winter 2009 (Flows
are given in m³/hour)

| Time | 05/12/2009 | 06/12/2009 | 07/12/2009 | 08/12/2009 | 09/12/2009 | 10/12/2009 | 11/12/2009 |
|----------|------------|------------|------------|------------|------------|------------|------------|
| Time | Saturday | Sunday | Monday | Tuesday | Wednesday | Thursday | Friday |
| 0 | 900 | 860 | 800 | 860 | 800 | 830 | 830 |
| 1 | 830 | 860 | 860 | 790 | 850 | 810 | 800 |
| 2 | 820 | 930 | 850 | 800 | 850 | 810 | 790 |
| 3 | 820 | 920 | 850 | 790 | 840 | 820 | 790 |
| 4 | 810 | 920 | 860 | 790 | 840 | 800 | 800 |
| 5 | 810 | 910 | 860 | 800 | 840 | 820 | 810 |
| 6 | 820 | 910 | 860 | 790 | 840 | 810 | 800 |
| 7 | 820 | 840 | 810 | 860 | 860 | 820 | 800 |
| 8 | 830 | 850 | 800 | 840 | 860 | 830 | 800 |
| 9 | 830 | 860 | 790 | 850 | 850 | 820 | 810 |
| 10 | 830 | 880 | 810 | 840 | 850 | 820 | 820 |
| 11 | 830 | 890 | 800 | 830 | 840 | 820 | 810 |
| 12 | 830 | 900 | 810 | 850 | 850 | 810 | 830 |
| 13 | 1250 | 900 | 840 | 800 | 820 | 800 | 830 |
| 14 | 850 | 910 | 850 | 800 | 830 | 800 | 820 |
| 15 | 1270 | 800 | 860 | 830 | 810 | 790 | 820 |
| 16 | 860 | 790 | 850 | 810 | 820 | 790 | 830 |
| 17 | 860 | 810 | 870 | 790 | 840 | 780 | 850 |
| 18 | 850 | 800 | 860 | 800 | 850 | 790 | 860 |
| 19 | 900 | 850 | 1500 | 840 | 800 | 830 | 840 |
| 20 | 900 | 840 | 1490 | 860 | 800 | 840 | 840 |
| 21 | 890 | 850 | 1460 | 850 | 790 | 830 | 850 |
| 22 | 880 | 860 | 1280 | 860 | 810 | 850 | 830 |
| 23 | 900 | 850 | 790 | 850 | 790 | 850 | 830 |
| Average: | 883 | 866 | 934 | 824 | 830 | 815 | 820 |

| Part I | | | | | | | | | |
|------------|--------|------------|--------|------------|---------------------|------------|--------|--|--|
| Date | m³/day | Date | m³/day | Date | m ³ /day | Date | m³/day | | |
| 01/01/2009 | 14460 | 17/02/2009 | 13240 | 05/04/2009 | 12710 | 22/05/2009 | 14930 | | |
| 02/01/2009 | 14170 | 18/02/2009 | 13320 | 06/04/2009 | 15310 | 23/05/2009 | 15420 | | |
| 03/01/2009 | 14670 | 19/02/2009 | 14220 | 07/04/2009 | 14080 | 24/05/2009 | 15640 | | |
| 04/01/2009 | 13000 | 20/02/2009 | 16290 | 08/04/2009 | 14440 | 25/05/2009 | 14200 | | |
| 05/01/2009 | 13210 | 21/02/2009 | 18770 | 09/04/2009 | 15020 | 26/05/2009 | 15090 | | |
| 06/01/2009 | 13050 | 22/02/2009 | 12970 | 10/04/2009 | 15240 | 27/05/2009 | 14450 | | |
| 07/01/2009 | 13570 | 23/02/2009 | 12760 | 11/04/2009 | 12210 | 28/05/2009 | 15400 | | |
| 08/01/2009 | 13960 | 24/02/2009 | 13760 | 12/04/2009 | 13400 | 29/05/2009 | 15470 | | |
| 09/01/2009 | 14400 | 25/02/2009 | 13340 | 13/04/2009 | 12550 | 30/05/2009 | 15130 | | |
| 10/01/2009 | 15430 | 26/02/2009 | 15170 | 14/04/2009 | 12560 | 31/05/2009 | 14960 | | |
| 11/01/2009 | 13920 | 27/02/2009 | 18960 | 15/04/2009 | 12250 | 01/06/2009 | 14720 | | |
| 12/01/2009 | 13320 | 28/02/2009 | 20560 | 16/04/2009 | 13700 | 02/06/2009 | 13970 | | |
| 13/01/2009 | 13000 | 01/03/2009 | 15510 | 17/04/2009 | 15150 | 03/06/2009 | 14750 | | |
| 14/01/2009 | 13270 | 02/03/2009 | 13140 | 18/04/2009 | 14870 | 04/06/2009 | 16650 | | |
| 15/01/2009 | 13800 | 03/03/2009 | 14000 | 19/04/2009 | 13470 | 05/06/2009 | 16020 | | |
| 16/01/2009 | 14220 | 04/03/2009 | 15120 | 20/04/2009 | 12660 | 06/06/2009 | 16450 | | |
| 17/01/2009 | 14710 | 05/03/2009 | 15170 | 21/04/2009 | 14400 | 07/06/2009 | 15470 | | |
| 18/01/2009 | 12660 | 06/03/2009 | 15340 | 22/04/2009 | 12840 | 08/06/2009 | 15040 | | |
| 19/01/2009 | 12290 | 07/03/2009 | 16790 | 23/04/2009 | 14140 | 09/06/2009 | 15460 | | |
| 20/01/2009 | 12330 | 08/03/2009 | 14750 | 24/04/2009 | 14110 | 10/06/2009 | 15630 | | |
| 21/01/2009 | 12460 | 09/03/2009 | 13420 | 25/04/2009 | 13540 | 11/06/2009 | 16270 | | |
| 22/01/2009 | 13400 | 10/03/2009 | 13680 | 26/04/2009 | 13550 | 12/06/2009 | 16320 | | |
| 23/01/2009 | 13210 | 11/03/2009 | 13240 | 27/04/2009 | 13860 | 13/06/2009 | 15520 | | |
| 24/01/2009 | 13540 | 12/03/2009 | 14390 | 28/04/2009 | 12900 | 14/06/2009 | 15690 | | |
| 25/01/2009 | 12550 | 13/03/2009 | 14420 | 29/04/2009 | 13650 | 15/06/2009 | 15660 | | |
| 26/01/2009 | 13460 | 14/03/2009 | 15140 | 30/04/2009 | 13850 | 16/06/2009 | 15930 | | |
| 27/01/2009 | 13050 | 15/03/2009 | 14390 | 01/05/2009 | 14620 | 17/06/2009 | 15380 | | |
| 28/01/2009 | 13080 | 16/03/2009 | 15490 | 02/05/2009 | 15540 | 18/06/2009 | 16080 | | |
| 29/01/2009 | 13560 | 17/03/2009 | 14130 | 03/05/2009 | 11900 | 19/06/2009 | 16430 | | |
| 30/01/2009 | 14070 | 18/03/2009 | 14300 | 04/05/2009 | 12990 | 20/06/2009 | 16400 | | |
| 31/01/2009 | 15580 | 19/03/2009 | 14560 | 05/05/2009 | 13150 | 21/06/2009 | 14660 | | |
| 01/02/2009 | 11850 | 20/03/2009 | 15070 | 06/05/2009 | 12700 | 22/06/2009 | 14220 | | |
| 02/02/2009 | 12100 | 21/03/2009 | 15850 | 07/05/2009 | 13820 | 23/06/2009 | 14600 | | |
| 03/02/2009 | 12830 | 22/03/2009 | 14000 | 08/05/2009 | 14190 | 24/06/2009 | 15010 | | |
| 04/02/2009 | 12450 | 23/03/2009 | 16470 | 09/05/2009 | 13780 | 25/06/2009 | 16420 | | |
| 05/02/2009 | 12560 | 24/03/2009 | 12350 | 10/05/2009 | 14510 | 26/06/2009 | 16190 | | |
| 06/02/2009 | 11930 | 25/03/2009 | 11650 | 11/05/2009 | 14370 | 27/06/2009 | 16180 | | |
| 07/02/2009 | 13890 | 26/03/2009 | 13270 | 12/05/2009 | 13150 | 28/06/2009 | 15540 | | |
| 08/02/2009 | 12320 | 27/03/2009 | 14960 | 13/05/2009 | 14460 | 29/06/2009 | 14350 | | |
| 09/02/2009 | 12200 | 28/03/2009 | 15070 | 14/05/2009 | 15010 | 30/06/2009 | 14410 | | |
| 10/02/2009 | 15010 | 29/03/2009 | 14410 | 15/05/2009 | 15750 | 01/07/2009 | 15430 | | |

Table 3East Zarqa Pumping Station

| 11/02/2009 | 12150 | 30/03/2009 | 13810 | 16/05/2009 | 16020 | 02/07/2009 | 14970 | | | |
|------------|--------|------------|--------|------------------|--------|------------------------|-------|--|--|--|
| 12/02/2009 | 14010 | 31/03/2009 | 14230 | 17/05/2009 14880 | | 03/07/2009 | 16200 | | | |
| 13/02/2009 | 14230 | 01/04/2009 | 13510 | 18/05/2009 16680 | | 04/07/2009 | 15510 | | | |
| 14/02/2009 | 15620 | 02/04/2009 | 14610 | 19/05/2009 14910 | | 05/07/2009 | 14480 | | | |
| 15/02/2009 | 13530 | 03/04/2009 | 14270 | 20/05/2009 | 15210 | 06/07/2009 | 14220 | | | |
| 16/02/2009 | 12980 | 04/04/2009 | 15260 | 21/05/2009 | 15040 | 07/07/2009 | 13670 | | | |
| Part II | | | | | | | | | | |
| Date | m³/day | Date | m³/day | Date | m³/day | ³ /day Date | | | | |
| 08/07/2009 | 14360 | 24/08/2009 | 14590 | 10/10/2009 | 16050 | 26/11/2009 | 15700 | | | |
| 09/07/2009 | 17430 | 25/08/2009 | 15100 | 11/10/2009 | 14860 | 27/11/2009 | 11330 | | | |
| 10/07/2009 | 16200 | 26/08/2009 | 15690 | 12/10/2009 | 13990 | 28/11/2009 | 11270 | | | |
| 11/07/2009 | 15520 | 27/08/2009 | 16420 | 13/10/2009 | 14120 | 29/11/2009 | 10710 | | | |
| 12/07/2009 | 13940 | 28/08/2009 | 16650 | 14/10/2009 | 14360 | 30/11/2009 | 10920 | | | |
| 13/07/2009 | 14740 | 29/08/2009 | 16420 | 15/10/2009 | 15370 | 01/12/2009 | 10780 | | | |
| 14/07/2009 | 13760 | 30/08/2009 | 16520 | 16/10/2009 | 16160 | 02/12/2009 | 10290 | | | |
| 15/07/2009 | 14150 | 31/08/2009 | 14560 | 17/10/2009 | 16530 | 03/12/2009 | 11390 | | | |
| 16/07/2009 | 15840 | 01/09/2009 | 14680 | 18/10/2009 | 13970 | 04/12/2009 | 12770 | | | |
| 17/07/2009 | 15060 | 02/09/2009 | 15780 | 19/10/2009 | 14270 | 05/12/2009 | 12880 | | | |
| 18/07/2009 | 16260 | 03/09/2009 | 16590 | 20/10/2009 | 14100 | 06/12/2009 | 10940 | | | |
| 19/07/2009 | 14600 | 04/09/2009 | 16620 | 21/10/2009 | 14140 | 07/12/2009 | 12920 | | | |
| 20/07/2009 | 13530 | 05/09/2009 | 16660 | 22/10/2009 | 14580 | 08/12/2009 | 10600 | | | |
| 21/07/2009 | 14040 | 06/09/2009 | 14680 | 23/10/2009 | 15330 | 09/12/2009 | 11320 | | | |
| 22/07/2009 | 14800 | 07/09/2009 | 14120 | 24/10/2009 | 14830 | 10/12/2009 | 12380 | | | |
| 23/07/2009 | 15530 | 08/09/2009 | 15030 | 25/10/2009 | 14300 | 11/12/2009 | 13280 | | | |
| 24/07/2009 | 15250 | 09/09/2009 | 14650 | 26/10/2009 | 14600 | 12/12/2009 | 12960 | | | |
| 25/07/2009 | 15920 | 10/09/2009 | 15570 | 27/10/2009 | 13040 | 13/12/2009 | 11810 | | | |
| 26/07/2009 | 15010 | 11/09/2009 | 17220 | 28/10/2009 | 13470 | 14/12/2009 | 10920 | | | |
| 27/07/2009 | 14580 | 12/09/2009 | 16550 | 29/10/2009 | 14140 | 15/12/2009 | 11540 | | | |
| 28/07/2009 | 15200 | 13/09/2009 | 14960 | 30/10/2009 | 14200 | 16/12/2009 | 11700 | | | |
| 29/07/2009 | 14730 | 14/09/2009 | 14730 | 31/10/2009 | 14270 | 17/12/2009 | 16560 | | | |
| 30/07/2009 | 15730 | 15/09/2009 | 14740 | 01/11/2009 | 13050 | 18/12/2009 | 16350 | | | |
| 31/07/2009 | 15170 | 16/09/2009 | 15480 | 02/11/2009 | 13400 | 19/12/2009 | 12840 | | | |
| 01/08/2009 | 15040 | 17/09/2009 | 16380 | 03/11/2009 | 12670 | 20/12/2009 | 10990 | | | |
| 02/08/2009 | 15350 | 18/09/2009 | 16470 | 04/11/2009 | 13520 | 21/12/2009 | 10610 | | | |
| 03/08/2009 | 14310 | 19/09/2009 | 17350 | 05/11/2009 | 14310 | 22/12/2009 | 10180 | | | |
| 04/08/2009 | 14400 | 20/09/2009 | 13730 | 06/11/2009 | 14960 | 23/12/2009 | 11960 | | | |
| 05/08/2009 | 14830 | 21/09/2009 | 13000 | 07/11/2009 | 14370 | 24/12/2009 | 13470 | | | |
| 06/08/2009 | 15620 | 22/09/2009 | 13400 | 08/11/2009 | 12350 | 25/12/2009 | 13140 | | | |
| 07/08/2009 | 15500 | 23/09/2009 | 14970 | 09/11/2009 | 12500 | 26/12/2009 | 13170 | | | |
| 08/08/2009 | 15230 | 24/09/2009 | 15320 | 10/11/2009 | 12300 | 27/12/2009 | 10700 | | | |
| 09/08/2009 | 14190 | 25/09/2009 | 16100 | 11/11/2009 | 12750 | 28/12/2009 | 11490 | | | |
| 10/08/2009 | 13830 | 26/09/2009 | 16570 | 12/11/2009 | 13560 | 29/12/2009 | 10460 | | | |
| 11/08/2009 | 14230 | 27/09/2009 | 14820 | 13/11/2009 | 14070 | 30/12/2009 | 11160 | | | |
| 12/08/2009 | 15160 | 28/09/2009 | 15210 | 14/11/2009 | 13730 | 31/12/2009 | 12490 | | | |
| 13/08/2009 | 16570 | 29/09/2009 | 14800 | 15/11/2009 | 11930 | 01/01/2010 | 12880 | | | |

| 14/08/2009 | 16650 | 30/09/2009 | 15400 | 16/11/2009 | 11620 | - | - |
|------------|-------|------------|-------|------------|-------|---|---|
| 15/08/2009 | 16250 | 01/10/2009 | 16050 | 17/11/2009 | 13560 | - | - |
| 16/08/2009 | 16500 | 02/10/2009 | 17280 | 18/11/2009 | 12820 | - | - |
| 17/08/2009 | 15030 | 03/10/2009 | 17280 | 19/11/2009 | 12870 | - | - |
| 18/08/2009 | 15590 | 04/10/2009 | 14780 | 20/11/2009 | 12900 | - | - |
| 19/08/2009 | 15210 | 05/10/2009 | 14800 | 21/11/2009 | 13110 | - | - |
| 20/08/2009 | 16300 | 06/10/2009 | 14650 | 22/11/2009 | 11240 | - | - |
| 21/08/2009 | 16710 | 07/10/2009 | 14860 | 23/11/2009 | 11720 | | - |
| 22/08/2009 | 16630 | 08/10/2009 | 15850 | 24/11/2009 | 13360 | - | - |
| 23/08/2009 | 16130 | 09/10/2009 | 15220 | 25/11/2009 | 12460 | - | - |

Average Daily Flow: 14,310 m³/day

Maximum Daily Flow: 20,560 m³/day

Minimum Daily Flow: 10,180 m³/day

APPENDIX 4 POPULATION PROJECTIONS

2025 2030 2035 2010 2015 2020 Neighbourhood al-Tafeh 835 937 1,027 1,116 1,205 1,293 District al-Rukban 213 239 262 285 308 330 Zarqa Khaw 445 499 547 594 641 688 al-Farwaniyeh 133 149 163 191 205 177 Hai al-Hadiga 4,080 4,183 4,288 4,397 4,508 4,621 Hai al-Nuzha 6.521 6,853 7,203 7,570 7,956 8,362 Hai al-Hussein 20,098 20,098 20,098 20,098 20,098 20,098 Hai al-Wasat al-Tijary 16,848 17,273 17,709 18,157 18,615 19,067 Hai al-Nasr 13,272 13,272 13,272 13,272 13,272 13,272 Hai Ramzi 31,230 34,506 32,018 32,827 33,656 35,181 13,418 Hai Shaker 12,451 12,765 13,088 13,757 14,104 Hai al-Basateen 5,373 7,451 9,716 10,934 11,509 12,823 Hai Ma'soum 24,477 25,095 25,729 26,378 27,044 27,727 Hai al-Hashemi 7,182 9,364 10,538 11,092 12,359 5,178 Hai al-Ghweireyeh 29,689 29,689 29,689 29,689 29,689 29,689 Hai al-Ameer Mohammad 15,727 16,125 16,532 16,949 17,377 17,816 Hai al-Shyoukh 9,092 9,322 9,557 9,798 10,046 10,300 Zarqa Municipality Hai Barakh 7,688 7,882 8,081 8,709 8,285 8,494 Hai Ibn Sina 7,033 7,210 7,579 6,691 6,860 7,393 4,259 Hai al-Iskan 4,052 4,154 4,367 4,477 4,590 Hai al-Dhubbat 4,399 4,510 4,624 4.741 4.861 4,983 Hai al-Janna'a 21,237 21,773 22,323 22,887 23,465 24,057 al-Hai al-Thawra al-Arabiyah Kubrah 22,063 22,620 23,192 23,777 24,378 24,993 Hai al-Jundi 5,610 5,752 5,897 6,046 6,199 6,355 Hai al-Masane'e 7,558 10,483 13,669 15,382 16,191 18.040 Hai Tarwq Bin Zeyad 6,547 6,712 6,881 7,055 7,233 7,416 Hai Tarwg Bin Zeyad 6,837 6,441 6,441 6,441 6,441 6,441 Hai al-Ameer Hamzah 12,546 12,863 13,188 13,521 13,862 14,212 Hai al-Jabal al-Abyad 17,887 16,189 16,598 17,017 17,446 18,339 Hai al-Ameera Rahmah 10,946 10,157 10,413 10,676 11,222 11,506 11,561 13,097 Hai al-Ameer Hassan 11,853 12,153 12,459 12,774 Hai al-Malek Talal 14,125 14,481 14,847 15,222 15,606 16,000 1,757 1,846 2,040 2,144 Hai Awajan 1,672 1,941

Table 1: Population Distribution Projections

Table 1: Population Distribution Projections

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|----------|---------------------------------|--------|--------|--------|--------|--------|--------|
| | Hai al-Falah | 9,051 | 9,513 | 9,998 | 10,508 | 11,044 | 11,608 |
| | Hai Umm Bayadhah | 3,820 | 3,917 | 4,015 | 4,117 | 4,221 | 4,327 |
| | Hai al-Dweik | 1,706 | 1,793 | 1,884 | 1,980 | 2,081 | 2,188 |
| | Hai al-Madina al-Munawara | 3,709 | 5,144 | 6,707 | 7,548 | 7,945 | 8,852 |
| | Hai Makka al-Mukarramah | 702 | 974 | 1,270 | 1,429 | 1,504 | 1,676 |
| | Hai al-Ahmad | 4,173 | 5,788 | 7,548 | 8,493 | 8,940 | 9,961 |
| | Hai Nassar | 2,282 | 2,339 | 2,398 | 2,459 | 2,521 | 2,585 |
| | Hai al-Zawahreh | 18,324 | 18,787 | 19,261 | 19,748 | 20,246 | 20,757 |
| > | Hai al-Qamar | 3,482 | 3,570 | 3,660 | 3,752 | 3,847 | 3,944 |
| oalit | Hai Qurtuba | 3,650 | 3,743 | 3,837 | 3,934 | 4,033 | 4,135 |
| Inicij | Hai al-Jneineh | 3,803 | 5,274 | 6,877 | 7,739 | 8,146 | 9,076 |
| a Mu | Hai al-Jabr | 1,900 | 1,997 | 2,099 | 2,206 | 2,318 | 2,437 |
| arqa | Hai al-Ameera Haya | 15,008 | 20,816 | 27,142 | 30,544 | 32,150 | 35,821 |
| N | Hai Shomar | 4,000 | 5,548 | 7,234 | 8,140 | 8,569 | 9,547 |
| | Hai al-Bustan | 3,500 | 4,854 | 6,330 | 7,123 | 7,497 | 8,354 |
| | Hai al-Zarqa'a al-Jadida | 25,782 | 26,433 | 27,101 | 27,785 | 28,487 | 29,206 |
| | Hai al-Batrawi | 33,254 | 46,121 | 60,139 | 67,676 | 71,235 | 79,369 |
| | Hai al-Hirafyeen | 33 | 30 | 30 | 30 | 30 | 30 |
| | Hai al-Hashemeyah al-Janoubiyah | 5,111 | 5,240 | 5,373 | 5,508 | 5,647 | 5,790 |
| | Hai Ma'amel al-Toub | 774 | 1,074 | 1,400 | 1,576 | 1,658 | 1,848 |
| | Birein | 1,415 | 1,587 | 1,740 | 1,891 | 2,041 | 2,190 |
| | Umm Rummaneh | 1,289 | 1,446 | 1,586 | 1,723 | 1,860 | 1,996 |
| | al-Kamsha | 1,493 | 1,674 | 1,836 | 1,996 | 2,154 | 2,311 |
| | al-Alouk | 759 | 851 | 934 | 1,015 | 1,095 | 1,175 |
| | Hai Sarout | 1,420 | 1,592 | 1,746 | 1,897 | 2,047 | 2,197 |
| | Marhab | 778 | 873 | 958 | 1,040 | 1,123 | 1,205 |
| ict | Rujm al-Shok | 831 | 933 | 1,023 | 1,111 | 1,199 | 1,287 |
| Dist | al-Naseriyah | 612 | 687 | 753 | 818 | 883 | 948 |
| Birein I | al-Mikman | 588 | 660 | 723 | 786 | 848 | 910 |
| | al-Masarrah al-Sharqiyah | 433 | 485 | 532 | 578 | 624 | 670 |
| | al-Masarrah al-Gharbiya | 519 | 582 | 639 | 694 | 749 | 804 |
| | al-Makhdat | 29 | 32 | 36 | 39 | 42 | 45 |
| | al-Khillah | 284 | 319 | 350 | 380 | 410 | 440 |
| | Maqam Eisa | 628 | 704 | 772 | 839 | 906 | 972 |
| | Ein Saber | 704 | 789 | 866 | 941 | 1,015 | 1,089 |
| | al-Bireh | 401 | 450 | 494 | 536 | 579 | 621 |
Table 1: Population Distribution Projections

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|-------------|----------------------------|--------|--------|--------|--------|--------|--------|
| | al-Riyadh | 527 | 591 | 648 | 704 | 760 | 815 |
| | al-Sahhara | 66 | 74 | 82 | 89 | 96 | 103 |
| | al-Ouweillieh | 168 | 188 | 206 | 224 | 242 | 259 |
| <u>ic</u> . | Wadi Suwwan | 251 | 281 | 308 | 335 | 362 | 388 |
| Distr | Umm Fatyer | 122 | 136 | 150 | 163 | 176 | 188 |
| ein | Ein al-Hawaya | 99 | 111 | 122 | 132 | 143 | 153 |
| Bir | Umm Khasheibah | 425 | 477 | 523 | 569 | 614 | 658 |
| | Umm al-Biyar | 498 | 558 | 612 | 665 | 718 | 770 |
| | al-Dhuleil | 33,312 | 37,359 | 40,973 | 44,523 | 48,047 | 51,560 |
| rict | Qasr al-Hallabat al-Sharqi | 2,197 | 2,464 | 2,702 | 2,936 | 3,169 | 3,400 |
| Dist | Qasr al-Hallabat al-Gharbi | 2,966 | 3,326 | 3,648 | 3,964 | 4,277 | 4,590 |
| lleil | al-Deheitem | 310 | 347 | 381 | 414 | 447 | 479 |
| Dhi | Sayeh Diyab | 329 | 369 | 405 | 440 | 475 | 509 |
| | Mazare'e Hallabat | 180 | 201 | 221 | 240 | 259 | 278 |
| | Hai Awajan al-Shamali | 297 | 272 | 272 | 272 | 272 | 272 |
| | Hai Umm Jarada | 738 | 1,024 | 1,335 | 1,502 | 1,581 | 1,762 |
| | Hai al-Jundi | 4,657 | 4,895 | 5,144 | 5,407 | 5,683 | 5,972 |
| | Hai al-Ameer Ali | 4,865 | 4,988 | 5,114 | 5,243 | 5,375 | 5,511 |
| | Hai Kharrouba al-Sharqi | 344 | 315 | 315 | 315 | 315 | 315 |
| | Hai Kharrouba al-Gharbi | 302 | 420 | 547 | 616 | 648 | 722 |
| | Hai al-Arateqa | 9,484 | 9,723 | 9,969 | 10,220 | 10,479 | 10,743 |
| | Hai al-Arab | 5,584 | 5,725 | 5,869 | 6,018 | 6,169 | 6,325 |
| ity | Hai al-Hussein | 10,709 | 10,089 | 10,089 | 10,089 | 10,089 | 10,089 |
| cipal | Hai al-Jabal al-Shamali | 33,975 | 34,833 | 35,712 | 36,614 | 37,539 | 38,487 |
| lunid | Hai al-Khalediyah | 4,157 | 4,262 | 4,370 | 4,480 | 4,593 | 4,709 |
| ifa N | Hai al-Qadessiyah | 25,873 | 26,527 | 27,197 | 27,883 | 28,587 | 29,309 |
| Isse | Hai Awajan al-Gharbi | 15,557 | 15,949 | 16,352 | 16,765 | 17,188 | 17,622 |
| RL | Hai Umm Jarada al-Shamali | 6,960 | 7,136 | 7,316 | 7,501 | 7,690 | 7,885 |
| | Hai Umm Jarada al-Gharbi | 4,595 | 4,711 | 4,830 | 4,952 | 5,077 | 5,206 |
| | Hai al-Daheriyah | 5,718 | 5,387 | 5,387 | 5,387 | 5,387 | 5,387 |
| | Hai Iskan al-Ameer Talal | 4,508 | 4,247 | 4,247 | 4,247 | 4,247 | 4,247 |
| | Hai al-Razi | 2,198 | 2,254 | 2,311 | 2,369 | 2,429 | 2,490 |
| | Hai al-Tatweer al-Hadari | 20,120 | 18,954 | 18,954 | 18,954 | 18,954 | 18,954 |
| | al-Mustashfa | 69 | 77 | 84 | 92 | 99 | 106 |
| | Hai al-Rasheed al-Janoubi | 8,728 | 8,949 | 9,175 | 9,406 | 9,644 | 9,887 |
| | Hai al-Hurriyah | 2,705 | 2,749 | 2,749 | 2,749 | 2,749 | 2,749 |

Table 1: Population Distribution Projections

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|------------------|-----------------------------------|---------|-----------|-----------|-----------|-----------|-----------|
| | Hai Ja'far al-Tayar al-Janoubi | 1,327 | 1,394 | 1,465 | 1,540 | 1,619 | 1,701 |
| | Hai Ja'far al-Tayar | 8,280 | 8,489 | 8,704 | 8,923 | 9,149 | 9,380 |
| | Hai al-Rasheed al-Shamali | 12,958 | 13,285 | 13,620 | 13,964 | 14,317 | 14,678 |
| | Hai Jraiba | 7,987 | 11,077 | 14,444 | 16,254 | 17,109 | 19,062 |
| | Hai al-Ghaidaniyah | 547 | 759 | 990 | 1,114 | 1,172 | 1,306 |
| | Hai Ein Shabwa | 292 | 405 | 527 | 594 | 625 | 696 |
| | Hai al-Msheirfah | 13,012 | 13,341 | 13,678 | 14,023 | 14,377 | 14,740 |
| ality | Hai al-Msheirfah al-Gharbi | 3,183 | 3,264 | 3,346 | 3,431 | 3,517 | 3,606 |
| nicip | Hai al-Msheirfah al-Janoubi | 3,563 | 3,653 | 3,745 | 3,840 | 3,936 | 4,036 |
| Mul | Hai al-Iskanat | 9,475 | 9,714 | 9,959 | 10,211 | 10,469 | 10,733 |
| seifa | Hai Abu Ghalyoon | 3,131 | 3,290 | 3,458 | 3,635 | 3,820 | 4,015 |
| Suss | Hai Jabal al-Ameer Faisal | 20,415 | 20,930 | 21,459 | 22,001 | 22,556 | 23,126 |
| - | Hai al-Wananat | 705 | 665 | 665 | 665 | 665 | 665 |
| | Theodor Shneller | 92 | 103 | 113 | 122 | 132 | 142 |
| | Hai al-Fakhourah | 2,698 | 2,467 | 2,467 | 2,467 | 2,467 | 2,467 |
| | Hai Abu Sayyah | 2,411 | 2,704 | 2,966 | 3,223 | 3,478 | 3,732 |
| | Hai Hitteen Camp | 42,706 | 43,784 | 44,890 | 46,023 | 47,185 | 48,377 |
| | Hai al-Hashemiyah | 20,405 | 20,920 | 21,448 | 21,990 | 22,545 | 23,115 |
| ¥ | Hai Iskan al-Hashemiyah | 6,632 | 6,799 | 6,971 | 7,147 | 7,328 | 7,513 |
| istric | Hai al-Fayha'a | 1,220 | 1,251 | 1,283 | 1,315 | 1,348 | 1,382 |
| D H | al-Sukhneh | 15,289 | 17,146 | 18,805 | 20,434 | 22,051 | 23,664 |
| miya | Abu al-Zeighan | 2,563 | 2,875 | 3,153 | 3,426 | 3,697 | 3,967 |
| shei | Dogara | 2,251 | 2,525 | 2,769 | 3,009 | 3,247 | 3,484 |
| I-Ha | Ein al-Nimra | 158 | 177 | 194 | 211 | 228 | 244 |
| а | Ghareisa | 804 | 901 | 989 | 1,074 | 1,159 | 1,244 |
| | Umm Suleih | 2,579 | 2,892 | 3,172 | 3,447 | 3,720 | 3,992 |
| ч | al-Ghuneiyah | 663 | 743 | 815 | 886 | 956 | 1,026 |
| niya | Daba'an | 293 | 328 | 360 | 391 | 422 | 453 |
| sher | Tawaheen al-Adwan | 57 | 64 | 70 | 76 | 82 | 88 |
| -Ha | al-Hasab | 57 | 64 | 70 | 76 | 82 | 88 |
| ធ | al-Ruhail | 396 | 445 | 488 | 530 | 572 | 614 |
| Azraq Distric | Azraq | 10,871 | 12,192 | 13,371 | 14,530 | 15,680 | 16,826 |
| | King Abdullah Bin Abdul Aziz City | | 67,945 | 121,824 | 220,000 | 339,071 | 430,400 |
| | al-Majd City | | 31,800 | 42,400 | 42,400 | 42,400 | 42,400 |
| | Total | 921,454 | 1,083,280 | 1,215,486 | 1,362,782 | 1,519,791 | 1,662,628 |

APPENDIX 5 WASTEWATER FLOW DISTRIBUTION PROJECTIONS

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|------------|---|-------|-------|-------|-------|-------|-------|
| <u>ici</u> | al-Tafeh | 67 | 75 | 82 | 89 | 96 | 103 |
| Distr | al-Rukban | 17 | 19 | 21 | 23 | 25 | 26 |
| 'qa I | Khaw | 36 | 40 | 44 | 48 | 51 | 55 |
| Zaı | al-Farwaniyeh | 11 | 12 | 13 | 14 | 15 | 16 |
| | Hai al-Hadiqa | 408 | 429 | 440 | 451 | 462 | 474 |
| | Hai al-Nuzha | 652 | 702 | 738 | 776 | 796 | 816 |
| | Hai al-Hussein | 2,010 | 2,010 | 2,010 | 2,010 | 2,010 | 2,010 |
| | Hai al-Wasat al-Tijary | 1,685 | 1,771 | 1,815 | 1,861 | 1,907 | 1,907 |
| | Hai al-Nasr | 1,327 | 1,327 | 1,327 | 1,327 | 1,327 | 1,327 |
| | Hai Ramzi | 3,123 | 3,282 | 3,365 | 3,450 | 3,518 | 3,518 |
| | Hai Shaker | 1,245 | 1,309 | 1,342 | 1,376 | 1,410 | 1,446 |
| | Hai al-Basateen | 477 | 603 | 717 | 823 | 899 | 922 |
| | Hai Ma'soum | 2,448 | 2,573 | 2,638 | 2,704 | 2,772 | 2,842 |
| | Hai al-Hashemi | 460 | 582 | 691 | 793 | 867 | 938 |
| | Hai al-Ghweireyeh | 2,969 | 2,969 | 2,969 | 2,969 | 2,969 | 2,969 |
| | Hai al-Ameer Mohammad | 1,573 | 1,653 | 1,695 | 1,738 | 1,781 | 1,826 |
| ality | Hai al-Shyoukh | 909 | 956 | 980 | 1,004 | 1,030 | 1,056 |
| licip | Hai Barakh | 769 | 808 | 828 | 849 | 871 | 893 |
| Mur | Hai Ibn Sina | 669 | 703 | 721 | 739 | 758 | 777 |
| ırqa | Hai al-Iskan | 405 | 426 | 437 | 448 | 459 | 471 |
| Za | Hai al-Dhubbat | 440 | 462 | 474 | 486 | 498 | 511 |
| | Hai al-Janna'a | 2,124 | 2,232 | 2,288 | 2,346 | 2,405 | 2,466 |
| | Hai al-Thawra al-Arabiyah al- Kubrah | 2,206 | 2,319 | 2,377 | 2,437 | 2,499 | 2,562 |
| | Hai al-Jundi | 561 | 590 | 605 | 620 | 635 | 652 |
| | Hai al-Masane'e | 240 | 258 | 272 | 285 | 293 | 300 |
| | Hai Tarwq Bin Zeyad | 655 | 688 | 705 | 723 | 741 | 757 |
| | Hai Tarwq Bin Zeyad | 644 | 644 | 644 | 644 | 644 | 644 |
| | Hai al-Ameer Hamzah | 1,255 | 1,319 | 1,352 | 1,386 | 1,421 | 1,457 |
| | Hai al-Jabal al-Abyad | 1,619 | 1,701 | 1,744 | 1,788 | 1,834 | 1,880 |
| | Hai al-Ameera Rahmah | 1,016 | 1,068 | 1,094 | 1,122 | 1,150 | 1,179 |
| | Hai al-Ameer Hassan | 1,156 | 1,215 | 1,246 | 1,277 | 1,309 | 1,343 |
| | Hai al-Malek Talal | 1,412 | 1,485 | 1,522 | 1,560 | 1,600 | 1,640 |

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|-------|---------------------------------|-------|-------|-------|-------|-------|-------|
| | Hai Awajan | 167 | 180 | 189 | 199 | 204 | 209 |
| | Hai al-Falah | 905 | 975 | 1,025 | 1,077 | 1,104 | 1,132 |
| | Hai Umm Bayadhah | 1,101 | 1,393 | 1,655 | 1,899 | 2,076 | 2,246 |
| | Hai al-Dweik | 750 | 949 | 1,127 | 1,293 | 1,414 | 1,530 |
| | Hai al-Madina al-Munawara | 329 | 417 | 495 | 568 | 621 | 672 |
| | Hai Makka al-Mukarramah | 320 | 405 | 481 | 552 | 603 | 653 |
| | Hai al-Ahmad | 371 | 469 | 557 | 639 | 699 | 756 |
| | Hai Nassar | 658 | 832 | 989 | 1,134 | 1,240 | 1,341 |
| | Hai al-Zawahreh | 1,832 | 1,926 | 1,975 | 2,024 | 2,075 | 2,128 |
| ~ | Hai al-Qamar | 348 | 366 | 375 | 385 | 394 | 404 |
| palit | Hai Qurtuba | 365 | 384 | 393 | 403 | 413 | 424 |
| Inici | Hai al-Jneineh | 338 | 427 | 507 | 582 | 637 | 689 |
| a Mu | Hai al-Jabr | 532 | 673 | 799 | 917 | 1,002 | 1,085 |
| arq | Hai al-Ameera Haya | 1,332 | 1,686 | 2,003 | 2,298 | 2,513 | 2,718 |
| N | Hai Shomar | 300 | 380 | 451 | 517 | 566 | 612 |
| | Hai al-Bustan | 400 | 506 | 601 | 690 | 754 | 816 |
| | Hai al-Zarqa'a al-Jadida | 2,578 | 2,710 | 2,778 | 2,848 | 2,920 | 2,994 |
| | Hai al-Batrawi | 2,952 | 3,735 | 4,438 | 5,092 | 5,567 | 6,023 |
| | Hai al-Hirafyeen | 3 | 3 | 3 | 3 | 3 | 3 |
| | Hai al-Hashemeyah al-Janoubiyah | 511 | 537 | 551 | 565 | 579 | 594 |
| | Hai Ma'amel al-Toub | 22 | 22 | 22 | 22 | 22 | 22 |
| | Birein | 113 | 127 | 139 | 151 | 163 | 175 |
| | Umm Rummaneh | 103 | 116 | 127 | 138 | 149 | 160 |
| | al-Kamsha | 119 | 134 | 147 | 160 | 172 | 185 |
| | al-Alouk | 61 | 68 | 75 | 81 | 88 | 94 |
| | Hai Sarout | 114 | 127 | 140 | 152 | 164 | 176 |
| ÷ | Marhab | 62 | 70 | 77 | 83 | 90 | 96 |
| stric | Rujm al-Shok | 67 | 75 | 82 | 89 | 96 | 103 |
| n Di | al-Naseriyah | 49 | 55 | 60 | 65 | 71 | 76 |
| Birei | al-Mikman | 47 | 53 | 58 | 63 | 68 | 73 |
| | al-Masarrah al-Sharqiyah | 35 | 39 | 43 | 46 | 50 | 54 |
| | al-Masarrah al-Gharbiya | 42 | 47 | 51 | 56 | 60 | 64 |
| | al-Makhdat | 2 | 3 | 3 | 3 | 3 | 4 |
| | al-Khillah | 23 | 26 | 28 | 30 | 33 | 35 |
| | Maqam Eisa | 50 | 56 | 62 | 67 | 72 | 78 |
| | Ein Saber | 56 | 63 | 69 | 75 | 81 | 87 |

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|----------|----------------------------|-------|-------|-------|-------|-------|-------|
| | al-Bireh | 32 | 36 | 39 | 43 | 46 | 50 |
| | al-Riyadh | 42 | 47 | 52 | 56 | 61 | 65 |
| | al-Sahhara | 5 | 6 | 7 | 7 | 8 | 8 |
| | al-Ouweillieh | 13 | 15 | 16 | 18 | 19 | 21 |
| <u>ថ</u> | Wadi Suwwan | 20 | 22 | 25 | 27 | 29 | 31 |
| Distr | Umm Fatyer | 10 | 11 | 12 | 13 | 14 | 15 |
| ein | Ein al-Hawaya | 8 | 9 | 10 | 11 | 11 | 12 |
| Bir | Umm Khasheibah | 34 | 38 | 42 | 45 | 49 | 53 |
| | Umm al-Biyar | 40 | 45 | 49 | 53 | 57 | 62 |
| | al-Dhuleil | 2,665 | 2,989 | 3,278 | 3,562 | 3,844 | 4,125 |
| rict | Qasr al-Hallabat al-Sharqi | 176 | 197 | 216 | 235 | 253 | 272 |
| Dist | Qasr al-Hallabat al-Gharbi | 237 | 266 | 292 | 317 | 342 | 367 |
| uleil | al-Deheitem | 25 | 28 | 30 | 33 | 36 | 38 |
| Ā | Sayeh Diyab | 26 | 30 | 32 | 35 | 38 | 41 |
| | Mazare'e Hallabat | 14 | 16 | 18 | 19 | 21 | 22 |
| | Hai Awajan al-Shamali | 27 | 27 | 27 | 27 | 27 | 27 |
| | Hai Umm Jarada | 21 | 21 | 21 | 21 | 21 | 21 |
| | Hai al-Jundi | 466 | 502 | 527 | 554 | 568 | 583 |
| | Hai al-Ameer Ali | 486 | 511 | 524 | 537 | 551 | 565 |
| | Hai Kharrouba al-Sharqi | 31 | 31 | 31 | 31 | 31 | 31 |
| | Hai Kharrouba al-Gharbi | 27 | 34 | 40 | 46 | 51 | 55 |
| | Hai al-Arateqa | 948 | 997 | 1,022 | 1,048 | 1,074 | 1,101 |
| | Hai al-Arab | 558 | 587 | 602 | 617 | 632 | 648 |
| pality | Hai al-Hussein | 1,009 | 1,009 | 1,009 | 1,009 | 1,009 | 1,009 |
| nicip | Hai al-Jabal al-Shamali | 3,397 | 3,571 | 3,661 | 3,753 | 3,848 | 3,945 |
| Mu | Hai al-Khalediyah | 416 | 437 | 448 | 459 | 471 | 483 |
| seifa | Hai al-Qadessiyah | 2,587 | 2,719 | 2,788 | 2,858 | 2,931 | 3,005 |
| Rus | Hai Awajan al-Gharbi | 1,556 | 1,635 | 1,676 | 1,719 | 1,762 | 1,807 |
| | Hai Umm Jarada al-Shamali | 696 | 732 | 750 | 769 | 788 | 808 |
| | Hai Umm Jarada al-Gharbi | 460 | 483 | 495 | 508 | 521 | 534 |
| | Hai al-Daheriyah | 539 | 539 | 539 | 539 | 539 | 539 |
| | Hai Iskan al-Ameer Talal | 425 | 425 | 425 | 425 | 425 | 425 |
| | Hai al-Razi | 220 | 231 | 237 | 243 | 249 | 255 |
| | Hai al-Tatweer al-Hadari | 1,895 | 1,895 | 1,895 | 1,895 | 1,895 | 1,895 |
| | al-Mustashfa | 7 | 8 | 8 | 9 | 10 | 11 |
| | Hai al-Rasheed al-Janoubi | 873 | 917 | 941 | 964 | 989 | 1,014 |

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|-------------------|-----------------------------------|-------|-------|--------|--------|--------|--------|
| | Hai al-Hurriyah | 271 | 275 | 275 | 275 | 275 | 275 |
| | Hai Ja'far al-Tayar al-Janoubi | 133 | 143 | 150 | 158 | 162 | 166 |
| | Hai Ja'far al-Tayar | 828 | 870 | 892 | 915 | 938 | 962 |
| | Hai al-Rasheed al-Shamali | 1,296 | 1,362 | 1,396 | 1,432 | 1,468 | 1,505 |
| | Hai Jraiba | 267 | 300 | 329 | 357 | 386 | 414 |
| | Hai al-Ghaidaniyah | 49 | 61 | 73 | 84 | 92 | 99 |
| | Hai Ein Shabwa | 26 | 33 | 39 | 45 | 49 | 53 |
| | Hai al-Msheirfah | 1,301 | 1,368 | 1,402 | 1,438 | 1,474 | 1,511 |
| ality | Hai al-Msheirfah al-Gharbi | 318 | 335 | 343 | 352 | 361 | 370 |
| nicip | Hai al-Msheirfah al-Janoubi | 356 | 374 | 384 | 394 | 404 | 414 |
| Mu | Hai al-Iskanat | 947 | 996 | 1,021 | 1,047 | 1,073 | 1,100 |
| seifa | Hai Abu Ghalyoon | 313 | 337 | 354 | 373 | 382 | 392 |
| Suss | Hai Jabal al-Ameer Faisal | 2,041 | 2,146 | 2,200 | 2,255 | 2,312 | 2,371 |
| | Hai al-Wananat | 66 | 66 | 66 | 66 | 66 | 66 |
| | Theodor Shneller | 9 | 10 | 11 | 12 | 13 | 14 |
| | Hai al-Fakhourah | 247 | 247 | 247 | 247 | 247 | 247 |
| | Hai Abu Sayyah | 193 | 216 | 237 | 258 | 278 | 299 |
| | Hai Hitteen Camp | 4,271 | 4,488 | 4,602 | 4,718 | 4,837 | 4,857 |
| | Hai al-Hashemiyah | 2,040 | 2,145 | 2,199 | 2,254 | 2,311 | 2,370 |
| Ħ | Hai Iskan al-Hashemiyah | 663 | 697 | 715 | 733 | 751 | 770 |
| istric | Hai al-Fayha'a | 122 | 128 | 131 | 135 | 138 | 142 |
| Dh | al-Sukhneh | 1,529 | 1,715 | 1,880 | 2,043 | 2,205 | 2,366 |
| miya | Abu al-Zeighan | 205 | 230 | 252 | 274 | 296 | 317 |
| Ishei | Dogara | 180 | 202 | 222 | 241 | 260 | 279 |
| I-Ha | Ein al-Nimra | 13 | 14 | 16 | 17 | 18 | 20 |
| σ | Ghareisa | 64 | 72 | 79 | 86 | 93 | 100 |
| | Umm Suleih | 206 | 231 | 254 | 276 | 298 | 319 |
| ۔ ب | al-Ghuneiyah | 53 | 59 | 65 | 71 | 76 | 82 |
| niya | Daba'an | 23 | 26 | 29 | 31 | 34 | 36 |
| sher | Tawaheen al-Adwan | 5 | 5 | 6 | 6 | 7 | 7 |
| -Ha H-Ha | al-Hasab | 5 | 5 | 6 | 6 | 7 | 7 |
| а | al-Ruhail | 32 | 36 | 39 | 42 | 46 | 49 |
| Azraq District | Azraq | 870 | 975 | 1,070 | 1,162 | 1,254 | 1,346 |
| | King Addullan Bin Addul Aziz City | | 5,000 | 13,500 | 23,000 | 34,000 | 45,040 |

| Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|---------------|--------|---------|---------|---------|---------|---------|
| al-Majd City | | 3,180 | 4,240 | 4,240 | 4,240 | 4,240 |
| Total | 90,578 | 105,673 | 120,279 | 134,683 | 149,891 | 164,837 |

Table 2: Wastewater Generation Distribution Projections (m³/day)

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|------------|---|-------|-------|-------|-------|-------|-------|
| <u>ici</u> | al-Tafeh | 58 | 65 | 71 | 78 | 84 | 90 |
| Distr | al-Rukban | 15 | 17 | 18 | 20 | 21 | 23 |
| rqa [| Khaw | 31 | 35 | 38 | 41 | 45 | 48 |
| Zaı | al-Farwaniyeh | 9 | 10 | 11 | 12 | 13 | 14 |
| | Hai al-Hadiqa | 355 | 373 | 382 | 392 | 402 | 412 |
| | Hai al-Nuzha | 567 | 611 | 642 | 675 | 692 | 710 |
| | Hai al-Hussein | 1,749 | 1,749 | 1,749 | 1,749 | 1,749 | 1,749 |
| | Hai al-Wasat al-Tijary | 1,466 | 1,541 | 1,579 | 1,619 | 1,659 | 1,659 |
| | Hai al-Nasr | 1,155 | 1,155 | 1,155 | 1,155 | 1,155 | 1,155 |
| | Hai Ramzi | 2,717 | 2,856 | 2,928 | 3,002 | 3,061 | 3,061 |
| | Hai Shaker | 1,083 | 1,138 | 1,167 | 1,197 | 1,227 | 1,258 |
| | Hai al-Basateen | 415 | 525 | 624 | 716 | 782 | 802 |
| | Hai Ma'soum | 2,129 | 2,238 | 2,295 | 2,353 | 2,412 | 2,473 |
| | Hai al-Hashemi | 400 | 506 | 601 | 690 | 754 | 816 |
| | Hai al-Ghweireyeh | 2,583 | 2,583 | 2,583 | 2,583 | 2,583 | 2,583 |
| | Hai al-Ameer Mohammad | 1,368 | 1,438 | 1,474 | 1,512 | 1,550 | 1,589 |
| | Hai al-Shyoukh | 791 | 831 | 852 | 874 | 896 | 919 |
| Ę | Hai Barakh | 669 | 703 | 721 | 739 | 758 | 777 |
| ipali | Hai Ibn Sina | 582 | 612 | 627 | 643 | 659 | 676 |
| unic | Hai al-Iskan | 353 | 370 | 380 | 389 | 399 | 409 |
| a M | Hai al-Dhubbat | 383 | 402 | 412 | 423 | 433 | 444 |
| Zarc | Hai al-Janna'a | 1,848 | 1,942 | 1,991 | 2,041 | 2,093 | 2,146 |
| | Hai al-Thawra al-Arabiyah al- Kubrah | 1,920 | 2,017 | 2,068 | 2,121 | 2,174 | 2,229 |
| | Hai al-Jundi | 488 | 513 | 526 | 539 | 553 | 567 |
| | Hai al-Masane'e | 209 | 225 | 236 | 248 | 255 | 261 |
| | Hai Tarwq Bin Zeyad | 570 | 599 | 614 | 629 | 645 | 658 |
| | Hai Tarwq Bin Zeyad | 560 | 560 | 560 | 560 | 560 | 560 |
| | Hai al-Ameer Hamzah | 1,092 | 1,147 | 1,176 | 1,206 | 1,236 | 1,268 |
| | Hai al-Jabal al-Abyad | 1,408 | 1,480 | 1,518 | 1,556 | 1,595 | 1,636 |
| | Hai al-Ameera Rahmah | 884 | 929 | 952 | 976 | 1,001 | 1,026 |
| | Hai al-Ameer Hassan | 1,006 | 1,057 | 1,084 | 1,111 | 1,139 | 1,168 |
| | Hai al-Malek Talal | 1,229 | 1,292 | 1,324 | 1,358 | 1,392 | 1,427 |
| | Hai Awajan | 145 | 157 | 165 | 173 | 177 | 182 |
| | Hai al-Falah | 787 | 848 | 892 | 937 | 961 | 985 |
| | Hai Umm Bayadhah | 958 | 1,212 | 1,440 | 1,652 | 1,806 | 1,954 |

Table 2: Wastewater Generation Distribution Projections (m³/day)

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|-------|---------------------------------|-------|-------|-------|-------|-------|-------|
| | Hai al-Dweik | 653 | 826 | 981 | 1,125 | 1,230 | 1,331 |
| | Hai al-Madina al-Munawara | 286 | 362 | 431 | 494 | 540 | 584 |
| | Hai Makka al-Mukarramah | 278 | 352 | 419 | 480 | 525 | 568 |
| | Hai al-Ahmad | 322 | 408 | 485 | 556 | 608 | 658 |
| | Hai Nassar | 572 | 724 | 860 | 987 | 1,079 | 1,167 |
| | Hai al-Zawahreh | 1,594 | 1,676 | 1,718 | 1,761 | 1,806 | 1,851 |
| > | Hai al-Qamar | 303 | 318 | 326 | 335 | 343 | 352 |
| palit | Hai Qurtuba | 318 | 334 | 342 | 351 | 360 | 369 |
| Inici | Hai al-Jneineh | 294 | 372 | 441 | 507 | 554 | 599 |
| a Mu | Hai al-Jabr | 463 | 585 | 695 | 798 | 872 | 944 |
| arq | Hai al-Ameera Haya | 1,159 | 1,467 | 1,743 | 1,999 | 2,186 | 2,365 |
| N | Hai Shomar | 261 | 330 | 392 | 450 | 492 | 532 |
| | Hai al-Bustan | 348 | 440 | 523 | 600 | 656 | 710 |
| | Hai al-Zarqa'a al-Jadida | 2,243 | 2,357 | 2,417 | 2,478 | 2,541 | 2,605 |
| | Hai al-Batrawi | 2,568 | 3,250 | 3,861 | 4,430 | 4,843 | 5,240 |
| | Hai al-Hirafyeen | 3 | 3 | 3 | 3 | 3 | 3 |
| | Hai al-Hashemeyah al-Janoubiyah | 445 | 467 | 479 | 491 | 504 | 516 |
| | Hai Ma'amel al-Toub | 20 | 20 | 20 | 20 | 20 | 20 |
| | Birein | 98 | 110 | 121 | 132 | 142 | 152 |
| | Umm Rummaneh | 90 | 101 | 110 | 120 | 129 | 139 |
| | al-Kamsha | 104 | 117 | 128 | 139 | 150 | 161 |
| | al-Alouk | 53 | 59 | 65 | 71 | 76 | 82 |
| | Hai Sarout | 99 | 111 | 122 | 132 | 143 | 153 |
| | Marhab | 54 | 61 | 67 | 72 | 78 | 84 |
| | Rujm al-Shok | 58 | 65 | 71 | 77 | 83 | 90 |
| lict | al-Naseriyah | 43 | 48 | 52 | 57 | 61 | 66 |
| Dist | al-Mikman | 41 | 46 | 50 | 55 | 59 | 63 |
| ein | al-Masarrah al-Sharqiyah | 30 | 34 | 37 | 40 | 43 | 47 |
| Ë | al-Masarrah al-Gharbiya | 36 | 41 | 44 | 48 | 52 | 56 |
| | al-Makhdat | 2 | 2 | 2 | 3 | 3 | 3 |
| | al-Khillah | 20 | 22 | 24 | 26 | 29 | 31 |
| | Maqam Eisa | 44 | 49 | 54 | 58 | 63 | 68 |
| | Ein Saber | 49 | 55 | 60 | 65 | 71 | 76 |
| | al-Bireh | 28 | 31 | 34 | 37 | 40 | 43 |
| | al-Riyadh | 37 | 41 | 45 | 49 | 53 | 57 |
| | al-Sahhara | 5 | 5 | 6 | 6 | 7 | 7 |

Table 2: Wastewater Generation Distribution Projections (m³/day)

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|-----------|--------------------------------|-------|-------|-------|-------|-------|-------|
| | al-Ouweillieh | 12 | 13 | 14 | 16 | 17 | 18 |
| <u>ci</u> | Wadi Suwwan | 17 | 20 | 21 | 23 | 25 | 27 |
| Distr | Umm Fatyer | 8 | 10 | 10 | 11 | 12 | 13 |
| ein [| Ein al-Hawaya | 7 | 8 | 8 | 9 | 10 | 11 |
| Bir | Umm Khasheibah | 30 | 33 | 36 | 40 | 43 | 46 |
| | Umm al-Biyar | 35 | 39 | 43 | 46 | 50 | 54 |
| | al-Dhuleil | 2,318 | 2,600 | 2,852 | 3,099 | 3,344 | 3,589 |
| rict | Qasr al-Hallabat al-Sharqi | 153 | 171 | 188 | 204 | 221 | 237 |
| Dist | Qasr al-Hallabat al-Gharbi | 206 | 231 | 254 | 276 | 298 | 319 |
| uleil | al-Deheitem | 22 | 24 | 27 | 29 | 31 | 33 |
| Ρ̈́ | Sayeh Diyab | 23 | 26 | 28 | 31 | 33 | 35 |
| | Mazare'e Hallabat | 12 | 14 | 15 | 17 | 18 | 19 |
| | Hai Awajan al-Shamali | 24 | 24 | 24 | 24 | 24 | 24 |
| | Hai Umm Jarada | 19 | 19 | 19 | 19 | 19 | 19 |
| | Hai al-Jundi | 405 | 436 | 459 | 482 | 494 | 507 |
| | Hai al-Ameer Ali | 423 | 445 | 456 | 468 | 479 | 492 |
| | Hai Kharrouba al-Sharqi | 27 | 27 | 27 | 27 | 27 | 27 |
| | Hai Kharrouba al-Gharbi | 23 | 30 | 35 | 40 | 44 | 48 |
| | Hai al-Arateqa | 825 | 867 | 889 | 912 | 935 | 958 |
| | Hai al-Arab | 486 | 511 | 523 | 537 | 550 | 564 |
| | Hai al-Hussein | 878 | 878 | 878 | 878 | 878 | 878 |
| lity | Hai al-Jabal al-Shamali | 2,956 | 3,107 | 3,185 | 3,265 | 3,348 | 3,432 |
| cipa | Hai al-Khalediyah | 362 | 380 | 390 | 400 | 410 | 420 |
| Juni | Hai al-Qadessiyah | 2,251 | 2,366 | 2,426 | 2,487 | 2,550 | 2,614 |
| ifa N | Hai Awajan al-Gharbi | 1,353 | 1,422 | 1,458 | 1,495 | 1,533 | 1,572 |
| əssr | Hai Umm Jarada al-Shamali | 606 | 636 | 653 | 669 | 686 | 703 |
| R | Hai Umm Jarada al-Gharbi | 400 | 420 | 431 | 442 | 453 | 464 |
| | Hai al-Daheriyah | 469 | 469 | 469 | 469 | 469 | 469 |
| | Hai Iskan al-Ameer Talal | 369 | 369 | 369 | 369 | 369 | 369 |
| | Hai al-Razi | 191 | 201 | 206 | 211 | 217 | 222 |
| | Hai al-Tatweer al-Hadari | 1,649 | 1,649 | 1,649 | 1,649 | 1,649 | 1,649 |
| | al-Mustashfa | 6 | 7 | 7 | 8 | 9 | 9 |
| | Hai al-Rasheed al-Janoubi | 759 | 798 | 818 | 839 | 860 | 882 |
| | Hai al-Hurriyah | 235 | 239 | 239 | 239 | 239 | 239 |
| | Hai Ja'far al-Tayar al-Janoubi | 115 | 124 | 131 | 137 | 141 | 144 |
| | Hai Ja'far al-Tayar | 720 | 757 | 776 | 796 | 816 | 837 |

| Table 2: Wastewater Generation | Distribution | Projections | (m ³ /day) |
|---------------------------------------|--------------|-------------|-----------------------|
|---------------------------------------|--------------|-------------|-----------------------|

| | Neighbourhood | 2010 | 2015 | 2020 | 2025 | 2030 | 2035 |
|-------------------|-----------------------------------|--------|--------|---------|---------|---------|---------|
| | Hai al-Rasheed al-Shamali | 1,127 | 1,185 | 1,215 | 1,245 | 1,277 | 1,309 |
| | Hai Jraiba | 233 | 261 | 286 | 311 | 335 | 360 |
| | Hai al-Ghaidaniyah | 42 | 53 | 64 | 73 | 80 | 86 |
| | Hai Ein Shabwa | 23 | 29 | 34 | 39 | 42 | 46 |
| | Hai al-Msheirfah | 1,132 | 1,190 | 1,220 | 1,251 | 1,282 | 1,315 |
| ality | Hai al-Msheirfah al-Gharbi | 277 | 291 | 298 | 306 | 314 | 322 |
| nicip | Hai al-Msheirfah al-Janoubi | 310 | 326 | 334 | 342 | 351 | 360 |
| Mul | Hai al-Iskanat | 824 | 866 | 888 | 911 | 934 | 957 |
| eifa | Hai Abu Ghalyoon | 272 | 293 | 308 | 324 | 332 | 341 |
| Suss | Hai Jabal al-Ameer Faisal | 1,776 | 1,867 | 1,914 | 1,962 | 2,012 | 2,063 |
| - | Hai al-Wananat | 58 | 58 | 58 | 58 | 58 | 58 |
| | Theodor Shneller | 8 | 9 | 10 | 11 | 11 | 12 |
| | Hai al-Fakhourah | 215 | 215 | 215 | 215 | 215 | 215 |
| | Hai Abu Sayyah | 168 | 188 | 206 | 224 | 242 | 260 |
| | Hai Hitteen Camp | 3,715 | 3,905 | 4,004 | 4,105 | 4,208 | 4,226 |
| | Hai al-Hashemiyah | 1,775 | 1,866 | 1,913 | 1,961 | 2,011 | 2,061 |
| н Н | Hai Iskan al-Hashemiyah | 577 | 606 | 622 | 637 | 654 | 670 |
| istric | Hai al-Fayha'a | 106 | 112 | 114 | 117 | 120 | 123 |
| Π | al-Sukhneh | 1,330 | 1,492 | 1,636 | 1,778 | 1,918 | 2,059 |
| niya | Abu al-Zeighan | 178 | 200 | 219 | 238 | 257 | 276 |
| sher | Dogara | 157 | 176 | 193 | 209 | 226 | 243 |
| I-Ha | Ein al-Nimra | 11 | 12 | 14 | 15 | 16 | 17 |
| а | Ghareisa | 56 | 63 | 69 | 75 | 81 | 87 |
| | Umm Suleih | 179 | 201 | 221 | 240 | 259 | 278 |
| ч | al-Ghuneiyah | 46 | 52 | 57 | 62 | 67 | 71 |
| niya | Daba'an | 20 | 23 | 25 | 27 | 29 | 32 |
| sher | Tawaheen al-Adwan | 4 | 4 | 5 | 5 | 6 | 6 |
| -Ha: | al-Hasab | 4 | 4 | 5 | 5 | 6 | 6 |
| ื่อ | al-Ruhail | 28 | 31 | 34 | 37 | 40 | 43 |
| Azraq District | Azraq | 757 | 849 | 931 | 1,011 | 1,091 | 1,171 |
| | King Abdullah Bin Abdul Aziz City | | 4,350 | 11,745 | 20,010 | 29,580 | 39,185 |
| | al-Majd City | | 2,767 | 3,689 | 3,689 | 3,689 | 3,689 |
| | Total | 78,803 | 91,935 | 104,643 | 117,175 | 130,406 | 143,408 |

TOPOGRAPHICAL SURVEY OF MAIN SEWER APPENDIX 6 SYSTEM

| T I I 4 | | |
|----------------|--------------|---------|
| l able 1 | Important Un | lopened |

d Manholes above 200 mm Dia. P ۱ŀ

| Zone | Line Name | Manhole Name | Easting | Northing | Elevation | Remarks |
|------|-----------|--------------|-----------|-----------|-----------|-----------------------------|
| EZ | 400-1 | 400-1-14 | 255453.41 | 169018.33 | 538.82 | Manhole cover flipped over |
| EZ | 700-1 | 700-1-13 | 255246.58 | 170997.72 | 517.51 | Manhole cover flipped over |
| ΕZ | 700-1 | 700-1-17 | 255456.48 | 170822.50 | 519.37 | Covered by concrete |
| EZ | 800 -1 | 800-1-19 | 255101.56 | 168884.26 | 554.75 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-20 | 255077.26 | 168806.43 | 555.96 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-21 | 255055.97 | 168731.80 | 555.58 | Covered by concrete |
| EZ | 800 -1 | 800-1-37 | 254908.17 | 167576.61 | 555.88 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-39 | 254910.44 | 167417.65 | 558.02 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-40 | 254910.76 | 167336.36 | 560.30 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-41 | 254910.74 | 167279.46 | 561.91 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-43 | 254894.71 | 167084.62 | 563.67 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-44 | 254882.39 | 167022.70 | 563.98 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-45 | 254870.42 | 166957.98 | 564.29 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-47 | 254837.34 | 166763.18 | 565.31 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-48 | 254825.40 | 166700.20 | 565.61 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-49 | 254814.25 | 166640.45 | 566.09 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-50 | 254800.49 | 166555.39 | 567.09 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-51 | 254792.28 | 166510.54 | 567.84 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-52 | 254788.30 | 166487.89 | 568.11 | Could not be opened (stuck) |
| EZ | 800 -1 | 800-1-7 | 255293.68 | 170948.20 | 517.98 | Could not be opened (stuck) |
| WZ | 300-17 | 300-17-10 | 251748.90 | 164235.40 | 580.90 | Could not be opened (stuck) |
| WZ | 300-17 | 300-17-11 | 251780.60 | 164235.88 | 586.16 | Could not be opened (stuck) |
| WZ | 300-17 | 300-17-12 | 251797.68 | 164236.51 | 588.39 | Could not be opened (stuck) |
| WZ | 300-17 | 300-17-13 | 251832.53 | 164248.70 | 589.92 | Could not be opened (stuck) |
| WZ | 300-17 | 300-17-7 | 251651.67 | 164265.81 | 561.51 | Could not be opened (stuck) |
| WZ | 300-17 | 300-17-8 | 251683.62 | 164253.88 | 567.88 | Could not be opened (stuck) |
| WZ | 300-17 | 300-17-9 | 251731.09 | 164238.12 | 577.28 | Could not be opened (stuck) |
| WZ | 300-21 | 300-21-1 | 251632.86 | 163486.57 | 558.99 | Manhole cover flipped over |
| WZ | 300-D | 300-D-7 | 250575.96 | 158840.42 | 601.83 | Could not be opened (stuck) |
| WZ | 400-A | 1000-1-26 | 251639.65 | 163702.15 | 544.45 | Covered by concrete |
| WZ | 400-A | 400-A-35 | 252741.85 | 162169.82 | 565.94 | Covered by back fill |
| WZ | 400-A | 400-A-38 | 252751.71 | 161979.28 | 567.17 | Covered by back fill |
| WZ | 400-A | 400-A-7 | 252076.96 | 163352.03 | 550.62 | Could not be opened (stuck) |
| WZ | 400-A | 400-A-9 | 252197.28 | 163301.29 | 555.59 | Covered by a large rock |
| WZ | 500-5 | 500-5-1 | 244542.50 | 157943.64 | 658.87 | Covered by concrete |
| WZ | 500-5 | 500-5-10 | 244554.56 | 157559.61 | 660.63 | Covered by concrete |
| WZ | 500-5 | 500-5-11 | 244540.94 | 157515.45 | 660.93 | Covered by concrete |
| WZ | 500-5 | 500-5-12 | 244528.47 | 157494.89 | 661.04 | Covered by concrete |

| Zone | Line Name | Manhole Name | Easting | Northing | Elevation | Remarks |
|------|-----------|--------------|-----------|-----------|-----------|-------------------------|
| WZ | 500-5 | 500-5-2 | 244540.15 | 157896.70 | 659.44 | Covered by concrete |
| WZ | 500-C | 500-C-1 | 251691.45 | 163656.27 | 544.79 | Covered by concrete |
| WZ | 500-C | 500-C-10 | 252034.20 | 163335.13 | 549.05 | Covered by concrete |
| WZ | 500-C | 500-C-11 | 252066.77 | 163325.29 | 549.46 | Covered by concrete |
| WZ | 500-C | 500-C-12 | 252094.60 | 163318.86 | 550.59 | Covered by concrete |
| WZ | 500-C | 500-C-13 | 252119.71 | 163311.53 | 550.09 | Covered by concrete |
| WZ | 500-C | 500-C-15 | 252146.51 | 163288.79 | 550.20 | Covered by concrete |
| WZ | 500-C | 500-C-16 | 252166.40 | 163265.84 | 550.35 | Covered by a large rock |
| WZ | 500-C | 500-C-17 | 252227.09 | 163209.55 | 551.62 | Covered by a large rock |
| WZ | 500-C | 500-C-2 | 251745.14 | 163610.19 | 545.36 | Covered by a concrete |
| WZ | 500-C | 500-C-3 | 251800.23 | 163570.24 | 545.70 | Covered by a concrete |
| WZ | 500-C | 500-C-4 | 251844.03 | 163525.70 | 546.29 | Covered by a concrete |
| WZ | 500-C | 500-C-5 | 251870.36 | 163486.50 | 546.78 | Covered by a concrete |
| WZ | 500-C | 500-C-6 | 251907.81 | 163427.69 | 547.75 | Covered by a concrete |
| WZ | 500-C | 500-C-7 | 251953.80 | 163377.40 | 548.21 | Covered by a concrete |
| WZ | 500-C | 500-C-8 | 251997.64 | 163353.59 | 548.43 | Covered by a concrete |
| WZ | 500-C | 500-C-9 | 252005.87 | 163344.20 | 548.21 | Covered by a concrete |
| WZ | 800-A | 800-A-10 | 252020.91 | 163300.22 | 550.13 | Covered by back fill |
| WZ | 800-A | 800-A-11 | 252088.02 | 163283.33 | 550.93 | Covered by back fill |
| WZ | 800-A | 800-A-13 | 252191.96 | 163194.66 | 552.41 | Covered by back fill |
| WZ | 800-A | 800-A-8 | 251910.23 | 163368.43 | 550.44 | Covered by back fill |
| WZ | 800-B | 800-B-166 | 245314.59 | 158483.59 | 648.59 | Covered by a concrete |
| WZ | 800-B | 800-B-171 | 245141.95 | 158392.51 | 651.22 | Covered by a concrete |
| WZ | 800-B | 800-B-172 | 245087.71 | 158365.42 | 652.34 | Covered by a concrete |
| WZ | 800-B | 800-B-177 | 244831.55 | 158288.01 | 654.70 | Covered by a large rock |
| WZ | 800-B | 800-B-178 | 244798.13 | 158278.10 | 655.31 | Covered by a large rock |
| WZ | 800-B | 800-B-180 | 244743.63 | 158239.33 | 655.53 | Covered by a large rock |
| WZ | 800-B | 800-B-181 | 244715.14 | 158215.71 | 655.84 | Covered by a large rock |
| WZ | 800-B | 800-B-183 | 244671.04 | 158159.46 | 656.24 | Covered by a large rock |
| WZ | 800-B | 800-B-186 | 244597.60 | 158004.68 | 657.99 | Covered by a large rock |
| WZ | 800-B | 800-B-188 | 244566.89 | 157913.46 | 658.48 | Covered by a large rock |
| WZ | 800-B | 800-B-189 | 244549.24 | 157865.54 | 658.04 | Covered by a large rock |
| WZ | 800-B | 800-B-191 | 244571.87 | 157746.73 | 659.11 | Covered by a large rock |
| WZ | 800-B | 800-B-194 | 244570.27 | 157599.66 | 661.13 | Covered by a large rock |
| WZ | 800-B | 800-B-195 | 244563.79 | 157557.18 | 661.31 | Covered by a large rock |
| WZ | 800-B | 800-B-196 | 244549.47 | 157522.80 | 661.79 | Covered by a large rock |
| WZ | 800-B | 800-B-198 | 244506.34 | 157439.95 | 662.40 | Covered by a large rock |
| WZ | 800-B | 800-B-199 | 244497.77 | 157434.36 | 662.28 | Covered by a large rock |

APPENDIX 7 FLOW MONITORING DATA

| Manhole Ref. No. : | MH-2 | | | | Pipe | e Dia. : 400 m | m | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|-------------------------|------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | South East of | of Zarqa West | P.S. | | | | | | |
| Period : | From Monda | y, Feb. 15, 20 | 010 03:59 PM | till | Mor | nday, Feb. 22, | 2010 03:14 F | M | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursd Frida | ay / Iy | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 03:59 PM to 03:54 PM | 03:59 PM to 03:54 PM | 03:59 PM to 03:54 PM | 03:59 l to 03: PM | PM 54 | 03:59 PM to 03:54 PM | 03:59 PM to 03:54 PM | 03:59 PM to 03:54 PM | 03:59 PM to 03:54 PM |
| Min. Daily Flow (m3/hr.) | 48.42 | 53.91 | 55.92 | 64.4 | 7 | 64.07 | 67.64 | 48.02 | 48.02 |
| Max. Daily Flow (m3/hr.) | 279.84 | 303.92 | 325.84 | 413.6 | 64 | 336.14 | 277.64 | 250.46 | 413.64 |
| Ave. Daily Flow (m3/hr.) | 150.06 | 152.84 | 163.68 | 193.3 | 81 | 180.43 | 154.24 | 135.80 | 161.58 |
| Ave. Total Daily Flow (m3/day) | 3,601.50 | 3,668.06 | 3,928.37 | 4,639. | 35 | 4,330.43 | 3,701.67 | 3,259.32 | 3,877.98 |

| Manhole Ref. No. : | MH-3 | | | | Pipe Di | ia: 240 mm | | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|--------------|----------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | South of Zar | qa West P.S. | | | | | | | |
| Period : | From Wedne | esday, Feb. 17 | 7, 2010 14:29 | PM | till | Thursday, Fe | eb. 18, 2010 1 | 4:24 PM | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thu Fr | rsday / iday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 14:29 PM to 14:24 PM | 14:29 PM to 14:24 PM | 14:29 PM to 14:24 PM | 14:2 to 7 | 29 PM 14:24 PM | 14:29 PM to 14:24 PM | 14:29 PM to 14:24 PM | 14:29 PM to 14:24 PM | 14:29 PM to 14:24 PM |
| Min. Daily Flow (m3/hr.) | 25.15 | 22.31 | 22.62 | 0 | .00 | | | | 22.31 |
| Max. Daily Flow (m3/hr.) | 82.62 | 78.49 | 82.56 | 0 | .00 | | | | 82.62 |
| Ave. Daily Flow (m3/hr.) | 46.55 | 46.65 | 43.25 | | | | | | 45.48 |
| Ave. Total Daily Flow (m3/day) | 1,117.21 | 1,119.52 | 1,037.93 | | | | | | 1,091.56 |

| Manhole Ref. No. : | MH-4 | | | | Pipe | e Dia: 800 mm | l | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|--------------------------|-----------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Mushairfeh - | - Russeifa | | | | | | | |
| Period : | From Monda | ay, Mar. 15, 20 | 010 4:04 PM | till | Mono | day, Mar. 22, 2 | 2010 03:44 PN | Л | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursda Frida | ay / y | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 04:04 PM to 03:59 PM | 04:04 PM to 03:59 PM | 04:04 PM to 03:59 PM | 04:04 F to 03:5 PM | РМ 59 | 04:04 PM to 03:59 PM | 04:04 PM to 03:59 PM | 04:04 PM to 03:44 PM | 04:04 PM to 03:59 PM |
| Min. Daily Flow (m3/hr.) | 63.25 | 52.53 | 78.39 | 92.8 ⁻ | 1 | 62.35 | 64.21 | 42.79 | 42.79 |
| Max. Daily Flow (m3/hr.) | 370.47 | 503.04 | 417.14 | 655.1 | 7 | 499.37 | 377.79 | 394.65 | 655.17 |
| Ave. Daily Flow (m3/hr.) | 203.79 | 192.41 | 230.56 | 283.3 | 0 | 221.73 | 208.67 | 183.99 | 217.83 |
| Ave. Total Daily Flow (m3/day) | 4,890.86 | 4,617.95 | 5,533.37 | 6,799. | 26 | 5,321.55 | 5,008.14 | 4,415.71 | 5,227.90 |

| Manhole Ref. No. : | MH-5 | | | | Pipe Dia. : 8 | 00 mm | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Russeifa | | | | | | | |
| Period : | From Monda | ıy, Mar. 08, 20 | 010 12:10 PM | till Mor | nday, Mar. 15, | 2010 10:45 A | M | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursday / Friday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 12:10 PM to 12:05 PM | 12:10 PM to 10:45 PM | 12:10 PM to 12:05 PM |
| Min. Daily Flow (m3/hr.) | 1,461.06 | 386.84 | 811.51 | 559.23 | 304.42 | 237.99 | 1,413.13 | 237.99 |
| Max. Daily Flow (m3/hr.) | 2,625.00 | 2,732.91 | 2,704.68 | 2,866.34 | 3,571.46 | 5,583.89 | 5,508.72 | 5,583.89 |
| Ave. Daily Flow (m3/hr.) | 2,105.04 | 2,017.90 | 2,047.46 | 1,968.75 | 1,586.77 | 1,780.57 | 1,977.44 | 1,926.23 |
| Ave. Total Daily Flow (m3/day) | 50,521.03 | 48,429.53 | 49,139.00 | 47,249.90 | 38,082.37 | 42,733.80 | 47,458.47 | 46,229.50 |

| Manhole Ref. No. : | MH-6 | | | | Pipe Dia: 70 | 0 mm | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Marka - Nea | r Bridge | | | | | | |
| Period : | From Sunda | y Feb. 21, 20 [.] | 10 04:00 PM | till Sund | day Feb. 28, 2 | 010 04:45 PM | | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursday / Friday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 04:00 PM to 03:55 PM |
| Min. Daily Flow (m3/hr.) | 46.50 | 39.15 | 33.90 | 57.08 | 201.15 | 61.93 | 26.65 | 26.65 |
| Max. Daily Flow (m3/hr.) | 270.14 | 277.69 | 279.87 | 395.83 | 389.00 | 534.99 | 470.85 | 534.99 |
| Ave. Daily Flow (m3/hr.) | 170.26 | 173.45 | 172.65 | 194.82 | 320.70 | 228.15 | 81.56 | 191.66 |
| Ave. Total Daily Flow (m3/day) | 4,086.32 | 4,162.85 | 4,143.61 | 4,675.68 | 7,696.80 | 5,475.64 | 1,957.40 | 4,599.76 |

| Manhole Ref. No. : | MH-7 | | | | Pipe Dia. : 8 | 00 mm | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Marka | | | | | | | |
| Period : | From Monda | iy, Feb. 22, 20 | 010 05:02 PM | till Mor | nday, Mar. 01, | 2010 02:02 F | M | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursday / Friday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 05:02 PM to 04:57 PM | 05:02 PM to 02:02 PM | 05:02 PM to 04:57 PM |
| Min. Daily Flow (m3/hr.) | 14.99 | 14.31 | 17.00 | 31.15 | 101.15 | 0.00 | 24.95 | 0.00 |
| Max. Daily Flow (m3/hr.) | 57.15 | 58.99 | 105.80 | 351.37 | 338.87 | 633.75 | 415.03 | 633.75 |
| Ave. Daily Flow (m3/hr.) | 34.64 | 35.86 | 38.75 | 119.20 | 171.99 | 148.86 | 74.78 | 89.41 |
| Ave. Total Daily Flow (m3/day) | 831.26 | 860.56 | 930.00 | 2,860.90 | 4,127.71 | 3,572.71 | 1,794.66 | 2,145.78 |

| Manhole Ref. No. : | MH-8 | | | | Pipe Dia. : 7 | 00 mm | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Marka | | | | | | | |
| Period : | From Monda | ay, Mar. 08, 20 | 010 10:07 AM | l till Mor | nday, Mar. 15, | 2010 09:57 A | M | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursday / Friday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 10:07 AM to 10:02 AM | 10:07 AM to 09:57 AM | 10:07 AM to 10:02 AM |
| Min. Daily Flow (m3/hr.) | 196.82 | 187.98 | 169.31 | 149.99 | 143.92 | 156.55 | 146.48 | 143.92 |
| Max. Daily Flow (m3/hr.) | 293.87 | 303.64 | 493.35 | 279.24 | 323.52 | 318.77 | 277.53 | 493.35 |
| Ave. Daily Flow (m3/hr.) | 252.48 | 253.44 | 256.81 | 226.68 | 218.98 | 240.48 | 219.62 | 238.37 |
| Ave. Total Daily Flow (m3/day) | 6,059.52 | 6,082.61 | 6,163.43 | 5,440.39 | 5,255.62 | 5,771.59 | 5,270.95 | 5,720.81 |

| Manhole Ref. No. : | MH-9 | | | | Pipe Dia. : 3 | 00 mm | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Next to Zarq | a East P.S. | | | | | | |
| Period : | From Sunda | y, Feb. 14, 20 | 10 16:31 PM | till Sund | ay Feb. 21, 20 |)10 14:26 PM | | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursday / Friday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 16:31 PM to 16:26 PM | 16:31 PM to 14:26 PM | 16:31 PM to 14:26 AM |
| Min. Daily Flow (m3/hr.) | 19.76 | 12.32 | 11.45 | 13.20 | 15.82 | 14.18 | 12.78 | 11.45 |
| Max. Daily Flow (m3/hr.) | 92.74 | 131.15 | 90.63 | 101.24 | 154.53 | 143.43 | 126.16 | 154.53 |
| Ave. Daily Flow (m3/hr.) | 57.22 | 59.02 | 54.79 | 57.32 | 64.96 | 58.49 | 49.94 | 58.31 |
| Ave. Total Daily Flow (m3/day) | 1,373.36 | 1,416.58 | 1,314.87 | 1,375.62 | 1,559.14 | 1,403.73 | 1,198.53 | 1,399.34 |

| Manhole Ref. No. : | MH-10 | | | | Pipe Dia. : 8 | 00 mm | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | South of Zar | qa West P.S. | | | | | | |
| Period : | From Sunda | y, Feb. 07, 20 | 10 6:00 PM t | ill Sunday F | eb. 14, 2010 | 4:00 PM | | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursday / Friday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 14:29 PM to 14:24 PM |
| Min. Daily Flow (m3/hr.) | 219.15 | 188.42 | 203.82 | 262.93 | 199.88 | 205.41 | 189.35 | 188.42 |
| Max. Daily Flow (m3/hr.) | 815.29 | 816.91 | 871.68 | 980.49 | 882.03 | 807.26 | 750.17 | 980.49 |
| Ave. Daily Flow (m3/hr.) | 483.32 | 497.38 | 520.99 | 584.37 | 518.90 | 499.67 | 443.92 | 505.98 |
| Ave. Total Daily Flow (m3/day) | 11,599.66 | 11,937.22 | 12,503.65 | 14,024.97 | 12,453.58 | 11,991.97 | 10,654.05 | 12,143.49 |

| Manhole Ref. No. : | MH-11 | | | | Pipe Dia. : 460 mm | | | |
|-----------------------------------|---|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Zarqa Power Station - Line from Free Zone | | | | | | | |
| Period : | From Sunday, Feb. 07, 2010 11:50 AM till Thursday, Feb. 14, 2010 11:50 AM | | | | | | | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursday / Friday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 11:50 AM to 11:45 AM | 11:50 AM to 11:45 AM | 11:50 AM to 11:45 AM | 11:50 AM to 11:45 AM | 11:50 AM to 11:45 AM | 11:50 AM to 11:45 AM | 11:50 AM to 11:45 AM | 11:50 AM to 11:45 AM |
| Min. Daily Flow (m3/hr.) | 63.29 | 81.45 | 56.90 | 50.29 | 52.56 | 49.42 | 33.89 | 33.89 |
| Max. Daily Flow (m3/hr.) | 235.37 | 235.72 | 260.15 | 233.40 | 246.71 | 305.01 | 158.87 | 305.01 |
| Ave. Daily Flow (m3/hr.) | 142.95 | 147.51 | 139.50 | 116.22 | 99.72 | 91.37 | 99.16 | 119.49 |
| Ave. Total Daily Flow (m3/day) | 3430.75 | 3540.29 | 3348.05 | 2,789.24 | 2,393.21 | 2,192.78 | 2,379.74 | 2,867.72 |

Preparatory Works Technical Report

| Manhole Ref. No. : | MH-12 | | | | Pipe Dia. : 700 mm | | | |
|-----------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|------------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Al Jaish Str. | | | | | | | |
| Period : | From Monda | ay, Mar. 01, 20 | 010 03:02 PM | l till Mor | nday, Mar. 08, 2010 08:28 AM | | | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursday / Friday | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 03:02 PM to 02:57 PM | 03:02 PM to 02:57 PM | 03:02 PM to 08:27 AM | 03:02 PM to 02:57 PM |
| Min. Daily Flow (m3/hr.) | 61.73 | 75.95 | 104.42 | 128.20 | 80.98 | 77.01 | 65.16 | 61.73 |
| Max. Daily Flow (m3/hr.) | 244.08 | 216.23 | 275.40 | 347.26 | 258.03 | 222.37 | 201.82 | 347.26 |
| Ave. Daily Flow (m3/hr.) | 142.76 | 151.00 | 179.23 | 216.79 | 165.51 | 159.52 | 128.23 | 164.70 |
| Ave. Total Daily Flow (m3/day) | 3,426.30 | 3,623.95 | 4,301.56 | 5,203.00 | 3,972.18 | 3,828.59 | 3,077.48 | 3,952.88 |

| Manhole Ref. No. : | Zarqa WEST PS | | | | Open Channel (Width): 1100 - 1000 mm | | | | |
|-----------------------------------|---|----------------------------|----------------------------|----------------------------|--------------------------------------|----------------------------|----------------------------|----------------------------|----------------------------|
| Location : | Zarqa WEST PS | | | | | | | | |
| Period : | From Monday, Mar. 01, 2010 08:34 AM till Monday, Mar. 08, 2010 07:29 AM | | | | | | | | |
| Day | Monday / Tuesday | Tuesday / Wed | Wed / Thursday | Thursda Frida | ay / y | Friday / Saturday | Saturday / Sunday | Sunday / Monday | Period - Week |
| Time | 08:32 AM to 08:29 AM | 08:34 AM to 08:29 AM | 08:34 AM to 08:29 AM | 08:34 AM to 08:29 AM | | 08:34 AM to 08:29 AM | 08:34 AM to 08:29 AM | 08:34 AM to 07:29 AM | 08:34 AM to 08:29 AM |
| Min. Daily Flow (m3/hr.) | 1904.63 | 1415.53 | 1756.12 | 1,554.38 | | 1,563.40 | 1,804.68 | 891.77 | 891.77 |
| Max. Daily Flow (m3/hr.) | 3824.14 | 2726.73 | 3289.05 | 3,002.42 | | 3,383.01 | 3,378.98 | 3,096.80 | 3,824.14 |
| Ave. Daily Flow (m3/hr.) | 2780.23 | 2185.71 | 2532.69 | 2,425.18 | | 2,513.22 | 2,669.52 | 1,992.95 | 2,445.55 |
| Ave. Total Daily Flow (m3/day) | 66,725.63 | 52,457.12 | 60,784.51 | 58,204 | .21 | 60,317.30 | 64,068.38 | 47,830.77 | 58,693.20 |